POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date : 23-Jan-17 Till now the maximum generation is : - 9036 MW 21:00 Hrs on 30-Jun-16 The Summary of Yester 22-Jan-17 Today's Actual Min Gen. & Probable Gen. & Demand Generation & Demand Hour Min. Gen. at Evening Peak Generation 7440.0 MW Hour 19:30 Max Generation 8831 MW Hour E.P. Demand (at gen end) 7440.0 19:30 Max Demand (Evening) 7700 Maximum Generation 7440.0 MW Hour 19:30 Reserve (Generation end) 2831 MW Total Gen. (MKWH) 138.1 System L/ Factor 77.33% Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -530 MW at 17:00 Energy 7.867 MKWHR Import from West grid to East grid :- Maximum Energy Water Level of Kaptai Lake at 23-Jan-17 Ft.(MSL) Actual: Rule curve : 98.80 99.40 Ft.(MSL) Gas Consumed: Total 885.32 MMCFD. Oil Consumed (PDB): Liter HSD : FO Liter Cost of the Consumed Fuel (F Gas Tk65,663,285 Coal Tk7,890,427 : Tk203,840,379 Total : Tk277,394,091 Load Shedding & Other Information Today Area Yesterday Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW (On Estimated Demand) Dhaka 0 0:00 2839 Chittagong Area 0:00 794 Khulna Area 0 0:00 792 0 0:00 771 Rajshahi Area Comilla Area 0 0:00 590 0 449 0:00 Mymensingh Are Sylhet Area 0 0:00 279 157 Barisal Area 0:00 0 0:00 434 Rangpur Area Total 7105

Information of the Generating Units under shut down.

Planned Shut- Down

Forced Shut- Down

1) Ghorasal ST: Unit-6 (18/07/201(10) Ghorasal Unit-2

2) Kaptai Unit-2 & 5 3) Ashuganj ST: Unit- 1 11) Sylhet 150 MW GT 12) Sikalbaha Peaking GT

4) Khulna ST 110 MW (04/11/2014 13) Sikalbaha ST 5) Ghorasal Unit-5 6) Baghabari 100 MW

14) Shahjibazar(Energyprima) 15) Shahjibazar GT: Unit- 8, 9

7) Haripur SBU GT- 1,2,3 8) Barapukuria ST: Unit-1 16) Saidpur GT 17) Fenchugonj CCPP-2

Comments on Power Interruption

9) Chittagong Unit-1

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

a) Hathazari 230/132 kV T3 transformer was under shut down from 10:05 to 17:10 for A/M.

b) Dohazari-Cox's bazar 132 kV Ckt-2 was under shut down from 08:53 to 16:53 for A/M.

c) Aminbazar 230/132 kV T1 transformer was under shut down from 09:57 to 22:53 for A/M. d) Julda-Sikalbaha 132 kV Ckt was under shut down from 08:56 to 15:30 for C/M.

e) Purbashadipur-Thakurgaon 132 kV Ckt-2 w as under shut down from 08:44 to 15:36 for A/M.

f) Sirajganj 132/33 kV T3 transformer w as under shut down from 10:48 to 11:48 for A/M.

g) Mymensingh S/S -Mymensingh RPCL 132 kV Ckt-2 was under shut down from 09:56 to 17:16 for A/M.

h) Chandpur 150 MW CCPP ST was under shut down at 14:02 due to lube oil leakage from bearing of turbine.

i) Sikalbaha 150 MW GT was synchronized at 14:44 and tripped at 15:32 again synchronized at 16:56 and tripped at 17:58.

j) Ashuganj 225 MW CCPP ST tripped at 14:59 due to problem with feed water pump.

k) Ashuganj(N) 450 MW CCPP GT was synchronized at 16:44.

I) Bheramara HVDC 400 kV 10CF13 filter tripped at 16:56 showing pole discrepancy.

m) Gulshan 132/33 kV T1 transformer was under shut down from 19:45 showing differential relay and

w as switched on at 00:25(23/01/2017)

Description

n) Bogra 132/33 kV T4 transformer was under shut down at 19:58 for development work.

o) After maintenance Summit Bibiyana CCPP GT & ST were synchronized at 21:54 & 00:09 (23/01/2017) respectively.

p) Ashuganj (S) 450 MW was shut down at 22:41 for intake air filter change work.

q) Goalpara-Bagherhat 132 kV Ckt-2 was under shut down at 07:29 (23/01/2017) for A/M.

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle