POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT 4-Feb-17 Reporting Date: 9036 MW 21:00 Till now the maximum generation is: -Hrs 30-Jun-16 on Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterda 3-Feb-17 5404.0 9:00 Day Peak Generation Min. Gen. at Evening Peak Generation 6870.0 MW Н 20:00 Max Generation 8870 E.P. Demand (at gen end) MW 20:00 6870.0 Max Demand (Evening) 7600 Maximum Generation 6870.0 MW 20:00 Reserve (Generation end) 2870 Total Gen. (MKWH) System L/ Factor 78.83% Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -360 MW at 16:00 Energy 7.867 Import from West grid to East grid :- Maximum MW at Energy Water Level of Kaptai Lake at 4-Feb-17 96.58 Ft.(MSL) Actual : 97.73 Ft.(MSL) Rule curve : 847.44 MMCFD. Oil Consumed (PDB): Gas Consumed: Total HSD FO Cost of the Consumed Fuel (F Gas Tk54,165,227 Tk14,804,316 : Tk151,036,548 Total: Tk220,006,090 Coal Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) 0.00 Dhaka O 2770 0 0:00 775 Chittagong Area Khulna Area 0 0:00 771 Raishahi Area 0 0:00 751 Comilla Area 0 0:00 576 Mymensingh Area 0 0:00 439 Sylhet Area 0 0:00 271 Barisal Area 0 0:00 153 Rangpur Area 0 0:00 424 Total 6930 0 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Ghorasal ST: Unit-6 (18/07/2010 10) Ghorasal Unit- 2 Nil 2) Kaptai Unit-2 & 5 11) Ghorasal Unit- 4(30/01/17) 3) Ashuganj ST: Unit- 1, 5 & GT-2 10) Thakurgaon (RZ) 4) Khulna ST 110 MW (04/11/2014 13) Sikalbaha ST 5) Ghorasal Unit-5 14) Shahjibazar(Energyprima) 6) Baghabari 100 MW 15) Shahjibazar GT: Unit-8, 9 7) Haripur SBU GT- 1,2,3 8) Summit Bibiana- 2 9) Chittagong Unit-1 & 2 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description **Comments on Power Interruption** a) Feni 132/33 kV T-2 transformer was under shut down from 07:15 to 14:36 for A/M. b) B.Pukuria 132/33 kV T-1 transformer was shut down at 09:10 for red hot maintenance at B-phase 132 kV CT connector and was switched on at 11:10. c) Ashuganj-225 MW CCPP ST was shut down at 10:22 for steam leakage from degenerator. d) Aminbazar-Mirpur 132 kV Ckt-2 tripped at 13:47 showing dist.RST at Mirpur end & dist.RST,SOTF at Aminbazar end and was switched on at 21:01. e) Kaliakoir-Aminbazar 230 kV Ckt-2 tripped at 16:20 due to LA burst at Aminbazar end. f) After maintenance Ashuganj #5 was synchronized at 01:33 (4/2/17). g) After maintenance Sikalbaha-150 MW GT was synchronized at 05:48 (4/2/17). h) Mymensing 132/33 kV T-2 transformer was shut down at 07:40 (4/2/17) for A/M.

- i) Ishurdi-Ghorasal 230 kV Ckt-2 & 1 tripped at 04:30 & 05:51 (4/2/17) showing dist.R-phase at Ishurdi end & primary & secondary protection at Ghorasal end and were switched on at 05:42 & 07:16 (4/2/17) respectively.
- j) Jessoré 132/33 kV T-3 transformer tripped at 23:26 showing E/F relay at 132 kV end & CB tripped at 33 kV end and was switched on at 04:04 (4/2/17).

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle