## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date : 2-Mar-17 Till now the maximum generation is : - 9036 MW 21:00 Hrs on 30-Jun-16 The Summary of Yester Today's Actual Min Gen. & Probable Gen. & Demand Generation & Demand 1-Mar-17 Hour Min. Gen. at Evening Peak Generation 7962.0 MW Hour : 19:00 Max Generation 9455 MW E.P. Demand (at gen end) 7962.0 19:00 Max Demand (Evening) 8200 Maximum Generation 7962.0 MW Hour 19:00 Reserve (Generation end) 1255 MW MW Total Gen. (MKWH) System L/ Factor 84.64% Load Shed 161.7 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum MKWHR. -400 MW at 10:00 Energy 7.867 Import from West grid to East grid :- Maximum Energy Water Level of Kaptai Lake at 2-Mar-17 92.84 Ft.( MSL ) Actual: Rule curve : 93.24 Ft.(MSL) Gas Consumed: Total 892.27 MMCFD. Oil Consumed (PDB): HSD : Liter FO Liter Cost of the Consumed Fuel (F Gas Tk70,155,154 Coal Tk13,632,469 : Tk420,855,516 Total : Tk504,643,139 Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW (On Estimated Demand) Dhaka 0 0:00 3024 Chittagong Area 0:00 845 Khulna Area 0 0:00 851 0 0:00 824 Rajshahi Area Comilla Area 0 0:00 625 475 0:00 Mymensingh Are 300 166 Sylhet Area 0 0:00 0:00 Barisal Area Rangpur Area 0 0:00 461 Total 7571 Information of the Generating Units under shut dow n. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010 10) Baghabari-71 MW 2) Kaptai Unit-2 & 5

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Comments on Power Interruption

b) Shahajibazar 330 MW CCPP GT-1 was shut down at 09:19 due to problem gas control valve and was synchronized at 10:24 again shut down at 11:16.

c) Mirpur-Uttara 132 kV Ckt was under shut down from 11:04 to 13:08 due to red hot at Y-phase CT of Mirpur end and was switched on at 13:08.

a) Ashuganj(N) 450 MW CCPP GT was synchronized at 08:52 and was shut down at 11:55 for turbine inspection.

- d) Julda-Halisahar 132 kV Ckt was under shut down from 11:39 to 13:05 to remove GI wire.
- e) Shahjibazar 330 MW ST tripped at 13:32 due to problem with control system.
- f) Sirajganj NWPGCL 225 MW GT & ST w ere synchronized at 03:45 & 05:20(02/03/2017) respectively.
- g) Khulna(S)-Shatkhira 132 kV Ckt tripped at 02:54 (02/03/2017) from Khulna(S) end showing E/F L1.

It is under maintenance.

Sub Divisional Engineer Executive Engineer Network Operation Division Network Operation Division About 30 MW power interruption has been running under Shatkira(S) S/S area since 02:54.

3) Ashuganj ST: Unit- 1, 4) Khulna ST 110 MW (04/11/2014) 5) Ghorasal Unit-2,5 6) Baghabari 100 MW 7) Haripur SBU GT- 1,3 8) Chittagong Unit-1 & 2 9) Thakurgaon (RZ)

> Superintendent Engineer Load Dispatch Circle