## POWER GRID COMPANY OF BANGLADESH LTD.

NATIONAL LOAD DESPATCH CENTER

DAILY REPORT Reporting Date:

Till now the maximum generation is:- 9036 MW 30-Jun-16 The Summary of Yester 5-Mar-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 6835.0 MM Hour 12:00 Min Gen at 5.00 4197 Evening Peak Generation 7488.0 MW Max Generation 9249 MW Hour 19:00 E.P. Demand (at gen end) 7488 0 MW Hour : 19:00 Max Demand (Evening) 8200 MW Reserve (Generation end) MW Maximum Generation 7488.0 MW Hour: 19:00 1049 Total Gen. (MKWH) мw 154.3 85.88% oad Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum 7.867 Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6-Mar-17 MW MKWHR.

Rule curve : 92.20 Ft.( MSL )

MMCFD.

HSD Liter FO Liter

QF-LDC-08

Page -

Cost of the Consumed Fuel (F Tk63.581.182 Gas

Coal Tk14.687.135 Oil : Tk312,170,423 Total: Tk390,438,741

## Load Shedding & Other Information

Area	Yesterday			Today	
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3083	-	-
Chittagong Area	0	0:00	862	-	-
Khulna Area	0	0:00	869	-	-
Rajshahi Area	0	0:00	841	-	-
Comilla Area	0	0:00	636	-	-
Mymensingh Area	0	0:00	484	-	-
Sylhet Area	0	0:00	307	-	-
Barisal Area	0	0:00	169	-	-
Rangpur Area	0	0:00	470	-	=
Total	0		7721	0	·

Information of the Generating Units under shut down.

Planned Shut- Down Forced Shut- Down

1) Ghorasal ST: Unit-6 (18/07/201(10) Baghabari-71 MW 2) Kaptai Unit-2 & 5

3) Ashuganj ST: Unit- 1,2 & 3 12) Sikalbaha Peaking GT 4) Khulna ST 110 MW (04/11/2014 13) Ghorasal ST: Unit-3

11) Sikalbaha ST

5) Ghorasal Unit-2,5 6) Baghabari 100 MW 7) Haripur SBU GT- 1,3 8) Chittagong Unit- 2

9)Thakurgaon (RZ)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Comments on Power Interruption Description

a) Ashuganj-225 MW GT & ST were shut down at 08:21 and GT was synchronized at 09:31. b) Sikalbaha-60 MW ST was shut down at 10:30 for gas shortage.

Nil

c) Madaripur 132/33 kV T-3 transformer was shut down from 10:52 to 11:58 for red hot maint.at 33 kV end.

d) Khulna(S)-Gallamari 132 kV Ckt-1 w as shut down from 11:43 to 17:15 for painting work at Gallamari end.

e) Ghorasal #3 was forced shut down at 12:29 due to boiler tube leakage.

f) Gallamari 132/33 kV T-2 transformer was forced shut down from 11:49 to 13:00 for 33 kV DS maintenance. g) Ashugani 132 kV Bus-2 was shut down from 13:55 to 17:07 for maintenance work.

h) Ashugani-Shahiibazar 132 kV Ckt-3 was shut down from 13:21 to 17:16 for red hot maint at Ashugani end.

i) Shahijibazar-330 MW GT-1 tripped at at 15:01 showing transfer valve fault and was synchronized at 17:54.

j) Ashuganj North GT was synchronized at 15:07 and was shut down at 20:45.

k) Haripur-Rampura 132 kV Ckt-2 tripped at 15:05 showing dist.A-N,Z1 and was switched on at 15:13.

I) Hasnabad 132/33 KV T-1 & T-5 transformers tripped at 16:42 showing DFF and associated 33 kV Bus section tripped due to flashing 33 kV Lalbagh feeder and was switched on at 17:04.

m) Tongi-Mirpur 132 kV Ckt tripped at 19:01 showing AB,Z1 at Tongi end and was switched on at 19:23. n) Tongi-Bashundhara 132 kV Ckt-1 tripped at 19:14 showing C-phase Z2,O/C at Tongi end & dist.BC-N,Z1

o) Ashuganj-comilla(N) 132 kV Ckt-1 tripped at 21:55 showing E/F relay from both end and was switched on at 22:20. p) Daudkandi-Sonargaon 132 kV Ckt-1 tripped at 23:06 showing dist.Z1 & E/F relay and was switched on at 23:13.

q) Haripur-Matuail 132 kV Ckt tripped at 23:02 showing dist.A-phase Z1,E/F relay and was switched on at 23:28.

r) Munsiganj-Katpotti 132 kV Ckt tripped at 23:09 showing differential relay.

s) Comilla(S)-Tripura 132 kv Ckt-2 tripped t 21:53 showing DTT,dist.ABC and was switched on at 23:18.
t) Comilla 132/33 kV T-1 & T-2 transformer tripped at showing O/C relay and was switched on at 22:22.

u) Joydevpur 132/33 kV T-3 transformer tripped at 01:14(6/3/17) showing main & back up protection trip and was switched on at 01:16(6/3/7).

v) Mymensing 132/33 kV T-1 & T-2 transformers tripped at 02:48(6/3/17) showing E/F relay and was switched on at 03:24(6/3/17).

w) Hathazari-Baraulia 132 kV Ckt-2 tripped at 05:43(6/3/17) showing dist.A,E/F,R-phase START

x) Hathazari-Baraulia 132 kV Ckt-1 tripped at 06:07(6/3/17) showing dist.A,E/F and was switched on at 06:50(6/3/17)

y) Hathazari-AKSML 230 kV Ckt tripped at 05:43(6/3/17) showing D3p,RE2,START line-1 and was switched on at 07:52(6/3/17).

c) Hathazari 230/132 kV MT-1,MT-2,MT-3 & MT-4 transformers tripped at 06:07(6/3/17) showing 11TS,1DY,11GL for MT-1 & MT-2 F/F for MT-3 & O/C F/F for MT-4 and MT-2 MT-3 were switched on at 06:46(6/3/17) MT-1 w as sw itched on at 07:10(6/3/17) & MT-4 w as sw itched on at 08:02(6/3/17). At the same time Sikalbaha-55 MW Julda-100 MW,Patenga-50 MW,ECPV-100 MW,Malancha & Kaptai-1 & 4 also tripped and were synchronized at 08:42,07:18,07:59,07:39, 09:44 ,07:15 & 07:35 respectively.

aa) Ashuganj 450 MW (South) tripped at 06:07(6/3/17) showing high frequency.

ab) Hathazari-Feni 132 kV Ckt-1 & 2 tripped at 06:07(6/3/17) showing E/F & O/C relays and were switched on at 06:40 & 06:59(6/3/17) respectively.

About 56 MW power interruption occurred under Hasnabad S/S areas from 16:42 to 17:04

About 28 MW power interruption occurred under Matuail S/S areas from 23:02 to 23:28

About 400 MW pow er interruption occurred under Chittagong zone S/S areas from 06:07 to 06:46(6/3/17).

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle