

Till now the maximum generation is :-			21:00		Hrs on 30-Jun-16	
The Summary of Yesterday 29-Mar-17			Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand	
Day Peak Generation	: 6650.0	MW	Hour :	12:00	Min. Gen. at	4:00 5367
Evening Peak Generation	: 8099.0	MW	Hour :	19:30	Max Generation	: 9415
E.P. Demand (at gen end)	: 8099.0	MW	Hour :	19:30	Max Demand (Evening)	: 8700
Maximum Generation	: 8099.0	MW	Hour :	19:30	Reserve (Generation end)	: 715
Total Gen. (MKWH)	: 164.8	System L/ Factor	:	84.79%	Load Shed	: 0

Export from East grid to West grid :- Maximum	-190	MW	at 10:00	Energy	7.867
Import from West grid to East grid :- Maximum	-	MW	at -	Energy	-

Rule curve : 88.51 Ft.(MSL)

Oil Consumed (PDB) :

Oil : Tk359,881,640

HSD :
FO :

Area	Yesterday		Estimated Demand (S/S end)	Today	
	MW			Estimated Shedding (S/S end)	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	3286	-	-
Chittagong Area	0	0:00	919	-	-
Khulna Area	0	0:00	933	-	-
Rajshahi Area	0	0:00	900	-	-
Comilla Area	0	0:00	675	-	-
Mymensingh Area	0	0:00	513	-	-
Sylhet Area	0	0:00	331	-	-
Barisal Area	0	0:00	179	-	-
Rangpur Area	0	0:00	500	-	-
Total	0		8236	0	

	Planned Shut-Down	Forced Shut-Down
	Nil	1) Ghorasal ST: Unit-6 (18/07/10) 2) Kaptai Unit-2 & 5 3) Ashuganj ST: Unit- 1,2,4 4) Khulna ST 110 MW (04/11/2014) 5) Ghorasal Unit-4,5 6) Baghabari 100 MW 14) Tongi GT 8) Chittagong Unit-2 9)Thakurgaon (RZ)
		10) Sikalbaha ST 11) Ghorasal ST: Unit-1

Description	Comments on Power Interruption
a) Natore-Ishurdi 132 kV Ckt-1 was under shut down from 09:15 to 10:31 for red hot maintenance at Y-phase CB terminal at Natore end.	
b) Rajshahi 132/33 kV T3 transformer was under shut down from 11:55 to 12:31 for red hot maintenance at 33 kV airport feeder.	About 40 MW power interruption occurred under Rajshahi S/S areas from 11:55 to 12:31.
c) Sikalbaha 225 MW (new) was synchronized at 13:10.	
d) Bogra 230/132 kV TR1 transformer tripped at 13:02 showing lock out relay at HV side and was switched on at 13:21.	
e) Barishal 132/33 kV T1 & T2 transformer tripped at 11:53 showing O/C & instantaneous relay and were switched on at 12:09.	About 68 MW power interruption occurred under Barishal S/S areas from 11:53 to 12:09.
f) Bakulia-Khulshi 132 kV Ckt-1 was under shut down from 12:50 to 13:39 for red hot maintenance at R-phase CB	
g) Sikalbaha 150 MW was shut down due to gas shortage.	
h) Savar 132/33 kV T1 & T2 transformer tripped at 15:18 from 33 kV side showing O/C & E/F relay and were switched on at 15:49 & 16:17 respectively.	About 20 MW power interruption occurred under Savar S/S areas from 15:18 to 15:49.
i) After maintenance Kulaura 132/33 kV T2 transformer switched on at 15:57.	
j) Barishal-Patuakhali 132 kV Ckt tripped at 17:04 from Barisal end Showing O/C & E/F relay and was switched on at 23:40.	About 25 MW power interruption occurred under Patuakhali S/S areas from 17:04 to 23:40.
k) Barishal-Bhandaria 132 kV Ckt tripped at 19:42 from Barisal end Showing O/C relay and was switched on at 23:48.	
l) Barisal 132/33 kV T1 & T2 transformer tripped at 19:42 from 33 kV side showing O/C relay at 33 kV Jhalakhati feeder and were switched on at 19:55.	About 80 MW power interruption occurred under Barisal S/S areas from 19:42 to 19:55.
m) Basundhara-Rampura 132 kV Ckt-1 & 2 tripped at 21:54 from both end showing dist Z1 at Rampura end and protection operated LBP-1 at Basundhara end and were switched on at 22:18 & 22:49 respectively.	About 35 MW power interruption occurred under Basundhara S/S areas from 21:54 to 22:49.
n) Basundhara-Tongi 132 kV Ckt-1 tripped at 21:54 from Basundhara end Showing high speed BBS at Basundhara end and was switched on at 22:25.	
o) Ashuganj(S) 450MW CCPP ST is under shut down since at 04:28(30/3/17) due to problem of HPST line.	
p) Bheramara HVDC pole got tripped at 03:56 showing group differential operated and was switched on at 07:20.	
q) Khulna®-Noapara 132 kV Ckt-1 & 2 tripped at 07:37 from Khulna © end showing E/F & instantaneous relay and were switched on at 07:47 & 07:48(30/3/17) respectively	About 215 MW power interruption occurred under Noapara, Jessore Jhenaidah, Magura S/S areas from 07:37 to 07:47(30/3/17)..

About 40 MW power interruption occurred under Rajshahi S/S areas from 11:55 to 12:31.

About 68 MW power interruption occurred under Barishal S/S areas from 11:53 to 12:09.

About 20 MW power interruption occurred under Savar S/S areas from 15:18 to 15:49.

About 25 MW power interruption occurred under Patuakhali S/S areas from 17:04 to 23:40.

About 80 MW power interruption occurred under Barisal S/S areas from 19:42 to 19:55.

About 35 MW power interruption occurred under Basundhara S/S areas from 21:54 to 22:49.

About 215 MW power interruption occurred under Noapara, Jessore Jhenaidah, Maqura S/S areas from 07:37 to 07:47(30/3/17)..

Superintendent Engineer
Load Dispatch Circle