POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT 5-Apr-17 Reporting Date Till now the maximum generation is: 9036 MW 21:00 Hrs on 30-Jun-16 The Summary of Yesterda Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 4-Apr-17 Day Peak Generation Evening Peak Generation 6696 N Hour 12:00 Min. Gen. at Max Generation 5756 9519 MW 8231.0 Hour 19:00 E.P. Demand (at gen end) 8231.0 MW Hour 19:30 Max Demand (Evening) 8700 Maximum Generation 8231.0 MW Hour 19:30 Reserve (Generation end) 819 Total Gen. (MKWH) n L/ Factor Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 7.867 at 22:00 Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake a 5-Apr-17 Energy 86.56 Ft.(MSL) Rule curve : 87.20 Ft.( MSL ) Gas Consumed: Total 930.81 MMCFD. Oil Consumed (PDB) HSD : FO Tk62.239.138 Cost of the Consumed Fuel ( Gas Tk14,921,504 Total: Tk390,167,160 Coal Oil : Tk313,006,518 **Load Shedding & Other Information** Area Yesterday Today Rates of Shedding Estimated Demand (S/S end) Estimated Shedding (S/S end) MW MW (On Estimated Demand) Dhaka 0:00 3248 Chittagong Area 0 0:00 908 Khulna Area 0 0:00 921 Rajshahi Area 0 0:00 889 0 Comilla Area 0:00 668 Mymensingh A 0:00 507 Sylhet Area 0 0:00 326 0:00 177 Barisal Area Rangpur Area 0 0:00 494 Total 8138 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Ghorasal ST: Unit-6 (18/07/2010) 10) Sikalbaha ST 2) Kaptai Unit-2 & 5 11) Siddhirgonj GT: Unit-1& 2 Nil 12) Siddhirgonj ST 3) Ashuganj ST: Unit- 1 4) Khulna ST 110 MW (04/11/2014) 13) Tongi GT 5) Ghorasal Unit-1,5,6 14) Shahjibazar (Energyprima) 6) Baghabari 100 MW 14) Tongi GT 8) Chittagong Unit-1,2 9) Baghabari-71 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Bagerhat 132/33 kV T-1 & T-2 transformers were tripped at 08:08 due to Rampal feeder fault and swi About 40 MW power interruption occurred under Bagerhat S/S area at 08:12. from 08:08 to 08:12. b) After maintenance Ghorasal 230 kV CB for Max power plant was switched on at 12:45. c) After maintenance Hathazari-Kaptai Ckt-2 was energized at 15:33. d) After maintenance Aminbazar-Hasnabad 132 kV Ckt-1 was energized at 19:02. e) Ishurdi-Ghorasal 132 kV Ckt-2 was under shut down from 14:46 to 17:19 to remove GI sheet hanging from Ckt. f) Feni-Hathazari 132 kV Ckt-1 was tripped at 14:46 from both end showing Dist. A phase Z1 at both end and switched on at 15:03. g) After maintenance Chandpur STG was synchronized at 16:00. h) Ashuganj-Kishoreganj 132 kV Ckt-2 was tripped at 17:28 from both end showing Dist. BC at both end. Switched on at 17:46. i) Sikalbaha GT was shut down at 18:55 due to problem at fine filter.
j) Shazibazar 330 MW GT-1 & ST was tripped at 20:31 and synchronized at 01:34(05/04/2017)
k) Tangail 132/33 T-2 transformer was under shut down from 15:06 to 15:51 due to Red hot at 33 kV Bu About 70 MW power interruption occurred under Tangail S/S area from 15:06 to 15:51. I) Ullon-Rampura 132 kV under ground cable Ckt-2 was shut down at 05:54 (05/04/2017) for red hot maintenance at line DS at Ullon end. m) Shahazibazar 132/33 kV T-4 & T-6 transformer were tripped at 01:25 (05/04/2017) from both end showing buchholtz at T-4. T-6 transformers was switched on at 02:31(05/04/2017) n) After maintenance Sikalbaha 150 MW GT was synchronized at 02:01 (05/04/2017)

Sub Divisional Engineer Executive Engineer
Network Operation Division Network Operation Division

Superintendent Engineer Load Dispatch Circle

Page 1 of 7