## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT Reporting Date 6-Apr-17 9036 MW Till now the maximum generation is 21:00 Hrs 30-Jun-16 Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterda 5-Apr-17 Generation & Demand Day Peak Generation 6839.0 MW 12:00 5169 Hour Min. Gen. at 5:00 Evening Peak Generation 6911.0 MW Hour 19:00 Max Generation 9456 E.P. Demand (at gen end) MW 8600 6911.0 Hour 20:00 Max Demand (Evening) 6911.0 MM 20.00 Reserve (Generation end) 856 Maximum Generation Hour Total Gen. (MKWH) Load Shed 166.4 System L/ Facto 100.30% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 7.867 Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6-Apr-17 MW at Actual : 86.38 Ft.(MSL) Rule curve : 87.00 Ft.( MSL ) Gas Consumed: Total 875.86 MMCFD Oil Consumed (PDB) HSD FO Cost of the Consumed Fuel (F Gas Tk62 903 599 Total: Tk355,465,716 Coal Tk14,843,384 Oil : Tk277,718,733 Load Shedding & Other Information Area Today Estimated Shedding (S/S end) Yesterday Rates of Shedding Estimated Demand (S/S end) MW MW MW (On Estimated Demand) Dhaka 0.00 3232 Chittagong Area 0 0:00 904 Khulna Area 0 0.00 916 Rajshahi Area 0:00 884 Comilla Area 0 0:00 665 0:00 505 Mymensingh Area Svlhet Area 0 0:00 324 Barisal Area 0:00 177 Rangpur Area 0 0:00 492 Total 8099 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07/201010) Sikalbaha ST 11) Siddhirgoni GT: Unit-1& 2 Nil 2) Kaptai Unit-2 & 5 3) Ashuganj ST: Unit- 1 12) Siddhirgonj ST 4) Khulna ST 110 MW (04/11/201413) Tongi GT 5) Ghorasal Unit-1,5,6 14) Shahjibazar (Energyprima) 6) Baghabari 100 MW 15) Ghorasal unit-3 14) Tongi GT 8) Chittagong Unit-1,2 9) Baghabari-71 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Feni 132/33 kV T-2 transformer was under shut down from 09:11 to 12:05 due to Red hotat 33 kV CT R phase, B phase. b) Ashugonj-Kishoregonj 132 Ckt-2 tripped at 12:23 from both end showing Dist. B,C from Ashugonj end and from Dist. B,C from Kishoregonj and switched on at 12:26. c) Hathazari-Kaptai 132 kV Ckt-1 was under shut down from 09:12 to 18:21. d) Feni-Comilla(N) 132 kV line tripped at 12:26 from both end showing Dist. A,B,C,Z2 from Comilla(N) and Dist. A,Z1 from Feni and switched on at 11:11(06/04/2017). e) Sylhet 132/33 kV T-2 transformer 33 kV bus was under shut down from 10:14 to 11:08 due to Red hot at 33 kV side. f) Sylhet 132/33 kV T-1 transformer was under shut down from 11:22 to 13:53 due to Red hot at 33 kV Bus. d) Kulaura 132/33 kV T-1 transformer was tripped at 13:26 showing O/C and switched on at 13:56. h) Comilla(S)-S.M.Nagar both Ckt tripped at 12:25 showing C phase,Z1 at Comilla end and switched on at 13:02 and 13:38 respectively. i) Comilla(N)-Feni 132 kV Ckt-1 tripped at 14:44 from Comilla end showing Dist. A,B phase,Z2,ARC and switched on at 14:53. Ashugonj - B. Baria 132 kV Ckt-2 was tripped at 15:12 from both ends showing Dist. A,B phase at network end and Dist. Z1,Z2 at B.Baria end and switched on at 15:43. k) Feni-Hat hazari 132 kV Ckt-2 was tripped at 15:49 from Feni end showing Dist. A,Z1 and switched on at 16:15. I) Ashugonj-Kishoregonj 132 kV Ckt-2 was tripped at 16:00 from both ends showing Dist. A at Ashugonj and Dist. B,C at Kishoregonj end. m) Baraulia 132/33 kV T-1 & T-2 transformers were tripped at 16:30 at 33 kV side only due to 33 kV Feeder fault and About 48 MW power interruption occurred under Baraulia S/S area from 16:30 to 17:10. switched on at 17:10. n) Bhola-Barisal 230 kV was tripped at 19:06 from both ends showing Dist at Bhola end and Dist. Z1,L3 trip and switched o) Barisal-Bhandaria 132 kV Ckt tripped at 18:29 from both ends showing Dist. C from Barisal end and Dist. Z1 from Bhandaria and tried to switched on at 20:30 and tripped again showing SOTF p) Hasnabad 33 kV bus was shut down at 21:45 to attend Red hot at 33 kV REB feeder.

- q) Bhola 225 MW CCPP STG was shut down at 21:06 for maintenance.
- r) EGCB 412 CCPP ST was shut down at 01:14 due to High positive ion in water.
- s) Ghorasal P/S unit-3 tripped at 01:45 showing condenser vacumme pressure low.
- t) Kodda PPP tripped at 23:20 showing fuel line problem and synchronized at 05:21(06/04/2017).
- u) Ullon ring bus closed and Shiddhirgonj 132 kV Ckt-1&2 opened from ullon end at 06:05.
- v) Cox'sbazar S/S 33 kV Bus is shut down at 06:14 (06/04/2017) for bus extension work and closed at 08:44.
- w) Ashugonj-Comila 230 kV Ckt-1 has been shut down at 07:09 due to Red hot at isolator at Ashugonj end.

x) Bhola GT-1&2 have been shut down at 07:03 and 07:14 respectively.

About 50 MW power interruption occurred under Cox'sbazar S/S area from 06:14 (06/04/2017) to 08:44.

Sub Divisional Engineer **Executive Engineer** Superintendent Engineer Page 1 of 7 Network Operation Division **Network Operation Division** Load Dispatch Circle