POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date: 17-Apr-17 Till now the maximum generation is: -9036 MW 21:00 Hrs on 30-Jun-16 The Summary of Yeste 16-Apr-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 6129.0 12:00 Min. Gen. at 7:00 6022 Evening Peak Generation 8505.0 MW MW 19:30 Max Generation 9998 E.P. Demand (at gen end 8505.0 MW19:30 9000 MW Max Demand (Evening) Maximum Generation 8505.0 MW 19:30 Reserve (Generation end) 998 MW Total Gen. (MKWH) 161.5 System L/ Factor 79.11% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :-Maximu -380 MW 9:00 Energy 7.867 MKWHR. Import from West grid to East grid :- Maximu MW at Energy MKWHR. Water Level of Kaptai Lake a 17-Apr-17 Actual 82.63 Ft.(MSL) Rule curve : 84.80 Ft.(MSL) 946 21 MMCFD Gas Consumed Total Oil Consumed (PDB): HSD : Liter FO Liter Cost of the Consumed Fu Tk63,984,793 Gas Coal Tk2,851,489 Oil : Tk319,646,460 Total: Tk386,482,742 **Load Shedding & Other Information** Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0:00 3333 Chittagong Area 0 0:00 932 Khulna Area 0 0:00 948 Rajshahi Area 0 0:00 913 Comilla Area 0 0:00 685 Mymensingh Ar 0 0.00 519 Sylhet Area 0 0:00 336 Barisal Area 0 0:00 182 0:00 Rangpur Area 0 507 8355 Total 0 0 Information of the Generating Units under shut down. Forced Shut- Down Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/07/2010) Sikalbaha ST 11) Siddhirgonj GT: Unit-1& 2 2) Kaptai Unit-2 & 5 3) Ashuganj ST: Unit- 1,2 12) Tongi GT 4) Khulna ST 110 MW (04/11/20 13) Shahjibazar (Energyprima) 5) Ghorasal Unit-1,5 6) Baghabari 100 MW 7) Tongi GT 8) Chittagong Unit-1 9) Sikalbaha ST Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description **Comments on Power Interruption**

- a) After maintenance Barapukuria Unit-1 was synchronized at 10:24.
- b) Saidpur-Barapukuria 132 kV Ckt-2 was under shut down from 10:24 to 11:10 for tightening clamp at Saidpur end.
- c) Bheramara HVDC 230 kV 20DF21 filter was under shut down from 11:21 to 11:58 for cleaning broken trees.
- d) Manikganj 132/33 kV T2 transformer tripped at 11:57 showing differential relay and was switched on at 21:17.
- e) Khulna (S) 230 kV Bus-2 was under shut down from 09:58 to 17:08 for project work.
- f) Sylhet 150 MW GT was under shut down from 11:45 to 13:37 due to gas booster problem.
- g) Hathazari 132/33 kV T1 transformer was under shut down from 13:10 to 13:42 for oil filling.
- h) Raozan Unit-2 was synchronized at 16:41. i) Feni-Hathazari 132 kV Ckt-2 tripped at 16:37 from both ends showing dist.relay and was switched on at 16:44.
- j) After maintenance Jhenidah 132/33 kV 80/120 MVA T1 transformer was switched on at 21:22.
- k) After maintenance Kishoreganj 132/33 kV T3 transformer was switched on at 18:10.
- After maintenance 132 kV Capacitor bank was switched on at 21:22.
 M) Sikalbaha 150 MW was under shut down from 18:11 to 18:25 for due to switch over from natural gas to HSD.
- n) After maintenance Shahjibazar GT-8 was synchronized at 19:53.
- o) After maintenance Barapukuria Unit-2 was synchronized at 01:03 (17/04/2017).
- p) Sikalbaha 150 MW was shut down at 01:11 (17/04/2017) for air filter maintenance.
- g) Saidpur 132/33 kV T2 & T3 transformers were shut down at 06:25 (17/04/2017) for red hot About 25 MW power interruption occurred under Saidpur S/S area bus coupler breaker isolator and were switched on at 08:30 (17/04/2017). from 06:25 to 08:30 (17/04/2017).
- r) Sylhet 150 MW GT tripped at 02:00 (17/04/2017) due to turbine sensors fail.

Sub Divisional Engineer **Executive Engineer** Superintendent Engineer Page 1 of 7 **Network Operation Division Network Operation Division** Load Dispatch Circle