## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date : 1-May-17 9212 MW The Summary of Yesterday' 30-Apr-17 7395.0 Generation & Demand Today's Actual Min Gen. & Probable Gen. & De 12:00 MW Day Peak Generation MW Hour Min. Gen. at 7:00 4162 Evening Peak Generation E.P. Demand (at gen end) 8735.0 MW Hour 19:00 Max Generation 9955 MW 8735.0 8735.0 MW Max Demand (Evening) : Reserve (Generation end) MW MW 19:00 Hour 19:00 1055 Maximum Generation Total Gen. (MKWH) 165.9 79.15% Load Shed MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 200 7.867 MKWHR Energy Import from West grid to East grid :- Maximum MW MKWHR Water Level of Kaptai Lake at 6 1-May-17 Actual: 84.31 Ft.(MSL), Rule curve : 82.00 Ft.( MSL ) Gas Consumed : Total 930.47 MMCFD. Oil Consumed (PDB) HSD FO Tk67.476.633 Cost of the Consumed Fuel (PD Gas Tk14,804,312 Oil : Tk306,380,790 Total : Tk388,661,735 Load Shedding & Other Information Today Estimated Shedding (S/S end) Area Estimated Demand (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0.00 3302 923 938 Chittagong Area 0:00 Khulna Area Raishahi Area 0:00 904 678 515 332 . Comilla Area 0:00 Mymensingh Area Sylhet Area 0:00 Barisal Area 0:00 180 Rangpur Area 0:00 502 8274 Total Information of the Generating Units under shut down Forced Shut- Down Planned Shut- Down 4) Khulna ST 110 MW (04/11/2014) 12) Ashuganj CCPP 225 MW 5) Ghorasal Unit-1,5 6) Baghabari 100 MW 7) Tongi GT 8) Chittagong Unit-1 & 2 Additional Information of Machines, lines, Interruption / Forced Load shed etc. **Comments on Power Interruption** a) Bibiyana-Shajibazar 230 kV Ckt-1 was under shut down from 08:49 to 14:09 for project work About 104 MW Power interruption occurred under Lalbagh, Kamrangirchar S/S areas b) Kallyanpur 132 kV bus coupler tripped at 08:49 showing O/C.E/F relay and was switched on at 08:59 c) Rajshahi-Natore 132 kV Ckt-1 was under shut down from 10:03 to 13:06 for red hot maintenance at Natore end. d) Mirpur 132/33 kV T3 transformer was under shut down at 09:23 due to OLDC maint for 6 days. from 08:49 to 08:59 e) Madaripur 132/33 kV T2 transformer was under shut down from 08:42 to 09:26 for red hot maint f) Madaripur 132/33 kV T3 transformer was under shut down from 09:28 to 12:43 for red hot maint. g) Ashuganj # 5 tripped at 11:07 due to shaft vibration and was switched on at 11:41. n) Bheramara CCPP GT was synchronized at 19:19. ) Kabirpur-Tongi Ckt-2 was shut down from 16:21 to 17:30 for tree trimming. ) Kabirpur-Tongi Ckt-1 was shut down from 15:10 to 16:17 for tree trimming. ) Maniknagar-Narinda 132 kV Ckt-1 tripped at 15:57 from Maniknagar end showing main protection, pilot wire relay y maintaigar-team a 162 to 7 mpc at 1627 from maintaigar and showing main protection, pilot wire relay and was switched on at 16:03. Maniknagar-Narinda 132 kV Ckt-2 tripped at 16:23 from Maniknagar end showing main protection, pilot wire relay and was switched on at 16:36. n Rajshahi-Chapai 132 kV Ckt-1 & 2 tripped at 19:29 from both end showing ins E/F relay at Rajshahi end & dist relay at Chapai end and were switched on at 19:57 & 22:46 respectively. n) Ashuganj-Kishoreganj 132 kV Ckt-1 tripped at 22:32 from both end showing distance C phase relay and was switched on at 23:38. of Microsophia (Control of Microsophia) by Mymensing-Kishoreganj 132 kV Ckt-2 tripped at 22:22 from both end showing distance AB at Kishoreganj end & dist ABC Z2 at Mymensing end and was switched on at 22:37. b) Mymensing-Kishoreganj 132 kV Ckt-2 tripped at 22:22 from both end showing distance AB at Kishoreganj end & A dist ABC 1 at Netrokona end and were switched on at 22:48,23:41 respectively. Shyampur 132/33 kV T3 transformer is under shut down from 00:18 to 00:54 for red hot maintenance at 33 kV Y phase isolator. Sylhet-Fenchuganj 132 kV Ckt tripped at 23:36 from both end showing distance C-phase at Sylhet end & dist ABC 21 at Fenchuganj end and was switched on at 00:22 again trip from Sylhet end showing SOTF. Sylhet-Chatak 132 kV Ckt-2 tripped at 22:26 from both end showing distance B-phase Z2 at Sylhet end & dist B phase at Chattak end and was switched on at 00:30. ) Bibiyana 400 kV shunt reactor 1 & 2 tripped at 23:12 ) Kaliakoir 400/132 kV TR1 transformer tripped at 23:11 from 132 kV side showing pole discrepancy and was switched and 0.0102 ft 17 17 the dissolution in hipper at 20.11 ft of 10 2 kV state showing fold dissolutions of all was smilled in at 0.108(0.105/17). #Indunaghat-Sikalbaha 132 kV Ckt-1 & 2 tripped at 01:26 from both end showing dist R phase N at Madunaghat end & dist Z1 at Sikalbaha end and were switched on at 01:38 & 01:39 respectively. v) Halishahar-Kulshi 132 kV Ckt-2 tripped at 03:11 from Halishahar end showing E/F instantaneous relay and was switched y) Halishahar-Juldah 132 kV Ckt tripped at 03:11 from Halishahar end showing dist BCN relay and was switched on at 03:51(01/05/2017). x) Sikalbaha-Juldah 132 kV Ckt tripped at 03:15 from Sikalbaha end showing dist Z2 relay and was similared on at 04:03(01/05/17). y) Shamirpur-Juldah 132 kV Ckt tripped at 03:15 from Sikalbaha end showing dist Z2 relay and was switched on at 04:03(01/05/17). switched on at 04:05(01/05/17).

**Executive Engineer** 

**Network Operation Division** 

Superintendent Engineer

Page 1 of 7

Load Dispatch C

Sub Divisional Engineer

**Network Operation Division**