POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER

DAILY REPORT					
9212 MW	20:00	Hrs	on	Reporting Date : 18-Apr-17	19-Mav-17
Generation & Demand		Today's Actua	l Min Ge	n. & Probable Gen. &	Demand
MW	12:00	Min. Gen. at		8:00	6500
MW	21:00	Max Generation	n :		8753
MW	21:00	Max Demand (I	Evening)	:	8550
MW	22:00	Reserve (Gene	ration en	d)	203
System L/ Factor :	80.25%	Load Shed	:		0
RT/IMPORT THROUGH EAST-WES	T INTERCONNECTOR				
n -160	MW at	1:00		Energy	7.867
1 -	MW at	-		Energy	-
it 19-May-17					
	Rule curve: 78.58	Ft.(MSL)			
MMCFD.	Oil Consum	ed (PDB):			
	9212 MW Generation & Demand MW MW MW MW System L/ Factor : RT / IMPORT THROUGH EAST-WES 1160 1 11 19-May-17	MW 12:00 MW 12:00 MW 20:00 MW 21:00 MW 21:00 MW 21:00 MW 22:00 MW 22:00 MW 22:00 MW 22:00 MW 22:00 MW 22:00 MW 20:00 MW	Max Content Content	MW	My 12:00 My My My My My My My

HSD : FO:

Cost of the Consumed Fuel (Gas Tk64,920,975 Tk15,038,684

Oil : Tk429,732,990 Total : Tk509,692,649

Load Shedding & Other Information

Area	Yest	erday		Today	
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3187	-	-
Chittagong Area	0	0:00	891	-	-
Khulna Area	0	0:00	902	-	-
Rajshahi Area	0	0:00	871	-	-
Comilla Area	0	0:00	656	-	-
Mymensingh Are	0	0:00	499	-	-
Sylhet Area	0	0:00	319	-	-
Barisal Area	0	0:00	174	-	-
Rangpur Area	0	0:00	485	-	-
Total	0		7984	0	

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut- Down
	1) Ghorasal ST: Unit-6 (18/07/2010) 9) Haripur SBU-2
Nil	2) Kaptai Unit- 5 10) Sirajganj CCPP 210 M
	3) Ashuganj ST: Unit- 1 11) Tongi GT
	4) Khulna ST 110 MW (04/11/2014) 12) Saidpur GT
	5) Ghorasal Unit-1,5 13) Ashuganj CCPP(South
	6) Baghabari 100 MW 14) Fenchugonj CCPP-2
	7) Tongi GT 15)Santahar Peaking
	8) Chittagong Unit-1 & 2

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Comments on Power Interruption

- a) Kaliakoir-Tongi 230 kV Ckt-1 was under shut down from 10:07 to 11:21 for project work.
- b) Kaliakoir-Aminbazar 230 kV Ckt-1 was under shut down from 11:25 to 12:26 for project work.
- c) Uttara 132/33 kV T1 transformer was under shut down from 10:52 to 11:04 for PT fuse change at 3 About 10 MW Power interruption occurred under Uttara S/S area
- d) Kaliakoir-Tongi 230 kV Ckt-2 was under shut from 12:39 to 13:27 for project work.
- e) Kaliakoir-Aminbazar 230 kV Ckt-2 was under shut down from 13:32 to 15:00 for project work.
- g) Ghorasal-Joydevpur 132 kV Ckt-2 was under shut down at 08:20 due to oil leakage.

 g) Ghorasal-Joydevpur 132 kV Ckt-2 was under shut down from 15:45 to 17:22 for string maintenance.
- h) Rampura-Bashundhara 132 kV Ckt-1 was under shut down from 11:59 to 15:38 for tree trimming.
- i) Bibiyana-Kaliakoir 400 kV Ckt-1 was under shut down from 07:45 to 20:52 for development work. j) Khulna(S)-Satkhira 132 kV Ckt-2 (new) was switched on at 15:39.

- | |) Khulha(S)-Satkhira 132 kV Ckt-2 (new) was switched on at 19:12. |
 | K) Mirpur-Uttara 132 kV Ckt was switched on at 19:12. |
 | Goalpara 132/33 kV T5 & T6 transformers tripped at 20:23 from both end showing O/C due to 33 k About 27 MW Power interruption occurred under Goalpara S/S area feeder fault and were switched on at 20:28. |
 | M) Fenchuganj-Kulaura 132 kV Ckt-1 & 2 tripped at 04:20 (19/05/2017) from Fenchuganj end showin About 10 MW Power interruption occurred under Fenchuganj S/S area and were switched on at 05:58. At the same time Fenchuganj Barakatullah, Fenchuganj prima, Sylh from 04:20 to 05:58 (19/05/2017).
- prima got tripped and Barakatullah & Sylhet 10 MW were synchronized at 05:00 & 05:21 respectively n) Madaripur-Gopalganj 132 kV Ckt was shut down at 07:15 (19/05/2017) for development work.

About 40 MW Power interruption occurred under Gopalganj S/S area from 07:15 to till now.

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer **Load Dispatch Circle**

Page 1 of 7