POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER

DAILY REPORT

Reporting Date : 5-Jun-17 9471 MW Till now the maximum generation is: -22:00 Hrs on 27-May-17 The Summary of Yesterday's 4-Jun-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 7294.0 M/M Нο 12:00 7:00 6693 8823.0 Evening Peak Generation MW Max Generation 10120 Но 21:00 E.P. Demand (at gen end) : 8823.0 MW 21:00 Max Demand (Evening) Maximum Generation 8823.0 MW Нο 21:00 Reserve (Generation end) 320 System L/ Factor Total Gen. (MKWH) 88.09% Load Shed 186.5 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -80 MW 8:00 Energy 7.867 Import from West grid to East grid :- Maximum Energy Water Level of Kaptai Lake at 6:0(5-Jun-17 Actual 83.21 Ft.(MSL) Rule curve : 77.04 Ft.(MSL)

Gas Consumed : Total 1041.66 MMCFD

HSD FO

Tk73,582,735 Cost of the Consumed Fuel (PDB-Gas

Coal Tk10,663,796

: Tk457,266,193 Total : Tk541,512,724

Load Shedding & Other Information

Area	Yester	day	Today		
•••	MW		Estimated Demand (S/S end) MW	Estimated Shedding (S/S end) MW	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	3344	0	0%
Chittagong Area	0	0:00	1153	0	0%
Khulna Area	0	0:00	941	0	0%
Rajshahi Area	0	0:00	896	0	0%
Comilla Area	0	0:00	888	0	0%
Mymensingh Area	0	0:00	725	0	0%
Sylhet Area	0	0:00	304	0	0%
Sarisal Area	0	0:00	189	0	0%
Rangpur Area	0	0:00	549	0	0%
Total	0		8989	0	

Information of the Generating Units under shut down.

Planned Shut- Down

Nil

Forced Shut-Down

Oil Consumed (PDB)

Comments on Power Interruption

- 1) Ghorasal ST: Unit-6 (18/07/2010) 2) Kaptai Unit- 5 3) Khulna ST 110 MW (04/11/2014)
- 8) Haripur SBU-3 9) Ashuganj Unit-3 10) Sikalbaha ST
- 4) Ghorasal Unit-1.5 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1
- 11) Barapukuria ST: Unit-1 12) Ashuganj ST: Unit- 2

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description

a) Fenchuganj-Sylhet 132 kV Ckt was under shut down from 09:23 to 11:39 for red hot maintenance at Sylhet end. b) HVDC Bheramara-Ishurdi 230 kV Ckt-2 was under shut down from 09:37 to 13:37 for jumper clearance reduce by storm at Tower no-5.

- c) Rampura-Basundhara 132 kV Ckt-1 tripped at 13:44 from both end showing high impedance, dist & differential relays
- at Rampura end and main protection, PRD at Basundhara end and was switched on at 14:03.
- d) Chapainawabganj-100 MW was shut down at 10:32.
- e) Barapukuria ST Unit-1 was shut down at 17:17 due to super heater tube leakage
- f) After maintenance Ashuganj-B.Baria 132 kV Ckt-2 was switched on at 21:25.
- g) Lalmonirhat 132/33 kV T4 transformer was under shut down from 20:02 to 21:06 for red hot maintenance at 33 About 15 MW power interruption occurred under Lalmonirhat S/S area incomer breaker of R-phase isolator. from 20:02 to 21:06.
- h) Shahjibazar CCPP 330 MW tripped at 02:56 due to gas problem and was synchronized at 06:20(05/06/2017)
- i) Ashuganj ST Unit-2 tripped at 04:46 due to air pree heater tripped.

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer **Load Dispatch Circle**

Page 1 of 7