## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

1					Reporting Da	ate: 6-Jun-17
Till now the maximum generation is : -		9471 MW		22:00	Hrs on 27-May-1	7
The Summary of Yesterda	5-Jun-17	Generation & Demand			Today's Actual Min Gen. & Pro	bable Gen. & Demand
Day Peak Generation :	7765.0	MW	Hour :	11:00	Min. Gen. at 6:00	6058
Evening Peak Generation :	8336.0	MW	Hour:	21:00	Max Generation :	10275
E.P. Demand (at gen end):	8336.0	MW	Hour:	21:00	Max Demand (Evening) :	9800
Maximum Generation :	8343.0	MW	Hour:	3:00	Reserve (Generation end)	475
Total Gen. (MKWH) :	177.2	System L/ Factor :		88.50%	Load Shed :	0
		EXPORT/IMPORT THROUGH EAST-WES	T INTERCONNECT	OR		

Export from East grid to West grid :- Maximum 220 MW at 16:00 Energy 7.867 Import from West grid to East grid :- Maximum - MW at - Energy -

Water Level of Kaptai Lake at 6-Jun-17

tual: 84.47 Ft.(MSL), Rule curve: 77.30 Ft.(MSL)

Tk5,898,291

Gas Consumed : Total 1016.54 MMCFD. Oil Consumed (PDB) :

HSD : FO :

Cost of the Consumed Fuel (I Gas : Tk74,649,356

Oil : Tk374,249,817 Total : Tk454,797,464

## **Load Shedding & Other Information**

Area	Yesterday		Today				
	-		Estimated Demand (S/S end) MW	Estimated Shedding (S/S end) MW	Rates of Shedding (On Estimated Demand)		
MW							
Dhaka	0	0:00	3385	0	0%		
Chittagong Area	0	0:00	1167	0	0%		
Khulna Area	0	0:00	954	0	0%		
Rajshahi Area	0	0:00	908	0	0%		
Comilla Area	0	0:00	899	0	0%		
Mymensingh Are	0	0:00	734	0	0%		
Sylhet Area	0	0:00	309	0	0%		
Barisal Area	0	0:00	191	0	0%		
Rangpur Area	0	0:00	556	0	0%		
Total	0		9103	0			

Information of the Generating Units under shut down.

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Comments on Power Interruption

- a) Bhulta-Ghorasal 132 kV Ckt was under shut down from 08:42 to 10:40 for finger of isolator replacement at Bhulta end .
- b) Madunaghat-Sikalbaha 132 kV Ckt was under shut down from 09:33 to 10:40 for red hot at wave trap of Madunaghat end.
- c) Kishoreganj 132 kV T2 transformer was under shut down from 10:18 to 13:42 for 33 kV loop replacement .

d) Ghorasal-Ishurdi 230 kV Ckt-1 tripped at 12:37 from both sides showing DT,PTAW at Ghorasal end and PD-3,DT at

Ishurdi end and was switched on at 13:16.
e) Hasnabad-Kamrangirchar 132 kV Ckt tripped at 13:55 from Hasnabad end showing dist Z2 A-phase Abou

e) Hashabad-Kamrangirchar 132 kV Ckt tripped at 13:55 from Hashabad end showing dist 22 A-phase and was switched on at 14:01.

About 5 MW power interruption occurred under Kamrangirchar S/S area

from 13:55 to 14:01.

- f) Aminbazar 230/132 kV T2 transformer was under shut down from 15:05 to 15:58 for red hot maintenance at 132 kV end.
- g) Khulna CCPP 225 MW GT synchronized at 17:57.
- h) Barisal 132/33 kV T1 & T2 transformers tripped at 19:43 from 33 kV sides showing inst. O/C due to Muladi fet About 54 MW power interruption occurred under Barisal S/S area and was switched on at 19:49.
- i) Barisal-Bhandaria 132 kV Ckt tripped at 19:44 from Barisal end showing O/C and was switched on at 19:55. i) Saidpur 132/33 kV T2 transformer was under shut down from 20:15 to 20:55 for 33 kV B-phase CT red hot maintenance.
- J) Salopur 132/33 KV 12 transformer was under snut down from 20:15 to 20:55 for 33 KV B-phase CT red not maintenance.
  K) Mongle 33 KV bus was under shut down from 22:43 to 23:11 due to excessive spark on the bushing of auxilia About 29 MW power interruption occurred under Mongle S/S area

k) Mongle 33 kV bus was under shut down from 22:43 to 23:11 due to excessive spark on the bushing of auxilia About 29 MW power interruption occurred under Mongle S/S area from 22:43 to 23:11.

l) Shyampur 33 kV bus under 132/33 kV T3 & T4 transformers were under shut down from 05:22 to 06:23 (06/04 About 29 MW power interruption occurred under Shyampur S/S area R-phase red hot at 33 kV Fatullah feeder. from 05:22 to 06:23(06/06/2017).

m) Halishahar 132/33 kV T2 & T3 transformers tripped at 05:58 (06/06/2017) due to tripping of 33 kV Agra feed About 60 MW power interruption occurred under Halishahar S/S area were switched on at 06:45. from 05:58 to 06:45(06/06/2017).

n) Goalpara 33 kV bus under T5 & T6 transformers were shut down at 07:31(06/06/2017) for red hot maintenance

at R-phase bus isolator and were switched on at 09:22 , 09:20 & 09:21 respectively.

Sub Divisional Engineer Network Operation Division Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle

Page 1 of 7