

## Page -1

Reporting Date : 16-Jun-17

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Water Level of Kaptai Lake at 16-Jun-17

Actual : 102.32 Ft.(MSL) , Rule curve : 79.95 Ft.(MSL)

Cost of the Consumed Fuel (	<b>Gas</b>	:	Tk81,018,857			
	<b>Coal</b>	:	Tk14,491,823	Oil	:	Tk520,241,262
						Total : Tk615,751,942

Area	Yesterday		Today	
	MW	Estimated Demand (S/S end)	MW	Rates of Shedding (On Estimated Demand)
Dhaka	0	0:00	3276	0%
Chittagong Area	0	0:00	1129	0%
Khulna Area	0	0:00	920	0%
Rajshahi Area	0	0:00	877	0%
Comilla Area	0	0:00	871	0%
Mymensingh Area	0	0:00	711	0%
Sylhet Area	0	0:00	297	0%
Barisal Area	0	0:00	186	0%
Rangpur Area	0	0:00	539	0%
<b>Total</b>	<b>0</b>		<b>8806</b>	<b>0</b>

Information of the Generating Units under shut down.

Planned Shut- Down

Nil

### Forced Shut-Down

- 1) Ghorasal ST: Unit-6 (18/07/8)
- 2) Kaptai Unit- 5
- 3) Khulna ST 110 MW (04/11/10)
- 4) Ghorasal Unit-5
- 5) Baghabari 100 MW
- 6) Tongi GT
- 7) Chittagong Unit-1
- 8) Haripur SBU-3
- 9) Sikalbaha ST
- 10) Siddhirgonj GT: Unit-1& 2
- 11) Ashuganj (North)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Comments on Power Interruption
-------------	--------------------------------

- a) Khulna 225 MW CCPP St tripped at 09:25 due to drum level fluctuation and was synchronized at 15:54.
- b) Bogra 132/33 kV T4 transformer was under shut down from 11:20 to 12:03 due to station supply maintenance.
- c) Bhandaria 132/33 kV T1 transformer was under shut down from 11:06 to 13:44 due to R/H maintenance at Y-phase CT connector of 33 kV end.
- d) Sakalbahar 225 MW CCPP GT tripped at 13:13 due to problem with protection system.
- e) Halishahar 132/33 kV T1 & T2 transformers tripped at 16:54 due to 33 kV TSP feeder CT burst and were switched on at 17:02.
- f) Thakurgaon 132/33 kV T1 & T2 transformers tripped at 17:45 due to 33 kV feeder fault and were switched on at 18:28.
- g) Meghnaghat Summit GT1 was synchronized at 04:33 (16/06/2017).
- h) Rampura-Ghorasal 230 kV Ckt-2 was shut down at 05:00 (16/06/2017) due to development work.
- i) Tangail-Mymensingh 132 kV Ckt-1 & 2 were shut down at 05:29 (16/06/2017) for project work.
- j) Sathkhira-Khulna(S) 132 kV Ckt-1 was shut down at 06:24 (16/06/2017) for C/M.

About 60 MW power interruption occurred under Hali Shahar S/S areas from 16:54 to 17:02.

Sub Divisional Engineer  
Network Operation Division

Executive Engineer  
Network Operation Division

Superintendent Engineer  
Load Dispatch Circle