POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

Reporting Date : 23-Jun-17 Hrs Till now the maximum generation is : 9479 MW 21:00 7-Jun-17 on The Summary of Yesterda 22-Jun-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 7841.0 12:00 Min. Gen. at **Evening Peak Generation** 8947.0 MW 21:00 Max Generation 10115 E.P. Demand (at gen end) : 8947.0 MW 21:00 Max Demand (Evening) 9300 Maximum Generation 8961.0 MW 22:00 Reserve (Generation end) 815 Total Gen. (MKWH) System L/ Factor 89.39% 192.2 Load Shed 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum 0 MW at 15:00 Import from West grid to East grid :- Maximum MW at

Water Level of Kaptai Lake at 23-Jun-17

Actual: 103.84 Ft.(MSL) Rule curve : 81.84 Ft.(MSL)

Gas Consumed : Total 1032 74 MMCFD Oil Consumed (PDB):

> HSD FO

Comments on Power Interruption

Energy

Energy

7.867

Cost of the Consumed Fuel (Gas Tk77,384,134

Coal Tk13,866,842 : Tk446,655,145 Total: Tk537,906,121

Load Shedding & Other Information

Area	Yesterday		Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3266	0	0%
Chittagong Area	0	0:00	1126	0	0%
Khulna Area	0	0:00	917	0	0%
Rajshahi Area	0	0:00	874	0	0%
Comilla Area	0	0:00	868	0	0%
Mymensingh Are	0	0:00	709	0	0%
Sylhet Area	0	0:00	296	0	0%
Barisal Area	0	0:00	185	0	0%
Rangpur Area	0	0:00	537	0	0%
Total	0		8778	0	

Information of the Generating Units under shut down.

Description

Forced Shut-Down Planned Shut- Down 1) Ghorasal ST: Unit-6 (18/078) Haripur SBU-3 9) Sikalbaha ST 2) Kaptai Unit- 5 3) Khulna ST 110 MW (04/11 10) Siddhirgonj GT: Unit-1 11) Ashuganj #3 4) Ghorasal Unit-5 5) Baghabari 100 MW 12) Barapukuria-1 6) Tongi GT 7) Chittagong Unit-1

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

- a) Khulna(S) 230 kV Bus-2 was under shut down from 08:40 to 15:32 for development work. b) Bogra-Natore 132 kV Ckt-1 was under shut down from 10:32 to 12:18 for corrective maintenance.
- c) Sylhet 132/33 kV T-4 transformer tripped at 09:50 showing O/C relay and was switched on at 11:35.
- d) After maintenance Sirajganj-225 MW GT & ST were synchronized at 12:58 & 14:46 respectively.
- e) Haripur-Siddirganj 132 kV Ckt-1,2 & 3 tripped at 18:04 showing dist.Z2,Z3 at Haripur end & ins.O/C,E/F & lockout at Siddirganj end and Ckt-2 & Ckt-3 were switched on at 18:58 & 18:40 respectively.Ckt-1 is under maint due to snap of conductor.
- f) Haripur-Maniknagar 132 kV Ckt-2 tripped at 18:17 showing dist.BY-phase,Z34 master relay trip at Haripur end and was switched on at 21:57.
- g) Chandpur-150 MW CCPP tripped at 23:50 due to first inlet gas pressure and was synchronized at 09:03.
- h) Shahjibazar-330 MW CCPP GT-2 was shut down at 01:04(23/6/17) for inlet air filter replacement.
- i) Barapukuria #1 was shut down at 06:00(23/6/17) for super heater tube leakage. j) Βagnapari-71 ivivv τripped at υδ:32(23/6/17) snowing lose of flame trip and was synchronized at υδ:υδ(23/6/17).

Sub Divisional Engineer **Executive Engineer** Superintendent Engineer **Network Operation Division** Network Operation Division **Load Dispatch Circle**