				ID COMPANY OF BANGLADESH LTD. NAL LOAD DESPATCH CENTER DAILY REPORT					QF-LDC-0 Page -	
Till now the ma	vimum aana	ration is :	9479 MW	2/1121 1121 0111	21:	00 Hrs on	Reporting Date : 7-Jun-17	17-Jul-17	- uge	
The Summary of		16-Jul-17	Generation & Demand		21.	Today's Actual Min Ger		. & Demand		
Day Peak Generat	ion :	8176.0	MW	Hour :	12:00		7:00	7668	MW	
Evening Peak Gen		9334.0	MW	Hour :	21:00		:	9960	MW	
E.P. Demand (at g Maximum Genera		9334.0 9334.0	MW MW	Hour : Hour :	21:00 21:00			9900 60	MW MW	
Total Gen. (MKW)		209.0	System L/ Factor :	Hour.	93.29%		<i>)</i>	0	MW	
	•		EXPORT / IMPORT	THROUGH EAST-WEST INTERCONNECTOR						
Export from East g				80	MW MW	at 9:00	Energy	7.867	MKWHR.	
	grid to East gr Vater Level of				IVIVV	at -	Energy	-	MKWHR.	
Actual :		t.(MSL) ,		Rule curv	re: 86.56	Ft.(MSL)				
Gas Consumed : "	Total	1017.13	MMCFD.		Oil Consu	umed (PDB):				
ous consumed .	Total	1017.10	WINIOI D.		Oil Oolise	amed (i DD).	HSD :		Liter	
							FO :		Liter	
0 1 1 1 0				T1.74.054.005						
Cost of the Consur	mea Fuei (i	Gas Coal	:	Tk74,354,325 Tk13,476,225	Oil	: Tk784,621,319	Total ·	Tk872,451,869		
		Ooui		11(10,470,220	011	. 11104,021,010	Total .	11072,401,000		
	Lo	ad Shedding	& Other Information							
Area	Yester	dav				Today				
	1 03(8)	y		Estimated Demand (S/S end)		Estimated Shedding (S/S	end)	Rates of Shed	ding	
	MW			MW			MW	(On Estimated I		
Dhaka	0	0:00		3415			0	0%		
Chittagong Area	0	0:00		1178			0	0%		
Khulna Area Rajshahi Area	0 0	0:00 0:00		964 916			0	0% 0%		
Comilla Area	0	0:00		906			0	0%		
Mymensingh Are	0	0:00		740			Ö	0%		
Sylhet Area	0	0:00		312			0	0%		
Barisal Area	0	0:00		193			0	0%		
Rangpur Area	0	0:00		561			0	0%		
Total	0			9185			0			
	Informati	on of the Gen	erating Units under shut dov	/n.						
	Planned Shut-	Down			Forced S	Shut- Down				
						asal ST: Unit-6 (18/07/2	010 8) Harinur	GT: Unit-1		
Nil						ai Unit- 5		na ST & GT		
						na ST 110 MW (04/11/2				
						asal Unit-5	11) Baghal			
						abari 100 MW	12) Ashuga			
					6) Tong		12) Ashage	ing Offic-4		
						agong Unit-1				
					1) Office	agong offic-1				
P	Additional Inf	ormation of I	Machines, lines, Interruption	on / Forced Load shed etc.						
			Description			С	omments on Pow	er Interruption		
a) Pagra Delecti	ri 122 IN O	10 0 1	ot 00:05 from P (Not 1.8 Delegable of one of Clat 2 - harving						
				kt-1 & Palashbari end of Ckt-2 showing						
	_		switched on at 08:32.	000 11/21/21/21/21/21/21/21/21/21/21/21/21/2	About 424	5 MW nower interruption and	urred under Dalach	hari Rangour So	idnur	
				3:05 from 230 kV side of Ckt-1 and 132 kV		About 435 MW power interruption occurred under Palashbari,Rangpur,Saidpur, Purbasadipur, Thakurgaon , Panchagar ,Lalmonirhat & Barapukuria				
of Ckt-2 showing BSR & O/C at Barapukuria 132 kV side and Ckt-2 was switched on at 09:10.						ilpur, Thakurgaon , Panchag s from 08:05 to 09:10.	ы, , саннонний СаВ	шарикина		
o) Pangny D	ikurio P D-	our Caldeon 4	22 kV Ckt 1 8 2 = -1t -1	own at 12:45 from Bangnin	O/O aidas	00.00 10 08.10.				
				own at 12:45 from Rangpur end.	About 12	MW power interruption occu	rrad undar Kishora	ani S/S areas		
d) Kishoreganj 132	2 kV bus-A wa	s under shut d	lown from 09:20 to 11:52 for	C/M.	1	20 to 11:52.	irea ariaer rasilore	ganj 0/0 areas		
e) Haripur CCPP 3	360 MW GT 8	ST tripped at	t 14:33 showing false fire ala	rm and were synchronized at 16:22 & 17:46 respe		.0.011.02.				
			ynchronized at 15:50.	,	1					
g) Kaptai Unit-3 tri	pped at 14:37	showing frequ	uency relay and were synchr	onized at 16:39.						
h) Sylhet-Chattak	132 kV Ckt-1 t	ripped at 17:4	I1 due to B-phase LA burst a	t Chattak end and was switched on at 22:58.						
i) Ashuganj CCPP	450 MW (Sour	h) was shut d	lown at 19:15 due to problem	at damper.						
j) Sylhet 150 MW tripped at 21:30 due to line tripping.						0.8484		0/0		
k) Kulshi 132/33 kV T1 & T2 transformers tripped at 22:59 from 33 kV sides due to 33 kV feeder fault and						0 MW power interruption occ 59 to 23:18.	urrea unaer Kulshi	oro areas		
were switched on at 23:18. I) Amnura 50 MW plant was shut down at 22:03 due to fuel shortage.						DO 10 23:10.				
			-							
	-		0:14(17/07/2017) due to fuel	_						
			, , ,	alance and was synchronized at 03:33.						
o) Ashuganj unit-2	was shut dow	n at 00:50 (17	7/07/2017) due to boiler tube	leakage.						
p) Khulna 55 MW t	tripped at 02:0	2(17/07/2017) due to 33 kV feeder proble	m.						
q) Faridpur 50 MW	/ was shut dov	n at 03:43 (1	7/07/2017) due to 132 kV inc	comer breaker open.						
r) Gopalganj 100 M	//W tripped at	03:46(17/07/2	2017) due to Gopalganj-Mad	aripur Ckt tripped.						
s) Gopalganj-Madaripur 132 kV Ckt tripped at 03:45(17/07/2017) from both end showing dist 3-phase and was						MW power interruption occu	rred under Gopalga	anj S/S areas		
s) Gopalganj-Mada	switched on at 05:02.						from 03:45 to 05:02(17/07/2017).			
	5:02.									
switched on at 0		ansformers tr	ripped at 02:02 (17/07/2017)	showing O/C due to 33 kV feeder fault and		MW power interruption occu	rred under Goalpar	a S/S areas		
switched on at 0	3 kV T5 & T6 t			showing O/C due to 33 kV feeder fault and	About 55		rred under Goalpar	a S/S areas		
switched on at 05 t) Goalpara 132/33	3 kV T5 & T6 t			showing O/C due to 33 kV feeder fault and	About 55	MW power interruption occu	rred under Goalpar	a S/S areas		

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle

Sub Divisional Engineer Network Operation Division