POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1

Reporting Date : 7-Jun-17 1-Sep-17 Till now the maximum generation is : 9479 MW 21:00 Hrs The Summary of Yesterda 31-Aug-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 7167 0 MW Hour 10.00 Min. Gen. at 7:00 5755 ΜW Evening Peak Generation 8053.0 MW Hour: 21.00 Max Generation 10348 MW MW E.P. Demand (at gen end) : 8053.0 MW Hour: 21:00 Max Demand (Evening) : 9400 Maximum Generation MW 8370.0 MW Hour 22:00 Reserve(Generation end) 948 Total Gen. (MKWH) System L/ Factor 89.75% Load Shed MW 180.3

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

MKWHR Export from East grid to West grid :- Maximum -200 MW at 19:00 Energy 7.867 MKWHR. Import from West grid to East grid :- Maximum MW at Energy

Water Level of Kaptai Lake at 1-Sep-17

Gas Consumed : Total

993 24

107.80 Ft.(MSL) 99.00 Ft.(MSL) Rule curve :

> HSD : Liter FO Liter

Cost of the Consumed Fuel (Gas Tk68,929,947

MMCFD

Coal Tk12,851,244 : Tk395,002,488 Total: Tk476,783,679

Oil Consumed (PDB):

Load Shedding & Other Information

Area	ea Yesterday		Today		
		•	Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3281	0	0%
Chittagong Area	0	0:00	1131	0	0%
Khulna Area	0	0:00	922	0	0%
Rajshahi Area	0	0:00	879	0	0%
Comilla Area	0	0:00	872	0	0%
Mymensingh Are	0	0:00	712	0	0%
Sylhet Area	0	0:00	298	0	0%
Barisal Area	0	0:00	186	0	0%
Rangpur Area	0	0:00	539	0	0%
Total	0		8820	0	

Information of the Generating Units under shut down.

Planned Shut- Down Forced Shut- Down 1) Ghorasal ST: Unit-6 (18/07 9) Haripur GT: Unit-1,2 2) Kaptai Unit- 5 10) Sikalbaha ST 3) Khulna ST 110 MW (04/1111) Ashuganj # 2,3 4) Ghorasal Unit-5 12) Siddhirgonj GT: Unit-1 5) Baghabari 100 MW & 71 MW 6) Tongi GT 7) Chittagong Unit-1,2 8) Siddhirgonj ST

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description

Comments on Power Interruption

- a) Comilla(N)-Chandpur 132 kV Ckt-2 tripped at 07:36 from both end showing Dist. A phase, ARB, DOC at Comilla(N) end and Dist. Relay at Chandpur end. Trial given at 08:40 but tripped again showing DOC at Comilla(N) end.
- b) After maintenance Ghorashal Unit-7 was synchronized at 09:30.
- c) Tangail 132/33 kV S/S 33 kV bus was under shut down from 08:11 to 10:16 due to Red hot at 33 kV B phase DS.
- d) Summit Meghnaghat GT-2 was shut down at 12:12.
- e) Sirajgonj NWPGCL Unit-2 was synchronized at 11:46.
- f) Tongi-Uttara tripped at 18:30 from Tongi due to LA burst at Tongi end at R phase.
- g) Tongi-Kabirpur 132 kV Ckt-1&2 tripped at 16:18 from Tongi showing O/C at Ckt-1 and CAT, CD, CE at Ckt-2 and synchronized at 16:35. h) Bheramara 360 MW CCPP G1 tripped at 19:26 showing inlet gas pressure low due to tripping of emergency shutoff valve of G1 CL
- and synchronized at 21:30.
- i) Shahjibazar 330 MW CCPP GT-1 was shut down at 00:20(01/09/2017) for replacing smoke detector.

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle