POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

OF-LDC-08

MKWHR.

Page -1

Reporting Date: 15-Sep-17 Till now the maximum generation is : 9479 MW 21:00 Hrs 7-Jun-17 on 14-Sep-17 The Summary of Yesterda Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 7799.0 12:00 Min. Gen. at 6829 **Evening Peak Generation** 9194.0 MW20:00 Max Generation 9600 MW E.P. Demand (at gen end) : 9194.0 MW Max Demand (Evening): 9500 MW 20:00 Reserve(Generation end) Maximum Generation 9194.0 MW 20:00 100 MW System L/ Factor Total Gen. (MKWH) 195.5 88.61% Load Shed 0 MW **EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR** Export from East grid to West grid :- Maximum -160 MW at 9:00 Energy 7.867 MKWHR.

MW

Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 15-Sep-17

979 32

Actual : 108.39 Ft.(MSL) Rule curve : 102.22 Ft.(MSL)

Gas Consumed : Total

HSD Liter FO Liter

Energy

Cost of the Consumed Fuel (Gas Tk71,784,196

Coal Tk13,124,672 : Tk552,956,402 Total: Tk637,865,271

at

Oil Consumed (PDB):

Load Shedding & Other Information

MMCFD

Area Yesterday			Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3317	0	0%
Chittagong Area	0	0:00	1144	0	0%
Khulna Area	0	0:00	933	0	0%
Rajshahi Area	0	0:00	889	0	0%
Comilla Area	0	0:00	881	0	0%
Mymensingh Are	0	0:00	720	0	0%
Sylhet Area	0	0:00	301	0	0%
Barisal Area	0	0:00	188	0	0%
Rangpur Area	0	0:00	545	0	0%
Total	0		8918	0	

Information of the Generating Units under shut down.

Planned Shut- Down	Forced Shut- Down	
	1) Ashuganj # 3	10) Meghnaghat CCPP
Nil	2) Kaptai Unit- 5	11) Sikalbaha Peaking GT
	3) Khulna ST 110 MW (04	I/11 12) Megnaghat CCPP GT-1
	4) Ghorasal Unit-3,5	
	5) Baghabari 100 MW	
	6) Tongi GT	
	7) Chittagong Unit-1,2	
	8) Sikalbaha ST	
	9)Baghabari-71 MW	

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Comments on Power Interruption Description

- a) Khulna-225 MW was shut down at 10:18 for filter change and was synchronized at 11:36.
- b) Meghnaghat 230 kV Bus-2 was shut down at 10:10 for maintenance and was switched on at 18:27.
- c) Ashuganj-Sirajganj 230 kV Ckt-1 tripped at 13:34 showing dist.Z1,RST and was switched on at 17:08.
- d) Sirajganj-225 MW CCPP GT & ST tripped at 13:35 showing dir.E/F relay and was synchronized at 15:35 & 17:20 respectively.
- e) Dohazari-Cox's bazar 132 kV Ckt-2 tripped at 16:47 showing dist.Z1 and was switched on at 17:05.
- f) Goalpara 132/33 kV T-5 & T-6 transformers tripped at 17:38 sh About 25 MW power interruption occurred under Goalpara S/S area on at 17:45. from 17:38 to 17:45.
- g) Ghorasal #7 was shut down at 00:33(15/9/17).
- ň) Kabirpur-Manikganj 132 kV Ukt-1 & 2 tripped´at 22:39 showing About 88 MW power interruption occurred under Manikganj S/S area from 22:39 to 22:54.
- i) Manikganj 132/33 kV T-2 transformer is under shut down at 07 About 18 MW power interruption occurred under Manikganj S/S area from 07:49 to 08:30(15/9/17).
- j) Unandpur-150 ivivy tripped at 07:14(15/9/17) que to electrical fault. k) Hatnazari 132/33 kV 1-1 transformèr is under snut down at 07:46 for corrective maintenance.

Sub Divisional Engineer **Executive Engineer** Superintendent Engineer Network Operation Division **Network Operation Division** Load Dispatch Circle