DAILY REPORT

Reporting Date : 18-Sep-17 Till now the maximum generation is :-9479 MW 21:00 Hrs 7-Jun-17 The Summary of Yesterday's 17-Sep-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 9:00 7445.0 MW Day Peak Generation Hou Min. Gen. at 7:00 6767 Evening Peak Generation 9094.0 MW Нου 20:00 Max Generation 9721 MW E.P. Demand (at gen end) 9094 0 MW Hou 20:00 Max Demand (Evening) : 9700 мw Maximum Generation 9094.0 MW Hou 20:00 Reserve(Generation end) 21 MW Total Gen. (MKWH) 193.2 System L/ Factor 88.53% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 10 MW 16:00 Energy 7.867 MKWHR Import from West grid to East grid :- Maximum MW Energy MKWHR

Water Level of Kaptai Lake at 6:00 18-Sep-17 108.80 Ft.(MSL) Rule curve : 102.91

> HSD Liter FO Liter

> > Total : Tk663,582,059

10) Megnaghat CCPP GT-1

Cost of the Consumed Fuel (PDB+I Tk69,974,919 Gas

968.71

Tk13,359,041 Coal

## Load Shedding & Other Information

MMCFD.

Area	Yesterday			Today	
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3411	0	0%
Chittagong Area	0	0:00	1176	0	0%
Khulna Area	0	0:00	962	0	0%
Rajshahi Area	0	0:00	915	0	0%
Comilla Area	0	0:00	905	0	0%
Mymensingh Area	0	0:00	739	0	0%
Sylhet Area	0	0:00	311	0	0%
Barisal Area	0	0:00	193	0	0%
Rangpur Area	0	0:00	560	0	0%
Total	0		9172	0	

Information of the Generating Units under shut down.

Planned Shut- Down

Nil

Total

Gas Consumed :

Forced Shut-Down

1) Ashuganj # 3

2) Kaptai Unit- 5 3) Khulna ST 110 MW (04/11/2014)

Ft.( MSL )

: Tk580,248,100

Oil Consumed (PDB):

4) Ghorasal Unit-3,5

5) Baghabari 100 MW 6) Tongi GT

7) Chittagong Unit-1,2 8) Sikalbaha ST 9)Baghabari-71 MW

from 21:10 to 22:10.

from 21:35 to 22:40.

from 23:35 to 23:40.

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Comments on Power Interruption

- a) Bhandaria 132/33 kV T1 & T2 transformers tripped at 09:04 from 33 kV sides due to 33 kV Matbaria feeder fau About 13 MW pow er interruption occurred under Bhandaria S/S areas from 09:04 to 09:06. and were switched on at 09:06.
- b) Goalpara 132/33 kV T5 & T6 transformers tripped at 10:07 due to 33 kV feeder fault and were switched on at 10:13.
- c) Bagherhat-Mongla 132 kV Ckt tripped at 10:14 showing inst. E/F and was switched on at 16:48. Due to this tripping KPCL-1 , KPCL-2 & Khulna (Aggreko) 55MW got tripped
- d) Goalpara -NWPGCL 132 kV Ckt tripped at 10:14 from NWPGCL end showing back-up protection and was switched on at 11:13.
- e) Barisal 132/33 kV T1 & T2 transformers tripped at 08:07 due to 33 kV feeder fault showing E/F and were switched on at 08:11. f) Comilla(N) 132/33 kV T3 transformer tripped at 08:07 showing inst E/F and w as switched on 19:24.
- g) Bogra-Naogaon 132 kV Ckt-1 tripped at 12:52 from both ends showing dist ABC Z1 and was switched on at 13:11. h) After maintenance Hathazari 230/132 kV T1 auto transformer was switched on at 14:19.
- After maintenance Bhandaria-Bagherhat 132 kV Ckt was switched on at 16:58.
  After maintenance Meghnaghat 230 kV bus was switched on at 14:52.
- k) After maintenance Hasnabad-Aminbazar 230 kV Ckt-1 & 2 w ere sw itched on at 15:08 & 16:56 respectively. i) Hathazari-Raozan 230 kV Ckt-2 w as switched on at 15:56
- m) Sikalbaha Peaking GT 150 MW was synchronized at 17:34.
- n) Chandpur 150 MW GT was synchronized at 17:23.
- o) Bashundhara 132/33 kV T3 transformer was shut down at 21:10 for red hot maintenance at HT CB and was switched on at 22:10.
- p) Lalmonirhat 132/33 kV T4 transformer w as under shut down from 21:35 to 22:40 for red hot maintenance.
- q) Gopalganj 132/33 kV T1 & T2 transformers tripped at 23:35 due to problem at T1 transformer CB.
- r) Bogra-Naogaon 132 kV Ckt-1 was under shut down from 07:33 to 10:10 (18/09/2017) due to B-phase strand
- damage near wave trap at Bogra end. s) Bagherhat-Bhandaria 132 kV Ckt tripped at 07:27 (18/09/2017) from both end showing DTEW Z1 at Bagherhat end
- & dist ABC at Bhandaria end.
- t) Julda S/S-Julda RPP Ckt was under shut down from 05:20 to 06:58(18/09/2017) for red hot maintenance at B-phase post insulator I clamp.

Sub Divisional Engineer Network Operation Division

Superintendent Engineer Load Dispatch Circle

About 47 MW power interruption occurred under Bashundhara S/S area

About 16 MW pow er interruption occurred under Lalmonirhat S/S area

About 60 MW pow er interruption occurred under Gopalganj S/S area

Executive Engineer Network Operation Division