## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

27-Sep-17

QF-LDC-08

Page -1

Reporting Date : 7-Jun-17 Till now the maximum generation is : 9479 MW 21:00 Hrs The Summary of Yesterda 26-Sep-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 8475 7 MW Hour 11.00 Min. Gen. at 7:00 7810 ΜW Evening Peak Generation 9431 0 MW Hour: 21:00 Max Generation 10002 MW MW E.P. Demand (at gen end) : 9431.0 MW Hour: 21:00 Max Demand (Evening) 10000 Maximum Generation 9431.0 MW Hour 0:00 Reserve(Generation end) MW Total Gen. (MKWH) System L/ Factor Load Shed MW 93.65%

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

MKWHR. Export from East grid to West grid :- Maximum -80 MW at 13:00 Energy 7.867 MKWHR. Import from West grid to East grid :- Maximum MW at Energy

Water Level of Kaptai Lake at 27-Sep-17

Gas Consumed : Total

1036 69

Ft.(MSL) 105.04 Ft.( MSL ) 108.78 Rule curve :

Oil Consumed (PDB):

HSD : Liter FO Liter

**Comments on Power Interruption** 

Cost of the Consumed Fuel ( Gas Tk83,975,591

Coal Tk12,773,116 : Tk657,936,708 Total: Tk754,685,415

## Load Shedding & Other Information

MMCFD

Area	Yesterday		Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
MW			MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3475	0	0%
Chittagong Area	0	0:00	1198	0	0%
Khulna Area	0	0:00	982	0	0%
Rajshahi Area	0	0:00	933	0	0%
Comilla Area	0	0:00	922	0	0%
Mymensingh Are	0	0:00	752	0	0%
Sylhet Area	0	0:00	318	0	0%
Barisal Area	0	0:00	196	0	0%
Rangpur Area	0	0:00	570	0	0%
Total	0		9346	0	

Information of the Generating Units under shut down

Planned Shut- Down Forced Shut-Down 1)Ashuganj CCPP(South) 10) Ashuganj-225 MW. 11)Ashugani CCPP(South) 2) Kaptai Unit- 5 3) Khulna ST 110 MW (04/11/2014) 4) Ghorasal Unit-5 5) Baghabari 100 MW

6) Tonai GT 7) Chittagong Unit-1,2 8) Sikalbaha ST 9)Baghabari-71 MW

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description

- a) Rajshahi 132/33 kV T2 transformer was under shut down from 08:28 to 09:16 for 🖟 About 20 MW power interruption occurred under Rajshahi S/S area b) Bogra 132/33 kV T3 transformer tripped at 11:20 for SF6 gas filling and was switch from 08:28 to 09:16.
- c) After maintenance Ashuganj-Sirajganj 230 kV Ckt-2 was switched on at 12:54.
- d) Kaliakoir-Tongi 230 kV Ckt-2 was under shut down from 09:26 to 17:24 for development work.
- e) Hasnabad-Sitalakha 132 kV Ckt was under shut down from 10:00 to 13:33 for corrective maintenance.
- f) Kaptai-Madunaghat 132 kV Ckt-1 was under shut down from 10:41 to 11:43 for red hot maintenance at Kaptai end.
- g) Sitalakha 132/33 kV T2 transformer was under shut down from 14:16 to 14:30 for relay test.
- h) Sitalakha 132/33 T3 kV transformer was under shut down from 15:40 to 16:01 for relay test.
- ) Shitalakha S/S Digital Gagnagar 132 kV Ckt was under shut down from 15:50 to 17:25 for relay test.
- j) Shitalakha- Madanganj 132 kV Ckt was under shut down from 16:55 to 17:58 for relay test.
- k) Sirajganj -Ashuganj 230 kV Ckt-1 was switched on at 20:04 from Sirajganj end.

- I) Barapukuria Unit-2 was shut down at 00:10 (27/09/2017) due to super heater problem.

  m) Sirajganj-Bogra 132 kV Ukt was shut down at 05:20 (27/09/2017) for development work.

  n) Bheramara 132 kV Ukt B-Bus was shut down at 05:46 (27/09/2017) for development work.
- o) Bogra-Natore 132 kV Ckt-1 was shut down at 07:21 (27/09/2017) for maintenance work.
- p) Shyampur 132/33 kV T3 & T4 transformers were under shut down from 06:52 to 0 About 50 MW power interruption occurred under Shyampur S/S area from 06:52 to 08:24 (27/09/2017). bus maintenance.
- q) Rampura-Gulshan 132 kV Ckt-1 was shut down at 05:52 (27/09/2017) for red hot maintenance
- r) Comilla(N)-BSRM 230 kV Ckt-1 tripped at 05:20 (27/09/2017) showing dist.relay and was switched on at 05:33(27/09/2017).

Sub Divisional Engineer Executive Engineer Superintendent Engineer Network Operation Division **Load Dispatch Circle Network Operation Division**