## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date : 3-Oct-17 Till now the maximum generation is:The Summary of Yesterday's 2-Oct-9479 MW Hrs 7-Jun-17 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand 2-Oct-17 12:00 Evening Peak Generation 9377.0 MW 19:30 Max Generation 10466 MW E.P. Demand (at gen end) : 9377.0 MW 19:30 Max Demand (Evening) 9800 MW Maximum Generation 9377.0 MW 19:30 Reserve(Generation end) 666 MW Total Gen. (MKWH) 200.4 System L/ Factor 89.06% Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 15:00 7.867 MKWHR 50 MW at Energy Import from West grid to East grid :- Maximum Energy MKWHR Water Level of Kaptai Lake at 6:00 3-Oct-17 Actual : 108.57 Ft.(MSL) Rule curve : 106.18 Ft.( MSL) Gas Consumed : 1034.11 MMCFD. Oil Consumed (PDB): HSD FO Liter Tk68,109,304 Cost of the Consumed Fuel (PDB+I Gas Tk13,163,736 Oil : Tk440,224,424 Total : Tk521,497,464 Load Shedding & Other Information

Area	a Yesterday		Today		
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3458	0	0%
Chittagong Area	0	0:00	1193	0	0%
Khulna Area	0	0:00	977	0	0%
Rajshahi Area	0	0:00	928	0	0%
Comilla Area	0	0:00	917	0	0%
Mymensingh Area	0	0:00	749	0	0%
Sylhet Area	0	0:00	316	0	0%
Barisal Area	0	0:00	195	0	0%
Rangpur Area	0	0:00	567	0	0%
Total	0		9300	0	

Information of the Generating Units under shut down.

Planned Shut- Down

Forced Shut-Down

Nil

1)Ashuganj CCPP(North)

2) Kaptai Unit- 5 3) Khulna ST 110 MW (04/11/2014)

4) Ghorasal Unit-2,4,5 5) Baghabari 100 MW 6) Tongi GT

7) Chittagong Unit-1,2 8) Sikalbaha ST 9)Baghabari-71 MW

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Comments on Power Interruption

- a) Kaliakoir-Tangail 132 kV line-2 was under shut down from 09:05 to 13:56 for protection test.
- b) Kamrangirchar-Hasnabad was under shut down from 09:11 to 12:52 for protection test.
- c) Serajganj-Ashuganj 132 kV line-1 w as under shut down from 09:14 to 17:41 due to development work.
- d) Kushiara GT tripped at 09:48 showing gas pressure low and synchronized at 10:28.
- e) Sikalbaha 150 MW GT tripped at 10:52 show ing unit protection trip.
- f) Thakurgaon 132 kV Bkr. No.902 was under shut down from 10:22 to 11:07 due to red hot.
- g) Rangpur 132/33 kV T-2 transformer was under shut down from 10:30 to 11:05 due to redhot at B phase bushing of 132 kV Bkr.
- h) Bhulta 132/33 kV T1 transformer was under shut down from 09:19 to 11:03 due to red hot at 132 kV Y phase CT connector.
- i) Kamrangirchar-Lalbag was under shut down from 12:52 to 15:12 due to protection test.
- j) Naogaon-Joypurhat 132 kV line tripped at at 13:49 from Naogaon showing Dist. Z1 and switched on at 14:02.
- k) Kaliakoir 400/132 kV TR1 transformer was under shut down from 14:52 to 17:01 for protection test.
- l) After maintenance Ghorashal unit-3 synchronized at 17:15. m) After maintenance Shikalbaha150 MW GT was synchronized at 18:46.
- n) Kabirpur-Manikgonj 132 kV Line1 was under shut down from 23:30 to 04:13(03/10/20107) due to attend re hot at Kabirpur end.

Sub Divisional Engineer Network Operation Division

Executive Engineer Network Operation Division

Superintendent Engineer Load Dispatch Circle