## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER OF-LDC-08 DAILY REPORT Page -1 Reporting Date : 20-Nov-17 Till now the maximum generation is 9507 MW 19:30 Hrs 18-Oct-17 The Summary of Yesterda Generation & Demand Today's Actual Min Gen. & Probable Hour 12:00 Day Peak Generation 6729.2 MW Min. Gen. at 5:00 5556 MW Evening Peak Generation 8693.0 Max Generation 9672 Hour E.P. Demand (at gen end) 8693.0 MW Hour 19:00 Max Demand (Evening) 8800 MW Reserve(Generation end) Maximum Generation 8693.0 MW 10.00 872 MW Hour System L/ Factor Total Gen. (MKWH) 165.7 79.41% Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 7.867 MKWHR. -180 at 17:00 Energy Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 20-Nov-17 MW MKWHR. 107.10 Ft.(MSL) Rule curve : 106.28 Ft.( MSL ) MMCFD. Gas Consumed: Total 930.46 Oil Consumed (PDB): HSD FO Liter Tk63,519,160 Cost of the Consumed Fuel (I Gas Coal Tk8,701,528 Tk271,750,055 Total: Tk343,970,743 Load Shedding & Other Information Area Yesterday Today Estimated Shedding (S/S end) Estimated Demand (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) 3070 1058 0:00 0 Chittagong Area 0:00 0 0% Khulna Area 0 0:00 856 0 0% Rajshahi Area 0 0:00 819 0% 0 Comilla Area n 0.00 818 n 0% 0% 0 0:00 669 Mymensingh Are Sylhet Area Barisal Area 0 0:00 275 0 0% 175 Rangpur Area 0 0:00 506 0 0% 8246 Total Information of the Generating Units under shut down Forced Shut-Down Planned Shut- Down 1) Barapukuria ST: Unit-1 10) Ashuganj #3 2) Kaptai Unit- 5 11) Siddirganj-210 MW ST 3) Khulna (04/11/14) 12) Haripur GT: Unit-1, 2 4) Ghorasal Unit-2,4 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1,2 8) Sikalbaha ST 9)Baghabari-71 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. **Comments on Power Interruption** Description a) Kabirpur-Manikganj 132 kV Ckt-2 was under shut down from 09:52 to 16:20 for A/M. b) Tongi-Bashundhara 132 kV Ckt-1 was under shut down from 08:31 to 15:52 for A/M. c) Haripur-Siddhirganj 230 kV Ckt-2 was under shut down from 10:30 to 17:26 for A/M. d) Aminbazar-Hasnabad 230 kV Ckt-1 was under shut down from 09:47 to 15:59 for A/M. e) Comilla(N)-BSRM 230 kV Ckt-1 was under shut down from 08:33 to 16:49 for A/M. f) Hathazari-Madunaghat 132 kV Ckt-1 was under shut down from 08:38 to 15:05 for A/M. g) Jamalpur 132/33 kV T1 transformer was under shut down from 08:24 to 16:23 for A/M. h) Netrokona 132/33 kV T1 transformer was under shut down from 08:08 to 15:30 for A/M.

- i) Mymensingh-Kishoreganj 132 kV Ckt-1 was under shut down from 09:25 to 15:57 for A/M.
- i) Tangail-Kaliakoir 230 kV Ckt-1 was under shut down from 08:18 to 16:05 for A/M.
- k) Hathazari 230/132 kV MT1 transformer was under shut down from 10:43 to 13:59 for C/M.
- l) B.Baria 132/33 kV T3 transformer was under shut down from 09:26 to 17:50 for A/M. m) Fenchuganj 132/33 kV T1 transformer was under shut down from 09:04 to 14:15 for A/M.
- o) Kulaura 132/33 kV T1 transformer was under shut down from 09:25 to 12:45 for A/M.
- p) Sirajganj-Bogra 230 kV Ckt-1 was under shut down from 08:15 to 16:56 for A/M.
- q) Palashbari 132/33 kV T2 transformer was under shut down from 08:35 to 16:06 for A/M.
- r) Baghabari-Ishurdi 230 kV Ckt-1 was shut down at 08:21 for A/M.
- s) Barapukuria 132/33 kV T4 transformer was under shut down from 09:36 to 13:15 for A/M.
- t) Satkhira 132/33 kV T2 transformer was under shut down from 09:08 to 13:30 for A/M.
- u) Khulna(C) 132/33 kV T3 transformer was under shut down from 09:20 to 16:17 for A/M.
- v) Gopalganj 132/33 kV T2 transformer was under shut down from 08:32 to 17:31 for A/M.
- w) After maintenance Ghorasal ST Unit-2 was synchronized at 12:25. x) Ashuganj ST Unit-4 was shut down at 12:51 due to gas shortage.
- y) After maintenance Ashuganj CCPP 225 MW GT & ST were synchronized at 13:44 & 22:29 respectively.
- z) Bogra-Sirajganj 132 kV Ckt tripped at 14:32 from Bogra end showing restricted E/F and was switched on at 15:22.
- aa) Gopalgani 132/33 kV T2 transformer tripped at 18:58 due to air pressure problem and was switched on at 19:55.
- ab) Haripur 412 MW ST tripped at 04:56(20/11/2017) due to problem with instrumentation air compressor and was synchronized at 07:26
- ac) B.Baria 132/33 kV T1 .T2 & T3 transformers tripped at 06;12(20/11/2017) showing over voltage and were switched on at 06:32.
- ad) Mirpur 132/33 kV T3 transformer tripped at 06:37 (20/11/2017) from both sides showing main protection trip at 132 kV side & E/F at 33 kV side.
- ae) Bashundhara-Rampura 132 kV Ckt-2 was under shut down from 08:28 to 16:27 for A/M

About 20 MW power interruption occurred under Gopalgani S/S areas from 18:58 to 19:55.

About 50 MW power interruption occurred under B.Baria S/S areas from 06:12 to 06:32(20/11/2017).

Sub Divisional Engineer Network Operation Division

**Executive Engineer Network Operation Division**  Superintendent Engineer **Load Dispatch Circle**