POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER QF-LDC-08 DAILY REPORT Page -1 Reporting Date 7-Dec-17 9507 MW Hrs 18-Oct-17 Till now the maximum generation is Today's Actual Min Gen. & Probai Min. Gen. at 5:0 Max Generation The Summary of Yesterda Day Peak Generation : Generation & Demand MW 6-Dec-17 5887.8 12:00 4582 MW Hour 5:00 Evening Peak Generation 7960.0 Hour MW F.P. Demand (at gen end) 7960.0 MW Hour 19:00 Max Demand (Evening) 8100 MW Maximum Generation 7960.0 MW 10.00 Reserve(Generation end) 1752 MM Total Gen. (MKWH) 143.7 System L/ Factor 75.19% Load Shed MW 0 EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 7.867 MKWHR. at 10:00 Energy Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 7-Dec-17 Energy MW at MKWHR 103.13 Ft.(MSL) Rule curve 105.46 Ft.(MSL) Gas Consumed : Total 873.33 MMCFD. Oil Consumed (PDB) : HSD : Liter FO Liter Tk78,116,232 Cost of the Consumed Fuel (I Gas Coal Tk0 Oil : Tk189.727.162 Total: Tk267.843.394 Load Shedding & Other Information Area Yesterday Today Estimated Demand (S/S end) Rates of Shedding (On Estimated Demand) Estimated Shedding (S/S end) MW MW MW Dhaka 0:00 2828 0% 0 Chittagong Area 0:00 974 0% 0% 0% 0% Khulna Area 0 0:00 780 0 0:00 751 757 Rajshahi Area 0 Comilla Area 0:00 0 0% 0% 0% 0% Mymensingh Are 0 0:00 619 0 Sylhet Area 0:00 250 0 . Barisal Area 0:00 162 Rangpur Area 7588 Total n Information of the Generating Units under shut down. Forced Shut-Down Planned Shut- Down 1) Barapukuria ST: Unit-1 & 2 10) Ashuqani # 2 2) Kaptai Unit- 5 11) Ashuganj North 3) Khulna S^{*} (04/11/14) 4) Ghorasal Unit-1,3,4,5 12) Sirajganj CCPP 1 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1,2 8) Sikalbaha ST 9) Baghabari-71 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption Description a) Meghnaghat-Comilla (N) 230 kV Ckt-2 was under shut down from 09:10 to 14:01 for A/M. b) New Tongi-Tongi 132 kV Ckt-2 was under shut down from 09:14 to 12:45 for A/M. c) Comilla(N)-Chandpur 132 kV Ckt-2 was under shut down from 08:32 to 16:30 for A/M. of Dollmianty-Charlupur 132 kV Ckt. was under shut down from 09:14 to 15:29 for S/S work. e) Jamalpur-Mymensingh 132 kV Ckt.-1 was under shut down from 08:10 to 16:15 for A/M. f) Hathazari-Baraulia 132 kV Ckt.-1 was under shut down from 08:10 to 16:16 for A/M. g) Fenchuganj-Sreemongal 132 kV Ckt.-2 was under shut down from 08:23 to 16:51 for A/M. Sylhet-Chatak 132 kV Ckt-2 was under shut down from 08:26 to 16:52 for A/M.) Chowmohoni 132/33 kV T1 transformer was under shut down from 08:20 to 13:15 for C/M.) Bogra(N)-Bogra(Old) 132 kV Ckt-1, 2 (one after another) were under shut down from 09:15 to 13:45 for A/M. k) Manikganj 132/33 kV GT-2 transformer and associated 132 kV Kabirpur Ckt-2 were under shut down from 09:15 to 17:06 for A/M 109:15 to 17:06 to 14M. () Gopalganj-Khulna(C) 132 kV Ckt-1 was under shut down from 08:31 to 17:01 for A/M. n) Khulna(S)-Satkhira 132 kV Ckt-1 was under shut down from 08:55 to 17:18 for A/M. n) Magura 13233 kV T2 transformer was under shut down 08:32 to 13:54 for A/M. b) Barapukuria 230/132 kV T02 transformer was under shut down from 09:45 to 17:49 for A/M.) Shaympur 132/33 kV GT1 & GT3 transformer tripped at 09:52 from both sides showing no relay and were About 46 MW power interruption occurred under Shaympur switched on at 10:33. r) Saidpur 132/33 kV T4 transformer was under shut down from 10:30 to 11:04 for B-phase CT oil leakage. S/S area from 09:52 to 10:33. About 8 MW power interruption occurred under Saidpur S/S area from 10:30 to 11:04. About 18 MW power interruption occurred under Saidpur s) Saidpur 132/33 kV T3 transformer was under shut down from 12:25 to 12:45 for red hot maintenance at 132 kV R-phase isolator. S/S area from 12:25 to 12:45. at 132 kV R-plase isolator. N Meghingaha 450 MW CCPP GT2 tripped 14:23 due to some control fault and was synchronized at 18:47. After maintenance Shahjibazar 330 MW CCPP GT2 was synchronized at 20:09. Barapukuria Unit-3 tripped at 21:02 due to excitation problem and was synchronized at 23:37. Sirajganj CCPP ST Unit-2 was synchronized at 00:45 (07/12/2017) for test purpose and tripped at 02:02. Chandpur 150 MW GT was shut down at 22:26 for replacing air filter.

y) Sylhet-Chatak 132 kV Ckt-2 tripped at 23:23 from both ends showing dist Z2 b-phase at Sylhet end and dist b-phase at Chatak end due to Y-phase L/A at Chatak end got burst. z) Ghorasal Unit-5 was shut down at 05:01(07/12/2017) due to steam line got cracked.

a) Sikalbaha 225 MW GT was synchronized at 06:46.

Sub Divisional Enginee Network Operation Division

Executive Engine Network Operation Division

Superintendent Engineer Load Dispatch Circle