Page -1

24-Dec-17 Reporting Date :

Till now the maximum generation is:-		9507 MW	19:30	) Hrs on 18-Oct-17						
The Summary of Yesterday's	23-Dec-17	Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand						
Day Peak Generation :	5383.5	MW	12:00	Min. Gen. at 4:00	4614	MW				
Evening Peak Generation :	7829.0	MW	19:00	Max Generation :	10378	MW				
E.P. Demand (at gen end):	7829.0	MW	19:00	Max Demand (Evening) :	8200	MW				
Maximum Generation :	7829.0	MW	19:00	Reserve(Generation end)	2178	MW				
Total Gen. (MKWH) :	136.9	System L/ Factor :	72.86%	Load Shed :	0	MW				
EYDORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR										

Export from East grid to West grid :- Maximum MW Energy 7.867 MKWHR. -410 at 17:00 Import from West grid to East grid :- Maximum MW MKWHR at Energy

Water Level of Kaptai Lake at 6:0 24-Dec-17

102.00 Ft.(MSL) Rule curve 103.80 Ft.( MSL )

Total 902.14 MMCFD. Oil Consumed (PDB): Gas Consumed:

HSD : FO : Liter

Cost of the Consumed Fuel (PDB+ Gas Tk76,084,085

Coal : Tk140,696,049 Total : Tk216,780,135 Tk0

## Load Shedding & Other Information

Area Yesterday			Today			
			Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding	
	MW		MW	MW	(On Estimated Demand)	
Dhaka	0	0:00	2885	0	0%	
Chittagong Area	0	0:00	994	0	0%	
Khulna Area	0	0:00	798	0	0%	
Rajshahi Area	0	0:00	767	0	0%	
Comilla Area	0	0:00	771	0	0%	
Mymensingh Area	0	0:00	631	0	0%	
Sylhet Area	0	0:00	256	0	0%	
Barisal Area	0	0:00	165	0	0%	
Rangpur Area	0	0:00	477	0	0%	
Total	0		7744	0		

Information of the Generating Units under shut down.

Planned Shut- Down Forced Shut-Down

1) Barapukuria ST: Unit-1,2 Nil 2) Kaptai Unit- 5

11) Sirajganj CCPP 1 3) Khulna ST 1(04/11/14) 12) Ashuganj ST: Unit- 2,5. 4) Ghorasal Unit-1,2,3,5,7.

10) Ashuganj CCPP(North)

5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1,2 8) Sikalbaha GT, ST 9) Baghabari-71 MW

## Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Comments on Power Interruption

- a) Siddhirganj 335 MW CCPP GT was synchronized at 08:46.
- b) Gulshan 132/33 kV T2 transformer w as under shut down from 08:10 to 15:52 for A/M.
- c) Siddhirganj-Ulon 132 kV Ckt-2 was under shut down from 08:51 to 20:55 for A/M.
- d) Siddhirgani 230/132 kV T1 transformer was under shut down from 08:41 to 16:22 for A/M. e) Hasnabad-Aminbazar 230 kV Ckt-1 was under shut down from 10:00 to 17:12 for A/M.
- f) Aminbazar-Meghnaghat 230 kV Ckt-2 w as under shut down from 09:03 to 16:45 for A/M.
- g) BSRM-Hathazari 230 kV Ckt was under shut down from 10:03 to 15:48 for A/M.
- h) Julda 132 kV main bus was under shut down from 09:15 to 15:34 for A/M.

About 18 MW Power interruption occurred under Julda S/S areas from 09:15 to 15:34.

- i) Jamalour-Mymensingh 132 kV Ckt-2 was under shut down from 08:54 to 17:03 for A/M.
- j) Ashuganj-B.Baria 132 kV Ckt-2 was under shut down from 10:27 to 14:52 for A/M.
- k) Ghorasal-Ishurdi 230 kV Ckt-1 was under shut down from 09:17 to 16:29 for A/M.
- I) Kabirpur 132/33 kV T3 transformer & reserve bus were under shut down from 08:52 to 15:48 for A/M.
- , m) Kaptai-Madunaghat 132 kV Ckt-2 w as under shut down from 06:43 to 20:08 for D/W. n) Bogra-Sirajganj 132 kV Ckt-2 w as under shut down from 08:37 to 16:10 for A/M.
- o) Khulna(S)-Khulna(C) 132 kV Ckt-2 was under shut down from 09:18 to 16:19 for A/M.
- p) Ishurdi 230/132 kV T1 transformer was shut down at 08:35 for A/M.
- q) Maniknagar-Narinda 132 kV Ckt-2 w as under shut down from 09:20 to 15:44 for A/M. r) Barisal 33 kV bus was under shut down from 11:16 to 13:55 for A/M. About 15 MW Pow er interruption occurred under Barisal S/S areas
- from 11:16 to 13:55.

s) Bhandaria-Bagherhat 132 kV Ckt tripped at 15:13 from both ends showing dist. Z1 abc at Bhandaria end

- & DSEW at Bagherhat end.
- t) Summit Bibiyana 341 MW CCPP ST was synchronized at 17:23. u) After maintenance Comilla(S)-Tripura 132 kV Ckt-1 w as switched on at 20:48.
- v) After maintenance Chandraghona-Kaptai 132 kV Ckt-1& 2 were switched on at 16:15 & 17:33 respectively.
- w) After maintenance Chandraghona-Madunaghat 132 kV Ckt-1& 2 were switched on at 15:59 & 20:40 respectively x) Ghorasal unit-5 tripped at 23:19 due to reason still unknown.
- y) Ashuganj (N) 450 MW CCPP GT tripped at 05:12(24/12/2017) due to under frequency O/C.
- z) Bogra 230/132 kV TR2 auto transformer was under shut down from 07:38 to 10:48(24/12/2017) for red hot maint.

Sub Divisional Engineer **Network Operation Division** 

**Executive Engineer Network Operation Division**  Superintendent Engineer Load Dispatch Circle