POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT QF-LDC-08 Page -1 Reporting Date : 6-Feb-18 Till now the maximum generation is : -The Summary of Yesterday's Day Peak Generation : 9507 MW Hrs 18-Oct-17 Generation & Demand 6805.2 MW Today's Actual Min Gen. & Probable Gen. & Demand Min. Gen. at 5:00 9:00 4871 MW Available Max Generation Evening Peak Generation 8247.0 MW 19:30 9160 MW E.P. Demand (at gen end) Maximum Generation 8247.0 MW 8247.0 MW 19:30 19:30 Max Demand (Evening) : Reserve(Generation end) 8400 MW 760 MW MKWHr System Load Factor : 78.80% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Total Gen. (MKWH) Load Shed 0 MW Export from East grid to West grid :- Maximum Import from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on -560 MW 2:00 MKWHR. Energy MW Energy MKWHR 6-Feb-18 Actual 97.99 Ft.(MSL) Rule curve 96.30 Ft.(MSL) Gas Consumed Total = 844.42 MMCFD. Oil Consumed (PDB) HSD Liter Cost of the Consumed Fuel (PDB+Pvt) : Tk80,528,415 Gas Coal Tk10,782,967 : Tk201,667,818 Total : Tk292,979,199 Load Shedding & Other Information Area Rates of Shedding Estimated Demand (S/S end) Estimated Shedding (S/S end) MW MW (On Estimated Demand) 0:00 0:00 0:00 Dhaka 2947 Chittagong Area Khulna Area 995 890 0% 0% 0% 0% 0% 0% Rajshahi Area 0 0:00 804 0 0:00 0:00 0:00 727 586 337 Comilla Area 0 0 lymensingh Area Sylhet Area . Barisal Area 0:00 151 0 Rangpur Area Total 0% Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-1 10) Chandpur CCPP 2) Kaptai Unit- 4,5 11) Ashuganj ST: Unit- 2,3,4 12) Siddirganj GT- 2 3) Khulna ST 110 MW 4) Ghorasal Unit-1,2,3,4 (04/11/14) 13) Siddirgani ST 14) Sirajganj-225 MW(Unit-1) 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1,2 8) Sikalbaha GT, ST 9) Baghabari-71 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. Comments on Power Interruption Description a) Sikalbaha 225 MW CCPP GT was synchronized at 11:20. a) Sindural a 229 MW GT was synchronized at 11.20. b) Sylhet 150 MW GT was synchronized at 12.37. c) Ashuganj-Kishoreganj 132 kV Ckt-2 was under shut down from 10.37 to 17:45 for development work. d) Feni-Hathazari 132 kV Ckt-2 was under shut down from 12:03 to 12:41 for CVT oil leakage. e) Aminbazar 230/132 kV T3 transformer was under shut down from 09:17 to 17:50 for A/M. f) Shahjibazar-Sreemongal 132 kV Ckt-2 was under shut down from 09:30 to 18:41 for A/M. g) Joydeypur 132/33 kV T3 transformer was under shut down from 09:17 to 11:08 for A/M. h) Hasnabad-Sitalakhya 132 kV Ckt was under shut down from 08:57 to 21:00 for corrective maintenance. ii) Hashiadad-oladakingki 132x N Crit was funder shipt ut own from 137 to 21.00 of to the curve maintenance. i) Ghorasal-Ishurdi 230 kV Ckt-2 tripped at 04:25 (06/02/2018) showing PTA5,PDC,PTAW relay at Ghorasal end and dist.relay at Ishurdi end and was switched on at 05:14 (06/02/2018). j) Aminbazar-Kaliakoir 230 kV Ckt-2 tripped at 05:05 (06/02/2018) showing CB pole discrepancy and was switched on at 05:32 (06/02/2018). switched on at 10:5.22 (10010/2/2016). Whanshad-Melphaghadt 205 NV Ckt-1 tripped at 05:23 (06/02/2018) showing dist.relay at Hasnabad end & CNZ1 at Meghnaghat end and was switched on at 06:02 (06/02/2018). U olydevpur-Kodda 132 kV Ckt-2 tripped at 06:48 (06/02/2018) showing dist.relay and was switched on at 07:06 (06/02/2018) 07:00 (0002/2016) M Mongla 13/33 kV T1 & T2 transformers tripped at 03:37 due to 33 kV PBS feeder fault and was switched on at 04:13 (02/06/2018). M Meghnaghat-Hasnabad 230 KV Ckt again tripped at 07:20 showing CVZ1 relay. Power interruption occurred (about 28 MW) under Mongla S/S areas from 03:37 to 04:13 (02/06/18) o) Sikalbaha 225 MW STG was synchronized at 23:53. p) Hasnabad-Kamrangirchar 132 kV Ckt tripped at 07:42 (06/02/2018) showing dist.relay and was switched on at

Sub Divisional Engineer Network Operation Division

07:51 (06/02/2018)

Executive Engineer
Network Operation Division

Superintendent Engineer Load Dispatch Circle