POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER

DAILY REPORT

Reporting Date:

QF-LDC-08 Page -1

Load Dispatch Circle

1-Mar-18 Till now the maximum generation is: 9507 MW 19:30 Hrs on 18-Oct-17 The Summary of Yesterday's 28-Feb-18 **Generation & Demand** Today's Actual Min Gen. & Probable Gen. & Demand 7419.3 MW Day Peak Generation 12:00 Min. Gen. at 5:00 Evening Peak Generation 8794.0 MW 19:30 Available Max Generation 9672 MW 8794.0 MW 19:30 9000 MW E.P. Demand (at gen end) Max Demand (Evening) Maximum Generation 8794.0 MW 19:30 Reserve(Generation end) 672 MW Total Gen. (MKWH) MKWHr 82.53% Load Shed 0 MW System Load Factor EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 20:00 Export from East grid to West grid :- Maximum -720 MW Energy MKWHR. at Import from West grid to East grid :- Maximum MW Energy - MKWHR. at Water Level of Kaptai Lake at 6:00 A M on 1-Mar-18 Actual: 94.42 Ft.(MSL) Rule curve 93.00 Ft.(MSL) Gas Consumed : Total = 916.00 MMCFD. Oil Consumed (PDB): HSD FO Liter Cost of the Consumed Fuel (PDB+Pvt): Gas Tk89,653,902 Tk11.331.257 Tk293.371.858 Total: Tk394.357.018 Coal **Load Shedding & Other Information** Area Yesterday Today Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW (On Estimated Demand) MW Dhaka 0 0:00 3182 Chittagong Area 0 0:00 1077 0% Khulna Area 0 0:00 964 0 0% 0 0:00 870 0% Raishahi Area 0 0 787 0% Comilla Area 0:00 0 0 0% Mymensingh Area 0:00 635 0 Sylhet Area 0 362 0% 0:00 0 Barisal Area 0 0:00 164 Λ 0% Rangpur Area n 0:00 490 0 0% Total 0 8530 0 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut- Down 1) Barapukuria ST: Unit-1 10) Ashuganj ST: Unit-2,3,4 Nil 11) Gopalganj Peaking 2) Kaptai Unit- 4,5 12) Bosila 108 MW 3) Khulna ST (04/11/14) 4) Ghorasal Unit-3,4,5 5) Baghabari 100 MW 6) Tongi GT 7) Chittagong Unit-1,2 8) Sikalbaha GT, ST 9) Baghabari-71 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description **Comments on Power Interruption** a) Chandpur CCPP GT was synchronized at 08:40. b) Ishwardi-Bheramara 132 kV Ckt-1 was shut down from 09:03 to 10:37 due to problem with 132 kV B-phase L/A at Ruppur S/S. c) Dohazari-Cox'sbazar 132 kV Ckt-2 was under shut down from 09:01 to 16:07 for C/M. d) Chandpur CCPP ST was synchronized at 14:01. e) Baghabari 71 MW was synchronized at 13:19. f) Comilla(N)-Chandpur 132 kV Ckt 2 was switched on at 17:01. g) Haripur S/S-Haripur P/S 132 kV Ckt-1 was under shut down from 14:45 to 15:07 due to CB problem. h) Hathazari 230/132 kV T3 transformer & 230 kV Bus were shut down at 19:27 due to red hot at Y-phase 821 M isolator and were switched on at 20:35, 20:36respectivly. i) Hathazari 230/132 kV T4 transformer was under shut down from 21:04 to 22:18 due to red hot at Y-phase 827 M isolator. j) Chittagong ECPV tripped at 18:07 due to PT problem and was synchronized at 03:55(01/03/2018). k) Ghorasal unit-7 was shut down at 06:25(01/03/2018) for opening damper and was synchronized at 09:23(01/03/2018). **Sub Divisional Engineer Executive Engineer** Superintendent Engineer

Network Operation Division

Network Operation Division