POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08

Page -1 Reporting Date 9507 MW Hrs 18-Oct-17 Till now the maximum generation is: Today's Actual Min Gen. & Probable Gen. & Demand 11-Mar-18 Generation & Demand The Summary of Yesterday's 7935.9 MW 12:00 6309 MW Day Peak Generation Min. Gen. at 5:00 Evening Peak Generation 9454.0 MW 19:00 Available Max Generation 10429 MW E.P. Demand (at gen end) 9454 0 MW 19:00 Max Demand (Evening) 9600 MW Maximum Generation 9454.0 MW 19:00 Reserve(Generation end) 829 MW Total Gen. (MKWH) MKWHr System Load Factor 80.43% EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR -660 MW Export from East grid to West grid :- Maximum 20:00 Energy MKWHR. Import from West grid to East grid :- Maximum MW Energy MKWHR. 12-Mar-18 Water Level of Kaptai Lake at 6:00 A M on 0.00 Ft.(MSL) 91.40 Ft.(MSL) Actual Rule curve Oil Consumed (PDB): Gas Consumed : Total = 983.38 MMCFD HSD Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Tk88,835,085 Gas : Tk437,520,090 Total: Tk526,355,174 **Load Shedding & Other Information**

Area	Yesterday			Today	
	·		Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
	MW		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	3417	0	0%
Chittagong Area	0	0:00	1158	0	0%
Khulna Area	0	0:00	1037	0	0%
Rajshahi Area	0	0:00	937	0	0%
Comilla Area	0	0:00	847	0	0%
Mymensingh Area	0	0:00	683	0	0%
Sylhet Area	0	0:00	387	0	0%
Barisal Area	0	0:00	176	0	0%
Rangpur Area	0	0:00	527	0	0%
Total	0		9170	0	

Information of the Generating Units under shut down

Planned Shut- Down		Forced Shut- Down			
		1) Barapukuria ST: Unit-1,2	10) Ashuganj ST: Unit- 2,3.		
	Nil	2) Kaptai Unit- 4,5	11) Bosila 108 MW		
		3) Khulna ST 110 MW (04/11/14)	· ·		
		4) Ghorasal Unit-4,5			
		5) Baghabari 100 MW			
		6) Tongi GT			
		7) Chittagong Unit-1,2			
		8) Sikalbaha ST			
		9) Baghabari-71 MW			

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description Comments on Power Interruption

- a) Chandraghona 132/33 kV T2 transformer was under shut down since at 08:02 for D/W.
- b) Gopalganj 132/33 kV T1 transformer was under shut down from 08:53 to 10:43 for About 20 MW Power interruption occurred under Gopalganj S/S areas bus isolator.
- c) Barisal-Bhandaria 132 kV line tripped at 12:56 from both end showing Distance Z-2, E/F relay at Barisal end and dist Z1 ABC phase on Bhandaria end and was switched on at 13:05.
- d) Meghna-Haripur 230 kV Ckt-1 was under shut down from 13:22 to 15:13 for loop maint at Haripur end.
- e) Sikalbaha 225 MW under went floating from 14:10 to 14:39 due to failure of backfeed power.
- f) Madunaghat-TK chemical 132 kV Ckt tripped at 14:13 showing O/C,E/F relay at TK end and was switched on at 14:52.
- g) Madunaghat-Sikalbaha 132 kV Ckt tripped at 14:15 showing Distance relay trip-1,trip-2 and was switched on at 14:23.
- h) Halishahar-Juldah 132 kV Ckt tripped at 14:15 from Juldah end showing O/C relay and was switched on at at 14:35.
- i) Above the tripping of line Ctg hole zone are tripped and flowing power plant Sikalbaha 150 MW, Sikalbaha 55 MW, ECPV, patanga, Dohazari are got tripped Juldah, Cox's & Shahmirpur S/S areas from 14:15 to 14:23.
- j) Sikalbaha-Bakulia 132 kV Ckt-1,2 were under shut down from 13:58 to 14:35 for bringing down Mad from the Tower.
- k) Jamalpur- Mymensing 132 kV Ckt was shut down from 15:55 to 17:20 for protection checking.
- I) Bheramara 410 MW CCPP STG tripped at 19:36 due to gas buster tripped & boiler dram level abnormal.
- m) After maintenance Ashuganj # 4 was synchronized at 21:47.
- n) Sirajganj 225 MW #1 was shut down at 17:04 due to fuel line filter problem.
- o) Maniknagar-Bangabhaban 132 kV Ckt-1 tripped at 05:34 from Maniknagar end showing pilot wire, main protection relay and was switched on at 06:02(12/03/2018).
- p) Hasnabad-Kamrangirchar 132 kV Ckt was shut down from 06:42 to 07:46 for conductor replacement at Kamrangirchar end
- q) Bagherhat 132/33 kV T1 & T2 transformer tripped at 21:54 showing E/F relay at C About 60 MW Power interruption occurred under Bagerhat feeder cable burst.

 S/S areas from 21:54 to 22:05.

Sub Divisional Engineer Network Operation Division Executive Engineer Network Operation Division Superintendent Engineer Load Dispatch Circle