			MPANY OF BANG OAD DESPATCH						QF-LDC-08	
		D	AILY REPORT				Reporting Date :	15-Mar-18	Page -1	
Till now the maximum generation is : -		9616 M	w		19:00	Hrs on	13-Mar-18	15-10121-16		
The Summary of Yesterday's	14-Mar-18		tion & Demand	40.00			Min Gen. & Probable		7	
Day Peak Generation : Evening Peak Generation :		80.9 MW 94.0 MW		12:00 20:00		Min. Gen. at Available Max Ge	5:00	6896 MW 10499 MW		
E.P. Demand (at gen end) :		94.0 MW		20:00		Max Demand (Ev		9700 MW		
Maximum Generation :		94.0 MW		20:00		Reserve(General	tion end)	799 MW		
Total Gen. (MKWH) :		Hr System	Load Factor : OUGH EAST-WEST II	83.51		Load Shed	:	0 MW	v	
Export from East grid to West grid :- Maximum				00 MW	at	7:00	Energy	МК	WHR.	
Import from West grid to East grid :- Maximum	0.00 A M	45.14	-	MW	at	-	Energy	- MK	WHR.	
Water Level of Kaptai Lake at Actual :	92.24 Ft.(MSL),	15-Mar-	18 Rule curve	a ·	90.76	Ft.( MSL )				
, total .	02.21 Fa(mor),		Tuio ourte		00.10	1(				
Gas Consumed :	Total = 94	3.98 MMCFD		Oil Co	onsumed (PDB):					
							HSD : FO :	Lite Lite		
								Lite	-	
Cost of the Consumed Fuel (PDB+Pvt) :	Gas		Tk84,724,334		01	TI-545 054 000	T-4-1 . T			
	002	al :	Tk9,808,240		Oil :	Tk545,654,289	Total : T	<sup>-</sup> k640,186,863		
	Load Shedding	g & Other Info	ormation							
Area	Vastarday					Today				
Area	Yesterday	Esti	mated Demand (S/S end	)		Today Estimated Shedd	ing (S/S end)	Rates of Shedding		
	MW		MW	, ,			MW (	On Estimated Deman	d)	
Dhaka	0 0:00 0 0:00		3424				0 0	0% 0%		
Chittagong Area Khulna Area	0 0:00 0 0:00		1161 1039				0	0%		
Rajshahi Area	0 0:00		939				0 0	0%		
Comilla Area	0 0:00		848				0	0%		
Mymensingh Area Sylhet Area	0 0:00 0 0:00		685 388				0	0% 0%		
Barisal Area	0 0:00		176				0	0%		
Rangpur Area	0 0:00		528				0	0%		
Total	0		9187				0			
1	nformation of the Generating	Units under sh	ut down.							
Plann	ed Shut- Down				d Shut-Down arapukuria ST	· I Init 1	10) Ashugani S	Tillnit 2.2		
Nil					aptai Unit- 4,5		10) Ashuganj S 11) Bosila 108			
INII INII					nulna ST 110		12) Sylhet 20 M			
					horasal Unit-4		13) Sylhet 150			
					aghabari 100 l		15) Sylliet 150			
					ongi GT					
					•	10				
					7) Chittagong Unit-1,2 8) Sikalbaha ST					
					aghabari-71 N	1\//				
				5) 6	agnabarrin					
	onal Information of Machine	es, lines, inte	rruption / Forced Load	snea etc						
	Description	1			Comments on Power Interruption					
a) Sikalbaha-Dohazari 132 kV Ckt-	2 was under shut do	wn from 1	0:44 to 10:54 to r	emove	a piece of c	onductor				
over the line.										
b) After maintenance Fenchuganj I	Power Station GT2 w	as synchr	onized at 11:45.							
c) Polashbari 132/33 kV T2 transfo	rmer was under shut	down from	m 12:10 to 13:45	to Abo	ut 18 MW po	ower interrupt	tion occurred u	nder Polashbar	i S/S	
Bus isolator.					area from 12:10 to 13:45.					
d) Meghnaghat Summit GT2 was synchronized at 09:47 and coupled to STG later.										
e) After maintenance Sylhet 150 MW GT was synchronized at 11:28.										
f) Barapukuria 132 kV main Bus and reserve bus were under shut down from 10:05 to 18:20 for development work.										
g) Ghorashal unit-3 wa forced shut down at 16:54 due to turbine vibration high.										
h) Bhulta 400/230 kV ICT2 transformer was charged from 230 kV side at 17:00.										
i) Barisal 132/33 kV T1& T2 transformers tripped at 19:39 from 33 kV side showing E/F, O/C due to 33 kV										
Palashpur feeder fault and was s	••	53 110111 53		μ <b>μ</b> , τ		JKV				
		00.22 from	both aida abawi	na Aho	ut 25 MM/ pc	wor intorrunt	tion occurred u	ndor Coopolno	ra 6/6	
j) Goalpara 132/33 kV T5 & T6 transformers tripped at 20:23 from both side showing About 3						•		nuel Guapalpa	14 3/3	
5					area from 20:23 to 20:45.					
k) Comilla(S) T1 & T2 transformers tripped at 22:12 from 33 kV side showing E/F du A										
					area from 22:12 to 22:36.					
I) G.K. Project 132/33 kV T1 transformer tripped at 04:51(15/03/2018) from 33 kV sid Ab					About 25 MW power interruption occurred under G.K. S/S area					
on at 05:06. from 04:51(15/03/2018) to 05:06.										
m) G.K. 132/33 kV T2 transformer	tripped at 04:51(15/0	3/2018) fi	om both side sho	owing L	./O at 33 kV	side due to				
33 kV Mirpur PBS feeder fault a	nd switched on at 05	5:06.								
n) Ashuganj CCPP 225 MW was s	hut down at 07:03(15	/03/2018)	for Air filter repla	acemer	nt.					
	,	,	•							
Sub Divisional Engineer			Executive Engineer					erintendent Engine		
Network Operation Division		Netwo	ork Operation Divisio	n			Lo	ad Dispatch Circle	9	
l				I						