## POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER

QF-LDC-08

DAILY REPORT Page -1 2-Apr-18 Reporting Date Till now the maximum generation is: 10084.0 Hrs 19-Mar-18 1-Apr-18 Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterday's 7359.1 MW 12:00 5910 MW Day Peak Generation Min. Gen. at 6:00 Evening Peak Generation 9147.0 MW 21:00 Available Max Generation 9955 MW E.P. Demand (at gen end) 9147.0 MW 21:00 Max Demand (Evening) 9950 MW Maximum Generation 9147.0 MW 21:00 Reserve(Generation end) 5 MW 171.6 78.15% Total Gen. (MKWH) 0 MW System Load Factor Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR MKWHR Export from East grid to West grid :- Maximum -880 MW 7:00 Energy Import from West grid to East grid :- Maximum MW Energy MKWHR Water Level of Kaptai Lake at 6:00 A M on 2-Apr-18 Actual 89.59 Ft.(MSL) Rule curve 88.34 Ft.( MSL ) Gas Consumed : Total = 932.62 MMCFD Oil Consumed (PDB) HSD Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Tk80,646,843 Gas Tk0 Tk448,064,960 Total: Tk528,711,804 **Load Shedding & Other Information** Yesterday Area Today Estimated Shedding (S/S end) Rates of Shedding Estimated Demand (S/S end) (On Estimated Demand) MW MW MW Dhaka 0:00 Chittagong Area 0 0:00 1179 0 0% 0% Khulna Area n 0.00 1055 Ω Rajshahi Area 0:00 953 0% 0 0 Comilla Area 0:00 862 0% Mymensingh Area 0 0:00 695 0 **0%** 0% Svlhet Area 0 0:00 393 Barisal Area 0:00 179 0 0% 536 Rangpur Area 0:00 0% Total 9330 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-1 10) Ashuganj ST: Unit- 2,3 2) Kaptai Unit- 5 11) Sylhet 20 MW Nil 3) Khulna ST 110 MW 12) Ashuganj (South)-ST (04/11/14) 4) Ghorasal Unit-3,5 13) Ashuganj (North)-ST 5) Baghabari 100 MW 14) Barapukuria ST: Unit-2 6) Tongi GT 7) Chittagong Unit-1,2 8) Sirajganj #2 9) Baghabari-71 MW Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Barapukuria Unit-3 was synchronized at 09:47 for test purpose. b) Mymensingh RPCL ST tripped at 09:43 due to voltage fluctuation and was synchronized at 11:23. c) Madanganj-Sitalakha 132 kV Ckt was under shut down from 10:18 to 13:08 for red hot maintenance at Madanganj end. d) Sirajganj Unit-1 was synchronized at 13:02. e) Ghorasal Unit-7 was synchronized at 13:33 for test purpose. f) Khulna 225 MW GT tripped at 13:34 due to controller communication fault. g) Siddhirganj 335 MW GT was synchronized at 13:38 for test purpose. h) Kaliakoir-Dhamrai 132 kV Ckt-1 was closed at 17:45.

- i) Summit Meghnaghat GT2 & ST were synchronized at 15:15 & 17:39 respectively.
- i) Bogra 132 kV bus-coupler closed at 20:52.

k) Amnura 132/33 kV T1 transformer tripped at 21:13 showing O/V and was switched on About 12 MW Power interruption occurred under Amnura S/S areas from 21:13 to 21:23.

Sub Divisional Engineer **Network Operation Division** 

**Executive Engineer Network Operation Division**  Superintendent Engineer Load Dispatch Circle