				GRID COMPANY OF BANGLAD IONAL LOAD DESPATCH CEI DAILY REPORT							QF-LDC-08 Page -1
									Reporting Date	: 14-Apr-18	
ill now the maximum			10084.0			1	9:30		19-Mar-18		
he Summary of Yester	erday's		Generation & Dem	land		40.00				Probable Gen. &	
Day Peak Generation	:	6363.3			Hour :	12:00		Min. Gen. at	7:00		0 MW
Evening Peak Generation		9257.0			Hour :	21:00		Available Max			5 MW
E.P. Demand (at gen end)):	9257.0			Hour :	21:00		Max Demand			0 MW
Maximum Generation	:	9257.0			Hour :	21:00		Reserve(Gene	ration end)		5 MW
otal Gen. (MKWH)	:	164.5		System	Load Factor	: 74.06%		Load Shed	:		0 MW
			EXPORT / IMPOR	T THROUGH EAST-WEST IN							
Export from East grid to W mport from West grid to E	East grid :- Maxim				-83	0 MW MW	at at	19:30 -	Energ Energ		MKWHR. - MKWHR.
ater Level of Kaptai Lake a Actual		Ft.(MSL),	14-Apr-18		Rule curve	: 86.2	0	Ft.(MSL)			
Gas Consumed :	Total =	942.12	MMCFD.			Oil Cons	sumed	I (PDB):			
									HSD : FO :		Liter Liter
Cost of the Consumed Fue		Gas :		Tk81,121,160							
		Coal :		Tk8,528,896		Oil	:	Tk425,563,440	6 Total	: Tk515,213,503	
	Lo	oad Sheddin	g & Other Informat	ion							
Area Yesterday								Today			
				Estimated Demand (S/S end)				Estimated She	edding (S/S en		
	MW			MW					MW	(On Estimated [Jemand)
Dhaka	0	0:00		3285					0	0%	
Chittagong Area	0	0:00		1112					0	0%	
Khulna Area	0	0:00		996					0	0%	
Rajshahi Area	0	0:00		899					0	0%	
Comilla Area	0	0:00		813					0	0%	
Nymensingh Area	0	0:00		656					0	0%	
Sylhet Area	0	0:00		373					0	0%	
Barisal Area	0	0:00		169					0	0%	
Rangpur Area	0	0:00		506					0	0%	
Total	0			8809					0		
	Informat	tion of the Ge	enerating Units unde	er shut down.							
	Planned Shut	t- Down				Forced					
	Nil					1) Barap 2) Sylhe		a ST: Unit-1 1W	10) Ashuga 11) Haripur	nj ST: Unit- 2,3 GT-1,2	
						3) Khuln	a ST	(04/11/14)	12) Sirajgor	nj Unit-1 225 MW	
						4) Ghora	asal L	nit-2,3,5	13) Ashuga	nj (South) 360 MW	/
						5) Bagh	abari	100 MW	14) Ashuga	nj (North) 360 MW	,
						6) Tongi	GT				
						7) Chitta		Unit-1,2			
						8) Bagh					
								210 MW ST			
								· · ·			
	Additional Inf	ormation of	Machines, lines, In	terruption / Forced Load shed	etc.						
	D	escription		-				Comme	nts on Power	Interruption	
	D	escription		terruption / Forced Load shed 09:56 and 09:57 to 10:50 respect				Comme	nts on Power	Interruption	
for development work.	V Ckt-1 & 2 were	escription under shut d	down from 08:22 to 0	09:56 and 09:57 to 10:50 respect				Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kV	V Ckt-1 & 2 were	escription under shut d	down from 08:22 to 0 m 08:40 to 112:34 fo	09:56 and 09:57 to 10:50 respect or corrective maintenance.	ively			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kV c) Shyampur S/S 132/33 kV	Do CV Ckt-1 & 2 were V ckt was under s CV T1 transformer	escription under shut d hut down fror was under sl	down from 08:22 to 0 m 08:40 to 112:34 fo hut down from 08:54	09:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena	ively ance.			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kV c) Shyampur S/S 132/33 k d) Siddhirganj-Haripur 132	Do CV Ckt-1 & 2 were V ckt was under s CV T1 transformer	escription under shut d hut down fror was under sl	down from 08:22 to 0 m 08:40 to 112:34 fo hut down from 08:54	09:56 and 09:57 to 10:50 respect or corrective maintenance.	ively ance.			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kW c) Shyampur S/S 132/33 k d) Siddhirganj-Haripur 132 conductor stringing.	V Ckt-1 & 2 were V Ckt was under s V T1 transformer V Ckt-2 was un	escription under shut d hut down fror was under sl der shut dow	down from 08:22 to 0 m 08:40 to 112:34 fc hut down from 08:54 rn from 07:39 to 20:2	09:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan	ively ance.			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kV c) Shyampur S/S 132/33 kV d) Siddhirganj-Haripur 132 conductor stringing. b) Khulshi-Halishahar 132	Dr V Ckt-1 & 2 were V ckt was under s V T1 transformer V Ckt-2 was un kV Ckt-1 tripped t	escription under shut d hut down fror was under sl der shut dow	down from 08:22 to 0 m 08:40 to 112:34 fc hut down from 08:54 rn from 07:39 to 20:2	09:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena	ively ance.			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kV c) Shyampur S/S 132/33 k' d) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-NZ1 at H	D. V Ckt-1 & 2 were V ckt was under s V T1 transformer V Ckt-2 was un kV Ckt-1 tripped 1 Halishahar end.	escription under shut d hut down fror was under sl der shut dow from 10:08 to	down from 08:22 to 0 m 08:40 to 112:34 fo hut down from 08:54 rn from 07:39 to 20:2 o 10:14 from both en	D9:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan nd showing Dist B phase E/F at K	ively ance.			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kV c) Shyampur S/S 132/33 kV j) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-N21 at H) Hasnabad S/S 132/33 kV	Dr CK Ckt-1 & 2 were V Ckt was under s V T1 transformer kV Ckt-2 was und kV Ckt-1 tripped i Halishahar end. V T2 was under s	escription under shut d hut down fror was under sl der shut dow from 10:08 to shut down fror	down from 08:22 to (m 08:40 to 112:34 f hut down from 08:54 r/n from 07:39 to 20:2 o 10:14 from both en m 09:25 to 11:28 du	29:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan nd showing Dist B phase E/F at K ne to CT oil leakage.	ively ance.			Commer	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kW 3 Shyampur S/S 132/33 k' d) Siddhirganj-Haripur 132 conductor stringing. 9 Khulshi-Halishahar 132 end and Dist C-NZ1 at H t) Hasnabad S/S 132/33 k' g) Sylhet 150 MW GT tripp	D V Ckt-1 & 2 were V ckt was under s V T1 transformer 2 kV Ckt-2 was und kV Ckt-1 tripped f Halishahar end. V T2 was under s ped at 17:44 due t	escription under shut d shut down fror was under sl der shut dow from 10:08 to shut down fror to TEPC sens	down from 08:22 to 0 m 08:40 to 112:34 fc hut down from 08:54 rn from 07:39 to 20:2 o 10:14 from both en m 09:25 to 11:28 du sor fault and synchro	29:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan ad showing Dist B phase E/F at K the to CT oil leakage. onized at 18:28.	ively ance. j (hulshi			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kk c) Shyampur S/S 132/38 k d) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-NZ1 at h) Hasnabad S/S 132/33 kk g) Sylhet 150 MW GT tripp n) Hathazari-Baraulia 132	V Ckt-1 & 2 were V ckt was under s V ckt was under s V T1 transformer V KV Ckt-2 was under s Halishahar end. V T2 was under s ved at 17:44 due t kV Ckt-1 tripped a	escription under shut d what down fror was under sl der shut dow from 10:08 to what down fror to TEPC sens at 17:40 from	down from 08:22 to 0 m 08:40 to 112:34 fr hut down from 08:5- in from 07:39 to 20:2 o 10:14 from both en m 09:25 to 11:28 du sor fault and synchrr Hathazari end due	D9:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan nd showing Dist B phase E/F at K ie to CT oil leakage. onized at 18:28. to wrong wiring and switched on	ively ance. j (hulshi			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kk c) Shyampur S/S 132/33 k' b) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-NZ1 at I t) Hasnabad S/S 132/33 kk g) Sylhet 150 MW GT tripp h) Hathazari-Baraulia 132 l) Ashuganj (k) ST was shi	Dr CK Ckt-1 & 2 were V Ckt was under s V T1 transformer kV Ckt-2 was und kV Ckt-1 tripped i Halishahar end. V T2 was under s ped at 17:44 due t kV Ckt-1 tripped a ut down at 22:57	escription under shut d thut down fror was under sl der shut dow from 10:08 to shut down fror to TEPC sens at 17:40 from due to proble	down from 08:22 to 0 m 08:40 to 112:34 ft hut down from 08:54 n from 07:39 to 20:2 o 10:14 from both en m 09:25 to 11:28 du sor fault and synchrr I Hathazari end due em with control valve	D9:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan nd showing Dist B phase E/F at K ie to CT oil leakage. onized at 18:28. to wrong wiring and switched on	ively ance. j (hulshi			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kW c) Shyampur S/S 132/33 k' d) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-NZ1 at H f) Hasnabad S/S 132/33 k' g) Sylhet 150 MW GT tripp h) Hathazari-Baraulia 132 i) Ashuganj (N) ST was shi Ashuganj (N) GT tripped	V Ckt-1 & 2 were V Ckt-1 & 2 were V ckt was under s V Ckt-1 missormer V Ckt-2 was under kV Ckt-1 tripped 1 Halishahar end. V T2 was under s ped at 17:44 due t kV Ckt-1 tripped 2 sut down at 22:57 1 at 23:00 by activ	escription under shut d whut down fror was under sl der shut dow from 10:08 to shut down fror to TEPC sens at 17:40 from due to proble rating HRSG p	down from 08:22 to 0 m 08:40 to 112:34 fc hut down from 08:54 rn from 07:39 to 20:2 o 10:14 from both en m 09:25 to 11:28 du sor fault and synchro Hathazari end due em with control valve protection.	D9:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan ad showing Dist B phase E/F at K he to CT oil leakage. onized at 18:28. to wrong wiring and switched on e of LP turbine.	ively ance. j (hulshi at 20:38.			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kk c) Shyampur S/S 132/38 k d) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-NZ1 at H) Hasnabad S/S 132/33 kk g) Sylhet 150 MW GT tripp h Hathazari-Baraulia 132 l) Ashuganj (N) ST was sh) Ashuganj (N) ST was sh) Ashuganj (N) GT tripped () Shahjibazar 330 MW CC	V Ckt-1 & 2 were V ckt was under s V ckt was under s V Ckt-1 tripped 1 Halishahar end. V T2 was under s ped at 17:44 due t kV Ckt-1 tripped a ut down at 22:57 d at 23:00 by activ. CPP GT-2 was un	escription under shut d whut down fror was under sl der shut dow from 10:08 to shut down fror to TEPC sens at 17:40 from due to proble rating HRSG p ader shut dow	down from 08:22 to 0 m 08:40 to 112:34 fr hut down from 08:5- in from 07:39 to 20:2 p 10:14 from both en m 09:25 to 11:28 du sor fault ad synchro Hathazari end due em with control valve protection. w from 22:81 to 01:	D9:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan ad showing Dist B phase E/F at K ie to CT oil leakage. onized at 18:28. to wrong wiring and switched on e of LP turbine. 15(14/04/2018) for running in cor	ively ance. j (hulshi at 20:38.			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kk c) Shyampur S/S 132/38 k/ b) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-NZ1 at H t) Hasnabad S/S 132/33 kk g) Sylhet 150 MW GT h Hathazari-Baraulia 132) Ashuganj (N) ST was shi) Ashuganj (V Ckt-1 & 2 were V ckt was under s V T1 transformer V Ctt-2 was und kV Ckt-1 tripped 1 Halishahar end. V T2 was under s ped at 17:44 due t KV Ckt-1 tripped a tit	escription under shut d whut down fror was under sli der shut dow from 10:08 to thut down fror to TEPC sens at 17:40 from due to proble rating HRSG p nder shut dow it down at 06:	down from 08:22 to 0 m 08:40 to 112:34 ft hut down from 08:54 n from 07:39 to 20:2 o 10:14 from both en m 09:25 to 11:28 du sor fault and synchrr H Athazari end due em with control valve protection. vn from 22:81 to 01: :36(14/04/2018) due	D9:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan nd showing Dist B phase E/F at K ue to CT oil leakage. onized at 18:28. to wrong wiring and switched on e of LP turbine. 15(14/04/2018) for running in cor a to development work.	ively ance. j (hulshi at 20:38. mbined cycle.			Comme	<u>nts on Power</u> ⊺	Interruption	
for development work. b) Hathazari-BSRM 230 kk c) Shyampur S/S 132/38 k/ b) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-NZ1 at H t) Hasnabad S/S 132/33 kk g) Sylhet 150 MW GT h Hathazari-Baraulia 132) Ashuganj (N) ST was shi) Ashuganj (V Ckt-1 & 2 were V ckt was under s V T1 transformer V Ctt-2 was und kV Ckt-1 tripped 1 Halishahar end. V T2 was under s ped at 17:44 due t KV Ckt-1 tripped a tit	escription under shut d whut down fror was under sli der shut dow from 10:08 to thut down fror to TEPC sens at 17:40 from due to proble rating HRSG p nder shut dow it down at 06:	down from 08:22 to 0 m 08:40 to 112:34 ft hut down from 08:54 n from 07:39 to 20:2 o 10:14 from both en m 09:25 to 11:28 du sor fault and synchrr H Athazari end due em with control valve protection. vn from 22:81 to 01: :36(14/04/2018) due	D9:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan ad showing Dist B phase E/F at K ie to CT oil leakage. onized at 18:28. to wrong wiring and switched on e of LP turbine. 15(14/04/2018) for running in cor	ively ance. j (hulshi at 20:38. mbined cycle.			Comme	nts on Power	Interruption	
for development work. b) Hathazari-BSRM 230 kW c) Shyampur S/S 132/33 k' d) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-NZ1 at H f) Hasnabad S/S 132/33 kV g) Sylhet 150 MW GT tripp h) Hathazari-Baraulia 132 l) Ashuganj (N) ST was shi) Ashuganj (N) ST was shi) Ashuganj (N) ST was shi) Ashuganj (N) GT tripped k) Shahjibazar 330 MW CC	V Ckt-1 & 2 were V ckt was under s V T1 transformer V Ctt-2 was und kV Ckt-1 tripped 1 Halishahar end. V T2 was under s ped at 17:44 due t KV Ckt-1 tripped a tit	escription under shut d whut down fror was under sli der shut dow from 10:08 to thut down fror to TEPC sens at 17:40 from due to proble rating HRSG p nder shut dow it down at 06:	down from 08:22 to 0 m 08:40 to 112:34 ft hut down from 08:54 n from 07:39 to 20:2 o 10:14 from both en m 09:25 to 11:28 du sor fault and synchrr H Athazari end due em with control valve protection. vn from 22:81 to 01: :36(14/04/2018) due	D9:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan nd showing Dist B phase E/F at K ue to CT oil leakage. onized at 18:28. to wrong wiring and switched on e of LP turbine. 15(14/04/2018) for running in cor a to development work.	ively ance. j (hulshi at 20:38. mbined cycle.			Comme	nts on Power⊺	Interruption	
for development work. b) Hathazari-BSRM 230 kV c) Shyampur S/S 132/33 k' d) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-NZ1 at H f) Hasnabad S/S 132/33 k' g) Sylhet 150 MW GT tripped h) Hathazari-Baraulia 132 l i) Ashuganj (N) ST was shi) Ashuganj (N) ST was shi) Ashuganj (N) GT tripped k) Shahijibazar 330 MW CC i) Haripur-Siddhirganj 132 l i) Siddhirganj-Desh energy	V Ckt-1 & 2 were V ckt was under s V T1 transformer V Ckt-2 was un kV Ckt-1 tripped 1 Halishahar end. V T2 was under s ped at 17:44 due t kV Ckt-1 tripped a nut down at 22:57 at 23:00 by activ CPP GT-2 was un kV Ckt-2 was shu y power plant 132	escription under shut d whut down fror was under sli der shut dow from 10:08 to thut down fror to TEPC sens at 17:40 from due to proble rating HRSG p nder shut dow it down at 06:	down from 08:22 to 0 m 08:40 to 112:34 ft hut down from 08:54 n from 07:39 to 20:2 o 10:14 from both en m 09:25 to 11:28 du sor fault and synchrr H Athazari end due em with control valve protection. vn from 22:81 to 01: :36(14/04/2018) due	29:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan ad showing Dist B phase E/F at K the to CT oil leakage. onized at 18:28. to wrong wiring and switched on e of LP turbine. 15(14/04/2018) for running in core to development work. 14/04/2018) due to development	ively ance. j (hulshi at 20:38. mbined cycle.			Comme	<u>nts on Power</u> ⊺	Interruption	
for development work. b) Hathazari-BSRM 230 kW c) Shyampur S/S 132/33 k' d) Siddhirganj-Haripur 132 conductor stringing. e) Khulshi-Halishahar 132 end and Dist C-NZ1 at H f) Hasnabad S/S 132/33 kV g) Sylhet 150 MW GT tripp h) Hathazari-Baraulia 132 l) Ashuganj (N) ST was shi) Ashuganj (N) ST was shi) Ashuganj (N) ST was shi) Ashuganj (N) GT tripped k) Shahjibazar 330 MW CC	V Ckt-1 & 2 were V ckt was under s V Ckt-1 & 2 ware V Ckt-1 kinsformer V Ckt-2 was under kV Ckt-1 tripped 1 Halishahar end. V T2 was under s ped at 17:44 due t kV Ckt-1 tripped 2 sod at 17:44 due t kV Ckt-1 tripped 2 at 23:00 by activ CPP GT-2 was un kV Ckt-2 was shu y power plant 132 neer	escription under shut d whut down fror was under sli der shut dow from 10:08 to thut down fror to TEPC sens at 17:40 from due to proble rating HRSG p nder shut dow it down at 06:	down from 08:22 to 0 m 08:40 to 112:34 ft hut down from 08:54 n from 07:39 to 20:2 o 10:14 from both en m 09:25 to 11:28 du sor fault and synchrr H Athazari end due em with control valve protection. vn from 22:81 to 01: :36(14/04/2018) due	D9:56 and 09:57 to 10:50 respect or corrective maintenance. 4 to 14:16 for corrective maintena 20 for 230 kV Haripur-Siddhirgan nd showing Dist B phase E/F at K ue to CT oil leakage. onized at 18:28. to wrong wiring and switched on e of LP turbine. 15(14/04/2018) for running in cor a to development work.	ively ance. j (hulshi at 20:38. mbined cycle.			Commen		Interruption Superintendent E Load Dispatch (