		ID COMPANY OF BANG NAL LOAD DESPATCH					QF-LDC-08
		DAILY REPORT			5 " 5 "	45.4 40	Page -1
Fill now the maximum generation is : -		10137.0	21	:00 Hrs on	Reporting Date : 24-Apr-18	15-May-18	
The Summary of Yesterday's	14-May-18	Generation & Demand		Today's Actual Min Ge	n. & Probable Gen. & Demand		
Day Peak Generation :	7619.0		12:00	Min. Gen. at	6:00	6748 MW	
Evening Peak Generation : E.P. Demand (at gen end) :	9464.0 9464.0		21:00 21:00	Available Max Generatio Max Demand (Evening)		11445 MW 10000 MW	
Maximum Generation :	9522.0		22:00	Reserve(Generation end		1445 MW	
Fotal Gen. (MKWH) :	185.7	ystem Load Factor	: 81.27%	Load Shed		0 MW	
	EXPORT / IMPORT	THROUGH EAST-WEST					
export from East grid to West grid :- Maximum		-560	0 MW at	20:00	Energy	MKWHR.	
mport from West grid to East grid :- Maximum Water Level of Kaptai Lake at 6:00 A M on		- 15-May-18	MW at	-	Energy	- MKWHR.	
Actual : 82.21	Ft.(MSL),	Rule curve	: 79.34	Ft.(MSL)			
				(/			
Gas Consumed : Total =	950.34	MMCFD.	Oil Consumed (PDB)	:			
					HSD :	Liter	
					FO :	Liter	
Cost of the Consumed Fuel (PDB+Pvt) :	Gas :	Tk78,914,756					
	Coal :	Tk1,523,018	Oil	: Tk440,795,200	Total : Tk52	1,232,974	
	Load Shedding & Other	<u>Information</u>					
Area Yesterday				Today			
•		Estimated Demand (S/S e	end)	Estimated Shedding (S/S		es of Shedding	
MW		MW			MW (On	Estimated Demand)	
Ohaka 0	0:00	3503			0	0%	
Chittagong Area 0 Khulna Area 0	0:00 0:00	1188 1064			0 0	0% 0%	
Rajshahi Area 0	0:00	961			0	0%	
Comilla Area 0	0:00	869			0	0%	
Mymensingh Area 0	0:00	701			0	0%	
Sylhet Area 0	0:00	396			0	0%	
Barisal Area 0 Rangpur Area 0	0:00 0:00	181 541			0 0	0% 0%	
Total 0	0.00	9404			0	078	
Information of the G	enerating Units under shut	down.					
Planned Shut- Down			Forced Shut-Down				
rialiled Stidt- Down			Barapukuria ST: Un	it-1	10) Ashuganj ST: Unit- 2,4		
Nil			2) Sylhet 20 MW		11) Haripur GT-1,2		
			3) Khulna ST 110 MW	(04/11/14)	12) Sirajgonj Unit-1 225 MW		
			4) Ghorasal Unit-2,4		13) Ashuganj 225 MW		
			 Baghabari 100 MW Tongi GT 		14) khulna-225 MW ST 15) Kushiyara 163 MW		
			7) Chittagong Unit-1,2		10) ((a) 11)		
			8) Baghabari-71 MW				
			0) 0:445:: 040 848	/ ST			
			9) Siddhirganj 210 MV				
			9) Siddnirganj 210 MV				
Additional Information o	f Machines, lines, Interru	uption / Forced Load she					
		uption / Forced Load she	ed etc.				
	Description		ed etc.	mments on Power Interrup	tion		
a) Sikalbaha-Julda 132 kV Ckt was under shut down	Description from 08:54 to 17:04 for E	I/W at Sikalbaha end.	ed etc.		tion		
a) Sikalbaha-Julda 132 kV Ckt was under shut down) Fenchuganj 230 kV diameter-3 was under shut do	Description from 08:54 to 17:04 for E own from 10:02 to 21:32 fo	n/W at Sikalbaha end.	ed etc.		tion		
a) Sikalibaha-Julda 132 kV Ckt was under shut down 5) Fenchuganj 230 kV diameter-3 was under shut do 5) Bhola 225 MW CCPP was shut down at 12:41 for & 01:53(15)05/2018) respectively.	Description from 08:54 to 17:04 for E own from 10:02 to 21:32 for EDG-2 maintenance and	n/W at Sikalbaha end. or D/W. GT-1 & GT-2 were syncl	column co	mments on Power Interrup			
a) Sikalbaha-Julda 132 kV Ckt was under shut down 5) Fenchuganj 230 kV diameter-3 was under shut do 5) Bhola 225 MW CCPP was shut down at 12:41 for & 01:53(15)05/2018) respectively.	Description from 08:54 to 17:04 for E own from 10:02 to 21:32 for EDG-2 maintenance and	n/W at Sikalbaha end. or D/W. GT-1 & GT-2 were syncl	ed etc. Controlized at 15:35 About 14 MW Power i				
a) Sikalbaha-Julda 132 kV Ckt was under shut down o) Fenchuganj 230 kV diameter-3 was under shut do o) Bhola 228 hW CCPP was shut down at 12:41 for & 01:53(15/05/2018) respectively. d) Cox'sbazar 132/33 kV T3 transformer was under :	Description If from 08:54 to 17:04 for E own from 10:02 to 21:32 for EDG-2 maintenance and	D/W at Sikalbaha end. or D/W. GT-1 & GT-2 were synct 2:35 for cable change.	column co	mments on Power Interrup			
a) Sikalbaha-Julda 132 kV Ckt was under shut down b) Fenchuganj 230 kV diameter-3 was under shut do D Bhola 225 MW CCPP was shut down at 12:41 for & 01:53(15/05/2018) respectively. d) Cox'sbazar 132/33 kV T3 transformer was under :	Description I from 08:54 to 17:04 for E won from 10:02 to 21:32 for EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30	D/W at Sikalbaha end. or D/W. GT-1 & GT-2 were synct 2:35 for cable change.	control at 15:35 About 14 MW Power in from 10:02 to 12:35.	mments on Power Interrup	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down o) Fenchuganj 230 kV diameter-3 was under shut do j Bhola 226 kW CCPP was shut down at 12:41 for & 01:53(15/05/2018) respectively. d) Cox'sbazar 132/33 kV T3 transformer was under: e) After maintenance Ashuganj 450 MW CCPP ST v j Chapainawabganj 132/33 kV T3 transformer was under:	Description from 08:54 to 17:04 for E wwn from 10:02 to 21:32 fc EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15:	oW at Sikalbaha end. or D/W. GT-1 & GT-2 were syncl 2:35 for cable change. I, 18 to 16:45 due to 33 kV I	control at 15:35 About 14 MW Power in from 10:02 to 12:35.	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down) Fienchuganj 230 kV diameter-3 was under shut do) Bhola 225 MW CCPP was shut down at 12:41 for & 01:53(15/05/2018) respectively. d) Cox/sbazar 132/33 kV T3 transformer was under: a) After maintenance Ashuganj 450 MW CCPP ST v) Chapainawabganj 132/33 kV T3 transformer was g) After maintenance Fenchuganj-Kushiara 230 kV C	Description I from 08:54 to 17:04 for E wwn from 10:02 to 21:32 fo EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. It to 16:45 due to 33 kV I	hronized at 15:35 About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i S/S areas from 15:18	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down o) Fenchuganj 230 kV diameter-3 was under shut do 5) Fenchuganj 230 kV diameter-3 was under shut do 5) Bhola 225 MW CCPP was shut down at 12:41 for 8 01:53(15/05/2018) respectively. d) Coxsbazar 132/33 kV T 3 transformer was under se e) After maintenance Ashuganj 450 MW CCPP ST v 1) Chapainawabganj 132/33 kV T 3 transformer was u 3) After maintenance Fenchuganj-Kushiara 230 kV C 1) Sikalbaha 225 MW CCPP tripped at 20:15 due to	Description I from 08:54 to 17:04 for E wwn from 10:02 to 21:32 fo EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. It to 16:45 due to 33 kV I	hronized at 15:35 About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i S/S areas from 15:18	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down b) Fenchuganj 230 kV diameter-3 was under shut do b) Fenchuganj 230 kV diameter-3 was under shut do Bhola 225 MW CCPP was shut down at 12:41 for 8 01:53(15/05/2018) respectively. d) Cox'sbazar 132/33 kV T3 transformer was under : e) After maintenance Ashuganj 450 MW CCPP ST v Chapainawabganj 132/33 kV T3 transformer was under : g) After maintenance Fenchuganj-Kushiara 230 kV (3) d) After maintenance Fenchuganj-Kushiara 230 kV (3) Sikalbaha 225 MW CCPP tripped at 20:15 due to 8 01:13 (15/05/2018) respectively.	Description Ifrom 08:54 to 17:04 for E work from 10:02 to 21:32 fc EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21 problem with strainer and	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. It to 16:45 due to 33 kV I	hronized at 15:35 About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i S/S areas from 15:18	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down s) Fenchuganj 230 kV diameter-3 was under shut do 5) Bhola 225 MW CCPP was shut down at 12:41 for 8 01:53(15/05/2018) respectively. c) Cox'sbazar 132/33 kV T3 transformer was under: s) After maintenance Ashuganj 450 MW CCPP ST c) Chapainawabganj 132/33 kV T3 transformer was: d) After maintenance Fenchuganj-Kushiara 230 kV c) Sikalbaha 225 MW CCPP tripped at 20:15 due to 8 01:13 (15/05/2018) respectively. Siddhirganj 132/33 kV T2 transformer was switche	Description from 08:54 to 17:04 for E wwn from 10:02 to 21:32 fc EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:36 under shut down from 15: Ckt was switched on at 21 problem with strainer and d on at 18:08.	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. It to 16:45 due to 33 kV to 32. GT & ST were synchronic	hronized at 15:35 About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i S/S areas from 15:18	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
i) Sikalbaha-Julda 132 kV Ckt was under shut down i) Fenchuganj 230 kV diameter-3 was under shut do i) Fenchuganj 230 kV diameter-3 was under shut do i Bhola 225 MW CCPP was shut down at 12:41 for & 01:53(15/05/2018) respectively. 1) Cox'sbazar 132/33 kV T3 transformer was under :) After maintenance Ashuganj 450 MW CCPP ST v Chapainawabganj 132/33 kV T3 transformer was : 1) After maintenance Fenchuganj-Kushiara 230 kV C i) Sikalbaha 225 MW CCPP tripped at 20:15 due to & 01:13 (15/05/2018) respectively. Siddhirganj 132/33 kV T2 transformer was switche After maintenance AES Meghnaghat 450 MW CMP in Madunaghat 132/33 T1 transformer was under si	Description from 08:54 to 17:04 for E won from 10:02 to 21:32 fo EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21 problem with strainer and d on at 18:08. PP GT-2 was synchronize	oW at Sikalbaha end. or D/W. GT-1 & GT-2 were syncl 2:35 for cable change. 1. 18 to 16:45 due to 33 kV l 3:32. GT & ST were synchroni. d at 23:24.	About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i S/S areas from 15:18 zed at 22:55	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down o) Fenchuganj 230 kV diameter-3 was under shut do 5) Bhola 225 MW CCPP was shut down at 12-41 for 8 01:53(15/05/2018) respectively. d) Cox'sbazar 132/33 kV T3 transformer was under e) After maintenance Ashuganj 450 MW CCPP ST v) Chapainawabganj 132/33 kV T3 transformer was uganj After maintenance Fenchuganj-Kushiara 230 kV C h) Sikalbaha 225 MW CCPP tripped at 20:15 due to 8 01:13 (15/05/2018) respectively.) Siddhirganj 132/33 kV T2 transformer was switche) After maintenance AES Meghnaghat 450 MW CC () Madunaghat 132/33 T1 transformer was under st at 33 kV B-phase bus isolator.	Description from 08:54 to 17:04 for E from 10:02 to 21:32 fc EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21 problem with strainer and d on at 18:08. PP GT-2 was synchronize ut down from 23:14 to 01	oW at Sikalbaha end. or D/W. GT-1 & GT-2 were syncl 2:35 for cable change. 1. 18 to 16:45 due to 33 kV l 3:32. GT & ST were synchroni. d at 23:24.	About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i S/S areas from 15:18 zed at 22:55	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down o) Flenchuganj 230 kV diameter-3 was under shut down o) Ehola 225 MW CCPP was shut down at 12:41 for & 01:53(15/05/2018) respectively. 2) After maintenance Ashuganj 450 MW CCPP ST v) Chapainawabganj 132/33 kV T3 transformer was under standard shut and the shut and t	Description I from 08:54 to 17:04 for E word from 10:02 to 21:32 fo EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:33 under shut down from 15: Ckt was switched on at 21 problem with strainer and id on at 18:08. PP GT-2 was synchronize ut down from 23:14 to 01 018) due to gas shortage.	D/W at Sikalbaha end. or D/W. GT-1 & GT-2 were syncl 2:35 for cable change. 1. 18 to 16:45 due to 33 kV l 32. GT & ST were synchroni. d at 23:24.	About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i S/S areas from 15:18 zed at 22:55	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down o) Fenchuganj 230 kV diameter-3 was under shut do Di Bhola 225 MW CCPP was shut down at 12:41 for 8 01:53(15/05/2018) respectively. a) Cox'sbazar 132/33 kV T3 transformer was under: e) After maintenance Ashuganj 450 MW CCPP ST v.) Chapainawabganj 132/33 kV T3 transformer was: 1) After maintenance Fenchuganj-Kushiara 230 kV Ci) Sikalbaha 225 MW CCPP tripped at 20:15 due to 8 01:13 (15/05/2018) respectively. Siddhirganj 132/33 kV T2 transformer was switche) After maintenance AES Meghnaghat 450 MW CCP (Maduanghat 132/33 kV Tarnsformer was under st at 33 kV B-phase bus isolator. Siddhirganj CT-1 was shut down at 00:05 (15/05/2018) Aminbazar-Kallyarpur 132 kV Ckt-2 was shut down AES was the down at 00:05 (15/05/2018) Aminbazar-Kallyarpur 132 kV Ckt-2 was shut down AES was the down at 00:05 (15/05/2018) Aminbazar-Kallyarpur 132 kV Ckt-2 was shut down AES was the down at 00:05 (15/05/2018) Aminbazar-Kallyarpur 132 kV Ckt-2 was shut down AES was the down at 00:05 (15/05/2018) Aminbazar-Kallyarpur 132 kV Ckt-2 was shut down AES was the down at 00:05 (15/05/2018) Aminbazar-Kallyarpur 132 kV Ckt-2 was shut down at 00:05 (15/05/2018)	Description I from 08:54 to 17:04 for E wown from 10:02 to 21:32 fe EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:36 under shut down from 15: Ckt was switched on at 21 problem with strainer and d on at 18:08. PP GT-2 was synchronize ut down from 23:14 to 01 018) due to gas shortage. wn at 07:46 (15/05/2018)	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. 18 to 16:45 due to 33 kV t 32. GT & ST were synchronic d at 23:24. :07(15/05/2018) due to re for C/M.	About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i S/S areas from 15:18 zed at 22:55	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down b) Fenchuganj 230 kV diameter-3 was under shut do c) Bhola 225 MW CCPP was shut down at 12:41 for 8 01:53(15/05/2018) respectively. d) Cox'sbazar 132/33 kV T3 transformer was under s: a) After maintenance Ashuganj 450 MW CCPP ST v C) Chapainawabganj 132/33 kV T3 transformer was under s: d) After maintenance Fenchuganj-Kushiara 230 kV C C) Sikalbaha 225 MW CCPP tripped at 20:15 due to 8 01:13 (15/05/2018) respectively. Siddhirganj 132/33 kV T2 transformer was switche After maintenance AES Meghnaghat 450 MW CC c) Madunaghat 132/33 T1 transformer was under si at 33 kV B-phase bus isolator. Siddhirganj GT-1 was shut down at 00:05 (15/05/2 n) Aminbazar-Kallyanpur 132 kV Ckt-2 was shut do Systhet 150 MW was shut down at 05:37 (15/05/20)	Description Ifrom 08:54 to 17:04 for E wwn from 10:02 to 21:32 fe EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:36 under shut down from 15: Ckt was switched on at 21 problem with strainer and of on at 18:08. PP GT-2 was synchronize tu down from 23:14 to 01 018) due to gas shortage. wn at 07:46 (18/05/2018) 18) for air filter replacement	D/W at Sikalbaha end. or D/W. CT-1 & GT-2 were synct 2:35 for cable change. 1. 18 to 16:45 due to 33 kV l 32. GT & ST were synchroni. d at 23:24. :07(15/05/2018) due to re for C/M. ent.	About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i S/S areas from 15:18 zed at 22:55	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down o) Fenchuganj 230 kV diameter-3 was under shut do Sphola 225 MW CCPP was shut down at 12:41 for 8 01:53(15/05/2018) respectively. d) Cox'sbazar 132/33 kV T3 transformer was under: e) After maintenance Ashuganj 450 MW CCPP ST v) Chapainawabganj 132/33 kV T3 transformer was: g) After maintenance Fenchuganj-Kushiara 230 kV Ch) Sikalbaha 225 MW CCPP tripped at 20:15 due to 8 01:13 (15/05/2018) respectively. 9) Siddhirganj 132/33 kV T2 transformer was switche 1) After maintenance AES Meghnaghat 450 MW CC (1) Madunaghat 132/33 T1 transformer was under st at 33 kV B-phase bus isolator. 9) Siddhirganj GT-1 was shut down at 00:05 (15/05/2018) My Aminbazar-Kallyappur 132 kV Ckt-2 was shut don 1) Sylhet 150 MW was shut down at 05:37 (15/05/20 5) Siddhirganj-Haripur 132 kV Ckt-2 was under shu	Description from 08:54 to 17:04 for E was from 10:02 to 21:32 fo EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21 problem with strainer and d on at 18:08. PP GT-2 was synchronize ut down from 23:14 to 01 018) due to gas shortage, wn at 07:46 (15/05/2018) 1018) for air filter replacemedown at 06:308/15/05/2014 s shut down at 06:314(15/05/2018)	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. 18 to 16:45 due to 33 kV t 3:32. GT & ST were synchroni: d at 23:2407(15/05/2018) due to re for C/M. ent. 3) for D/W. 5/2018) for D/W.	About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i S/S areas from 15:18 zed at 22:55	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down of Fenchugari 230 kV diarmeter-3 was under shut do Fenchugari 230 kV diarmeter-3 was under shut do Fenchugari 230 kW CCPP was shut down at 12:41 for & 01:53(15/05/2018) respectively. 3 (Cox'sbazar 132/33 kV T3 transformer was under start down at 12:43 for Chapainawabganj 132/33 kV T3 transformer was under start down at 12:45 kW CCPP tripped at 20:15 due to & 01:13 (15/05/2018) respectively. 3 (Alter maintenance Fenchuganj-Kushiara 230 kV CPP tripped at 20:15 due to & 01:13 (15/05/2018) respectively. 3 (Sidhirganj 132/33 kV T2 transformer was switche After maintenance AES Meghinaghiat 450 MW CPP (Madunaghat 132/33 T1 transformer was under start 33 kV B-phase bus isolator. 3 (Sidhirganj GT-1 was shut down at 00:05 (15/05/20) Aminbazar-Kallyanpur 132 kV Ckt-2 was shut down 3 (15/15/05/20) Siddhirganj-Haripur 132 kV Ckt-2 was under shut o) Siddhirganj-Haripur 132 kV Ckt-2 was under shut o) Siddhirganj 132/33 kV T2 transformer was shut do	Description I from 08:54 to 17:04 for E work from 10:02 to 21:32 fc EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21 problem with strainer and d on at 18:08. PP GT-2 was synchronize tut down from 23:14 to 01 018) due to gas shortage, wn at 07:46 (15/05/2018) 118) for air filter replaceme down at 06:08(15/05/2018) s shut down at 06:08(15/05/2018) s shut down at 06:03(15/05/2018) s shut down at 06:03(15/05/2018)	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. 18 to 16:45 due to 33 kV k 32. GT & ST were synchroni d at 23:2407(15/05/2018) due to re for C/M. ent. 3) for D/W. 5/2018) for D/W. for tan(delta) test.	About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i S/S areas from 15:18 zed at 22:55	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down b) Ficarbidupari 230 kV diameter-3 was under shut do p) Bhola 225 MW CCPP was shut down at 12:41 for & 0.153(15:05:2018) respectively. 8 01:53(15:05:2018) respectively. 9 After maintenance Ashugani 450 MW CCPP ST v Chapainawabgani 132/33 kV T3 transformer was under separate was under	Description I from 08:54 to 17:04 for E work from 10:02 to 21:32 fc EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21 problem with strainer and d on at 18:08. PP GT-2 was synchronize tut down from 23:14 to 01 018) due to gas shortage, wn at 07:46 (15/05/2018) 118) for air filter replaceme down at 06:08(15/05/2018) s shut down at 06:08(15/05/2018) s shut down at 06:03(15/05/2018) s shut down at 06:03(15/05/2018)	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. 18 to 16:45 due to 33 kV k 32. GT & ST were synchroni d at 23:2407(15/05/2018) due to re for C/M. ent. 3) for D/W. 5/2018) for D/W. for tan(delta) test.	About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i S/S areas from 15:18 zed at 22:55	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down o) Fenchuganj 230 kV diameter-3 was under shut do 5) Bhola 225 MW CCPP was shut down at 12:41 for 8 01:53(15/05/2018) respectively. d) Cox'sbazar 132/33 kV T3 transformer was under: e) After maintenance Ashuganj 450 MW CCPP ST v) Chapainawabganj 132/33 kV T3 transformer was: g) After maintenance Fenchuganj-Kushiara 230 kV C i) Sikalbaha 225 MW CCPP tripped at 20:15 due to 8 01:13 (15/05/2018) respectively.) Siddhirganj 132/33 kV T2 transformer was switche i) After maintenance AES Meghnaghat 450 MW CC i) Madunaghat 132/33 kV T2 transformer was under si 43 3 kV B-phase bus isolator.) Siddhirganj GT-1 was shut down at 00:05 (15/05/2018) m) Aminbazar-Kallyarpur 132 kV Ckt-2 was shut don) Sylhet 150 MW was shut down at 05:37 (15/05/20 i) Siddhirganj-Haripur 132 kV Ckt-2 was under shu	Description I from 08:54 to 17:04 for E work from 10:02 to 21:32 fc EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21 problem with strainer and d on at 18:08. PP GT-2 was synchronize tut down from 23:14 to 01 018) due to gas shortage, wn at 07:46 (15/05/2018) 118) for air filter replaceme down at 06:08(15/05/2018) s shut down at 06:08(15/05/2018) s shut down at 06:03(15/05/2018) s shut down at 06:03(15/05/2018)	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. 18 to 16:45 due to 33 kV k 32. GT & ST were synchroni d at 23:2407(15/05/2018) due to re for C/M. ent. 3) for D/W. 5/2018) for D/W. for tan(delta) test.	About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i S/S areas from 15:18 zed at 22:55	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down b) Ficarbidupari 230 kV diameter-3 was under shut do p) Bhola 225 MW CCPP was shut down at 12:41 for & 0.153(15:05:2018) respectively. 8 01:53(15:05:2018) respectively. 9 After maintenance Ashugani 450 MW CCPP ST v Chapainawabgani 132/33 kV T3 transformer was under separate was under	Description I from 08:54 to 17:04 for E work from 10:02 to 21:32 fc EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21 problem with strainer and d on at 18:08. PP GT-2 was synchronize tut down from 23:14 to 01 018) due to gas shortage, wn at 07:46 (15/05/2018) 118) for air filter replaceme down at 06:08(15/05/2018) s shut down at 06:08(15/05/2018) s shut down at 06:03(15/05/2018) s shut down at 06:03(15/05/2018)	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. 18 to 16:45 due to 33 kV k 32. GT & ST were synchroni d at 23:2407(15/05/2018) due to re for C/M. ent. 3) for D/W. 5/2018) for D/W. for tan(delta) test.	About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i from 10:02 to 12:35. b About 14 MW Power i S/S areas from 15:18 zed at 22:55	mments on Power Interrup interruption occurred Cox's B interruption occurred under C	azar S/S areas		
a) Sikalbaha-Julda 132 kV Ckt was under shut down of Fenchugari 230 kV diarmeter-3 was under shut do Fenchugari 230 kV diarmeter-3 was under shut do Fenchugari 230 kW CCPP was shut down at 12:41 for & 01:53(15/05/2018) respectively. 3 (Cox'sbazar 132/33 kV T3 transformer was under start down at 12:43 for Chapainawabganj 132/33 kV T3 transformer was under start down at 12:45 kW CCPP tripped at 20:15 due to & 01:13 (15/05/2018) respectively. 3 (Alter maintenance Fenchuganj-Kushiara 230 kV CPP tripped at 20:15 due to & 01:13 (15/05/2018) respectively. 3 (Sidhirganj 132/33 kV T2 transformer was switche After maintenance AES Meghinaghiat 450 MW CPP (Madunaghat 132/33 T1 transformer was under start 33 kV B-phase bus isolator. 3 (Sidhirganj GT-1 was shut down at 00:05 (15/05/20) Aminbazar-Kallyanpur 132 kV Ckt-2 was shut down 3 (15/15/05/20) Siddhirganj-Haripur 132 kV Ckt-2 was under shut o) Siddhirganj-Haripur 132 kV Ckt-2 was under shut o) Siddhirganj 132/33 kV T2 transformer was shut do	Description I from 08:54 to 17:04 for E work from 10:02 to 21:32 fc EDG-2 maintenance and shut down from 10:02 to 1 was synchronized at 16:30 under shut down from 15: Ckt was switched on at 21 problem with strainer and d on at 18:08. PP GT-2 was synchronize tut down from 23:14 to 01 018) due to gas shortage, wn at 07:46 (15/05/2018) 118) for air filter replaceme down at 06:08(15/05/2018) s shut down at 06:08(15/05/2018) s shut down at 06:03(15/05/2018) s shut down at 06:03(15/05/2018)	DW at Sikalbaha end. or DW. GT-1 & GT-2 were syncl 2:35 for cable change. 18 to 16:45 due to 33 kV k 32. GT & ST were synchroni d at 23:2407(15/05/2018) due to re for C/M. ent. 3) for D/W. 5/2018) for D/W. for tan(delta) test.	About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i from 10:02 to 12:35. About 14 MW Power i S/S areas from 15:18 zed at 22:55 d hot	mments on Power Interrup interruption occurred Cox's B interruption occurred under Co to 16:45.	azar S/S areas		