

POWER GRID COMPANY OF BANGLADESH LTD.										QF-LDC-08	
NATIONAL LOAD DESPATCH CENTER										Page -1	
DAILY REPORT										Reporting Date : 4-Jun-18	
Till now the maximum generation is :-										10958.0	
The Summary of Yesterday's										21:00 Hrs on 28-May-18	
3-Jun-18										Generation & Demand	
Today's Actual Min Gen. & Probable Gen. & Demand											
Day Peak Generation :										8703.2 MW	
Evening Peak Generation :										10602.0 MW	
E.P. Demand (at gen end) :										10602.0 MW	
Maximum Generation :										10602.0 MW	
Total Gen. (MKWH) :										220.7	
System Load Factor :										86.75%	
EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR											
Export from East grid to West grid :- Maximum										-840 MW at 20:00	
Import from West grid to East grid :- Maximum										- MW at -	
Water Level of Kaptai Lake at 6:00 A M on										4-Jun-18	
Actual : 79.70										Ft.(MSL) , Rule curve : 76.26 Ft.( MSL )	
Gas Consumed : Total = 1065.63 MMCFD.										Oil Consumed (PDB) :	
										HSD : Liter	
										FO : Liter	
Cost of the Consumed Fuel (PDB+Pvt) :										Gas : Tk100,109,055	
										Coal : Tk11,026,653	
										Oil : Tk623,022,233	
										Total : Tk734,157,940	
Load Shedding & Other Information											
Area										Yesterday	
										Today	
										Estimated Demand (S/S end)	
										Estimated Shedding (S/S end)	
										Rates of Shedding	
										(On Estimated Demand)	
Dhaka										0	
Chittagong Area										0	
Khulna Area										0	
Rajshahi Area										0	
Comilla Area										0	
Mymensingh Area										0	
Sylhet Area										0	
Barisal Area										0	
Rangpur Area										0	
Total										0	
Information of the Generating Units under shut down.											
Planned Shut- Down										Forced Shut- Down	
Nil										1) Barapukuria ST: Unit-1	
										2) Sylhet 20 MW	
										3) Khulna ST 110 MW (04/11/14)	
										4) Ghorasal Unit-3,4	
										5) Baghabari 100 MW	
										6) Tongi GT	
										7) Chittagong Unit-1,2	
										8) Baghabari-71 MW	
										9) Siddhirganj 210 MW ST	
Additional Information of Machines, lines, Interruption / Forced Load shed etc.											
Description										Comments on Power Interruption	
a) Ishurdi 132/33 kV T2 transformer tripped at 10:04 from both sides showing L/O at 132 kV & 33 kV side and was switched on at 10:10.										About 20 MW Power interruption occurred under Ishurdi S/S area from 10:04 to 10:10.	
b) After maintenance Bheramara CAPP GT & ST were synchronized at 09:30 & 14:32 respectively.											
c) After maintenance Sikalbaha 132 kV bus-2 was under shut down from 08:30 to 10:50 for red hot maintenance.											
d) Rampura-Bashundhara 132 kV Ckt-1 tripped at 10:01 from both ends showing Dist Z1 and was switched on at 10:44.											
e) Joydevpur 132/33 kV T3 & T4 transformers tripped at 09:06 from both end showing gen trip, 33 kV feeder fault and were switched on at 09:17.										About 84 MW Power interruption occurred under Joydevpur S/S area from 09:06 to 09:17.	
f) Jamalpur 100 MW PP tripped at 11:39 due to B-phase conductor P.Plant end got snapped and was synchronized at 15:13.											
g) Faridpur 132/33 kV T1 transformer was under shut down from 10:43 to 12:38 due to oil leakage 33 kV Y-phase bushing.										About 20 MW Power interruption occurred under Faridpur S/S area from 10:43 to 12:38.	
h) Purbasadipur 132/33 kV T1 transformer along with 33 kV bus was under shut down from 12:56 to 14:06 for bus Isolator red hot maintenance.											
i) After maintenance Ghorasal ST:Unit-1 was synchronized at 14:25.											
j) After maintenance HVDC Bheramara 230 kV bus was switched on at 15:44.											
k) Sirajganj CAPP GT & ST were synchronized at 16:45 & 19:39 respectively.											
l) Dutched Bangla-Siddhirganj 132 kV Ckt was switched on at 21:35.											
m) After maintenance Modunaghat 132/33 kV T1 transformer was switched on at 17:31.											
n) After maintenance Aminbazar-Savar 132 kV Ckt-1 was switched on at 18:06.											
o) Sylhet 132/33 kV T4 transformer tripped at 21:51 showing temperature alarm and was switched on at 22:40.										About 64 MW Power interruption occurred under Sylhet S/S area from 21:51 to 22:40.	
p) Ashuganj-Kishoreganj 132 kV Ckt-2 was shut down at 07:15 (04/06/2018) for C/M.											
q) Rampura-Bhulta 230 kV Ckt-3 was shut down at 05:30(04/06/2018) for D/W.											
Sub Divisional Engineer										Executive Engineer	
Network Operation Division										Network Operation Division	
										Superintendent Engineer	
										Load Dispatch Circle	