POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1

Load Dispatch Circle

Reporting Date: 2-Sep-18 Till now the maximum generation is : -22:00 on 18-Jul-18 11387.0 Hrs 1-Sep-18 **Generation & Demand** Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterday's 8471.5 MW 12:00 Day Peak Generation Min Gen at 8.00 Evening Peak Generation 10617.0 MW Available Max Generation 12190 MW 21:00 Max Demand (Evening): 11100 MW E.P. Demand (at gen end) : 10617.0 MW 21:00 Maximum Generation 10617.0 MW Reserve(Generation end) 1090 MW 21:00 Total Gen. (MKWH) 0 MW System Load Factor 85.29% Load Shed EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -880 MW 19:30 MKWHR. Energy Import from West grid to East grid :- Maximum MW Energy - MKWHR. Water Level of Kaptai Lake at 6:00 A M on 2-Sep-18 Actual: 104.97 Ft.(MSL) Rule curve : 98.67 Ft.(MSL) Gas Consumed : 1206.20 MMCFD Oil Consumed (PDB): Total = HSD Liter FO Liter Cost of the Consumed Fuel (PDB+Pvt): Gas Tk102.827.905 Coal Tk0 : Tk476,541,963 Total : Tk579,369,868 **Load Shedding & Other Information** Today Area Yesterday Estimated Demand (S/S end) Estimated Shedding (S/S end) Rates of Shedding MW MW MW (On Estimated Demand) Dhaka 0:00 3880 0 0 0% 0.00 1319 0% Chittagong Area 0 n 0:00 1182 0% Khulna Area 0 0 Rajshahi Area 0 0:00 1068 0% 0 Comilla Area 0 0:00 965 0% 0 779 Mymensingh Area 0 0:00 0% 0 Sylhet Area 0 0:00 436 0% 0 0% Barisal Area 0:00 201 Rangpur Area 601 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut- Down 1) Barapukuria ST: Unit-1,2,3 10) Fenchuganj CCPP-2 2) Khulna ST 110 MW 11) Ashuganj Unit-4 3) Ghorasal Unit-4, 4) Baghabari 100 MW 5) Tongi GT 6) Chittagong Unit-1,2 7) Baghabari-71 MW 8) Ashuganj Unit-5 9) Haripur GT-1 Additional Information of Machines, lines, Interruption / Forced Load shed etc. **Comments on Power Interruption** Description a) Bheramara-Kustia 132 kV Ckt-1 & Bus-A were under shut down from 07:15 to 11:19 for development work. b) Khulna (C) 132/33 kV T2 transformer tripped at 09:27 showing E/F relay and was switched on at 10:41. c) Ashuganj Unit-3 tripped at 11:54 due to CW pump problem and was synchronized at 14:15. d) Tongi-Kabirpur 132 kV Ckt-1 tripped at 11:25 from Tongi end showing dist relay and was switched on at 11:39. About 146 MW Power interruption occurred under Kodda & Manikganj S/S areas from 11:25 to 11:39. e) Uttara (3rd phase) 132/33 kV T1 transformer was under shut down from 12:28 to 15:45 for checking under ground cable. f) Manikganj 132/33 kV T2 transformer was under shut down from 10:40 to 12:28 for OLTC maintenance work. About 80 MW Power interruption occurred under Comilla (S) g) Comilla (S) 132/33 kV T1 & T2 transformers tripped at 17:35 showing definite earth current relay and were switched on at 18:11. S/S area from 17:35 to 18:11. h) Ashuganj Unit-5 was synchronized at 22:58. i) Bhola 225 MW GT-2 was synchronized at 23:45.) Madunaghat 132/33 kV T1 & T2 transformers tripped at 04:13 (02/09/2018) due to 33 kV under ground cable burn and were switched on at 08:32 & 04:55 (02/09/2018) respectively. Sub Divisional Engineer **Executive Engineer** Superintendent Engineer

Network Operation Division

Network Operation Division