		POWER GE	RID COMPANY OF BAN							
			NAL LOAD DESPATC						QF-LDC-08	
		NATIO	DAILY REPORT						Page -1	
			DALET KEFORT				Reporting Date :	6-Oct-18	I age -I	
Till now the maximum generatio	n ie ·	11623 MW			10-		1 19-Sep-18	0-000-10		
The Summary of Yesterday's	5-Oct-18		4		13.		al Min Gen. & Pr	obable Con & I	Domand	
Day Peak Generation :		1.0 MW	<i>.</i>	Hour :	12:00	Min. Gen. at	8:00		MW	
Evening Peak Generation :		8.0 MW		Hour :	21:00	Available Max		12786		
E.P. Demand (at gen end) :		8.0 MW		Hour :	21:00	Max Demand		11500		
Maximum Generation :		B.0 MW		Hour :	21:00	Reserve(Gene		1286		
Total Gen. (MKWH)	21			System Load Factor	: 85.60%	Load Shed	·		MW	
	2.			ST INTERCONNECTOR		Loud onod				
Export from East grid to West grid :-	Maximum				MW .	at 5:00	Energy		MKWHR.	
Import from West grid to East grid :-						at -	Energy	-	MKWHR.	
Water Level of Kaptai Lake at 6:00 A		6-Oct-18								
Actual : 102				Rule curve	: 106.36	Ft.(MSL)				
Gas Consumed : T	otal = 1187	46 MMCFD.			Oil Consu	med (PDB):				
				HSD :				Liter		
							FO :		Liter	
Cost of the Consumed Fuel (PDB+P)	/t): Gas	:	Tk99,560,822							
, , , , , , , , , , , , , , , , , , ,	Coal	:	Tk16,086,936		Oil	: Tk381,772,86	6 Total :	Tk497,420,624		
	Load Shed	ding & Other Information								
Area	Yesterday					Today				
	•		Estimated Demand (S/S	S end)		Estimated Sh	edding (S/S end)	Rates of Shedd	ling	
M			MW					(On Estimated D		
Dhaka 0			4008				0	0%		
Chittagong Area 0			1363				0	0%		
Khulna Area 0	0:00		1222				0	0%		
Rajshahi Area 0	0:00		1104				0	0%		
Comilla Area 0	0:00		998				0	0%		
Mymensingh Area 0	0:00		805				0	0%		
Sylhet Area 0	0:00		450				0	0%		
Barisal Area 0	0:00		207				0	0%		
Rangpur Area 0	0:00		621				0	0%		
Total 0			10777				0			
In	formation of the G	enerating Units under shut o	down.							
Planne	d Shut- Down				Forced S	hut- Down				
					1) Barapu	kuria ST: Unit-1,2	9) Siddhirganj	210 MW ST		
Nil						ST 110 MW	10) Kaptai #5			
					3) Ghoras	al Unit-3,4	11) Siddhirgan	j CCPP-335 MW	/	
					4) Baghab	pari 100 MW	12) Sylhet-150			
					5) Tongi G		13) Santahar-5	50 MW		
					6) Ashuga	anj Midland 51 MV	V 14) Sirajganj u	nit-3 255 MW		
					7) Baghat	pari-71 MW		Precision) 55 MV	N	
					8) Haripur	GT-1,2				
Additio	nal Information o	f Machines, lines, Interrup	otion / Forced Load she	ed etc.						
	Descriptio					Comme	nts on Power Int	erruption		
a) Baraulia-KSRM 132 kV line was u		n 09:03 to 14:12 for correc	tive maintenance.							
b) Khulna 225 MW CCPP ST synchronized at 09:06.										
c) Daudkandi- Cumilla(North) 132 kV	ckt-1 tripped at 11	:31 from both end showing	distance Z1 at both side	is and						
switched on at 11:43.										
<ul> <li>d) Khulna (C) 132/33 kV T1 transform</li> </ul>										
e) Chuadanga 132/33 kV T2 transformer was under shut down from 10:32 to11:18 for corrective maintenance.										
f) Ashuganj- Kishoreganj 132 kV ckt-2 was under shut down from 10:38 to 12:47 for corrective maintenance.										
g) Shyampur-Brammangaon 132 kV line was under shut down from 08:27 to 18:00 for development work.										
h) Tangail 132/33 kV T1 & T2 transformers were under shut down from 10:02 to 11:12 and 11:23 to 12:34 respectively										
due to corrective maintenance.										
i) Hathazari 230/132 kV T4 transform										
j) Halishahar 132/33 kV T1 transformer was under shut down from 08:05 to 13:05 due to annual maintenance.										
						About 120 MW power interruption occurred at Manikganj & Kodda S/S				
						14:49 to 14:58.				
I) Tongi- Kabirpur 132 kV line-1 tripped at 14:49 from Tongi end showing Dist. zone-1 and switched on at 14:57.										
m) Halishahar-Khulshi 132 kV line-2 was switched on at 16:47.										
n) Tongi- Uttara 132 kV line switched on at 16:25 and again switched off at 20:51.										
<ul> <li>o) Mirpur- Uttara 132 kV line switched off at 16:26 at Uttara end and switched on at 20:50.</li> <li>p) Bheramara 410 MW GT was synchronized at 18:20.</li> </ul>										
<ul> <li>p) Bneramara 410 MW GT was synchronized at 18:20.</li> <li>q) Kodda 132 kV bus-2 was shut down at 07:59 (06/10/2018) for corrective maintenance.</li> </ul>										
r) Sikalbaha 150 MW GT was shut down at 01:05(06/10/2018) for air filter cleaning.										
s) Sikalbaha 225 MW CCPP tripped at 03:29(06/10/2018) due to gas regulating valve. t) Tongi-Uttara 132 kV line was under shut down from 05:02(06/10/2018) to 07:02 for red hot maintenance at Uttara end.										
u) Bheramara CCPP ST was synchronized at 05:02(06/10/2018).										
v) Bakulia-Sikalbaha 132 kV ckt-1 wa			ve maintenance							
w) Shyampur-Brammangaon power				nent work.						
x) Mymensing 132 kV bus-2 & Myme										
for development work.				5, 15, 2010)						
v) Hathazari 230 kV bus-2 was under	shut down from N	6:40(06/10/2018) to 07:35 c	lue to corrective mainter	nance.						
,,										
Sub Divisional Engineer			Executive Engine	er	:	Supe	erintendent Engir	neer		
Network Operation Division			Network Operation Div			- 494		patch Circle		
		-								