

QF-LDC-08  
Page -1

### Load Shedding & Other Information

Information of the Generating machines under maintenance

**Additional Information of Machines, lines, Interruption / Forced Load shed etc**

Description	Forced load shed / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 690 MW (20:00) of load shed was imposed over the whole area of the national grid .
b) Due to gas limitation, Raozan (180 MW), NEPC (95 MW), RPCL (175 MW), and Meghnaghat P.Ltd (450) were limited to 170 MW , 34 MW, 105 MW , 428 MW and 337 MW respectively.	
c) Due to gas limitation, Shahjibazar - 4 & 5, Haripur SBU GT-1, 2, 3 (96 MW) were under shut down.	
d) Ashuganj unit -2 was shut down at 01:15 (10/08/09) due to maintenance of turbine,	
e) Due to tripping of Shahjibazar 33/.4 KV transformer ( 33 KV CT burst) , Shahjibazar GT-9, Shahjibazar Rental (50 MW), Shahjibazar Power Co. Ltd. (86 MW) tripped at 18:05. The machines were synchronized at 18:30 , 18:23 and 18:40 respectively.	
f) After maintenance, Ishurdi - Baghabari 230 KV line -2 was switched on at 10:00.	
g) Hasnabad - Kamrangirchar 132 KV line was under shut down from 11:10 to 18:50 due to red-hot maintenance of Y-phase line isolator at Kamrangirchar end.	
h) Bheramara - Bottail 132 KV line -2 was under shut down from 11:27 to 18:02 due to red-hot maintenance of Y-phase isolator at Bheramara end.	
	Due to generation shortage and MVAR problem, about 120 MW (09:00) of load shed has been running since morning (10/08/09) over the whole areas (except Sylhet ) of the national grid.
Deputy / Asstt. Manager Load Despatch Division	Deputy General Manager Load Despatch Circle