

QF-LDC-08  
Page -1

Reporting Date : 11-Aug-09

## EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Cost of the Consumed Fuel (PDB) :	Gas	:	Tk54.378.543		Oil	:	Tk17.876.444		Total	:	Tk72.254.987
-----------------------------------	-----	---	--------------	--	-----	---	--------------	--	-------	---	--------------

Area	Yesterday			Today		
	Actual Shedding (s/s end)			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	MW	fro	to			
Dhaka	163	(19:30-cont'd, gen. shortage)		1700	357	21%
Chittagong Area	133	(19:30-cont'd, gen. shortage)		490	102	21%
Khulna Area	111	(19:30-cont'd, gen. shortage)		425	86	20%
Rajshahi Area	101	(19:30-cont'd, gen. shortage)		380	72	19%
Comilla Area	71	(19:30-cont'd, gen. shortage)		280	65	23%
Mymensing Area	57	(19:30-cont'd, gen. shortage)		230	33	14%
Sylhet Area	38	(19:30-00:50, gen. shortage)		180	38	21%
Barisal Area	21	(19:30-cont'd, gen. shortage)		80	17	21%
Rangpur Area	50	(19:30-cont'd, gen. shortage)		195	22	11%
<b>Total</b>	<b>745</b>	<b>20:00</b>		<b>3960</b>	<b>792</b>	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	7) Baghabari GT-2(02/07/09)
	8) Siddhirgonj Steam (05/08/09)
	9) Ashuganj CCPP St (07/08/09)
	10) Raozan -1 (08/08/09)
	11) Ashuganj -2 (10/08/09)
2) Kapital- 3 (19/04/08)	
3) Shajibazar- 2 (13/07/08)	
3) Shajibazar-4 (18/10/08)	
4) Ghorasal-1 (30/09/08)	
5) Khulna 110 (31/03/09)	
6) NEPC 1 unit is under S/D	

**Additional Information of Machines, lines, Interruption / Forced Load shed etc**

Description	Forced load shed / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 745 MW (20:00) of load shed was imposed over the whole area of the national grid .
b) Due to gas limitation, Raozan (180 MW), NEPC (95 MW), RPCL (175 MW), and Meghnaghat P.Ltd (450) were limited to 170 MW , 35 MW, 105 MW , 436 MW and 347 MW respectively.	
c) Due to gas limitation, Shahjibazar - 4 & 5, Haripur SBU GT-1, 2, 3 (96 MW) were under shut down.	
d) Haripur NEPC tripped at 15:40 due to tripping of gas booster and was synchronized at 17:12.	
e) Ashuganj CCGT GT-2 tripped at 23:01 showing ' Fire protection alarm ' and was synchronized at 00:11 (11/08/09).	
f) Thakurgaon - Purbasadipur 132 KV line-2 was shut down at 09:25 due to NLDC project work.	
g) Haripur 132/33 KV GT-2 transformer tripped at 21:28 showing ' DIST, O/C ' and was switched on at 21:50.	Power interruption occurred (25 MW) under Haripur S/S areas from 21:28 to 21:50.
	Due to generation shortage and MVAR problem, about 150 MW (09:00) of load shed has been running since morning (11/08/09) over the whole areas (except Sylhet ) of the national grid.

Deputy General Manager  
Load Despatch Circle