POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER

OF-LDC-08 DAILY REPORT Page -1 Hrs on 19-Sep-18
Today's Actual Min Gen. & Probable Gen. & Demand
Min. Gen. at 5:00 4040 \ \text{Actual Min Gen.} \text{ Actual Min Min Ge Reporting Date: 6-Dec-18 Till now the maximum generation is: 11623 MW 19:30 The Summary of Yesterday's
Day Peak Generation : 5-Dec-18 c-18 Generation & Demand 6622.4 MW Evening Peak Generation E.P. Demand (at gen end) 8458.0 MW 19:30 Available Max Generation 11667 MW 8458.0 MW 19:30 Max Demand (Evening) 8600 MW Maximum Generation 8458.0 MW 19:30 Reserve(Generation end) 3067 MW Total Gen. (MKWH) 76.09% 154.5 System Load Factor Load Shed 0 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum -500 MW at 8:00 Energy MKWHR. Import from West grid to East grid :- Maximum Energy Water Level of Kaptai Lake at 6:00 A M on 6-Dec-18 Actual : Ft.(MSL) Rule curve : Ft.(MSL) 100.02 105.55 1031.46 MMCFD. Oil Consumed (PDB): Gas Consumed Total = HSD Lite FO Liter Cost of the Consumed Fuel (PDB+Pvt) : Tk82,487,787 Gas Tk14,141,882 : Tk108,523,097 Total : Tk205,152,767 **Load Shedding & Other Information** Area Yesterday Today Rates of Shedding Estimated Demand (S/S end) Estimated Shedding (S/S end) MW MW (On Estimated Demand) MW 2989 1009 Dhaka 0:00 0% 0% 0 0:00 Chittagong Area Khulna Area 0 0:00 903 0 0% 816 0% Raishahi Area 0:00 0 Comilla Area 0:00 737 0 0% 595 Mymensingh Area 0:00 0 0% Sylhet Area 0:00 342 0% Barisal Area 0.00 153 n 0% Rangpur Area Total 8004 Information of the Generating Units under shut down. Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-1,2 10) Ghorasal Max 2) Khulna ST 110 MW 11) Siddhirganj GT-1,2 3) Ghorasal Unit-2,3,4,5 4) Tongi GT 5) Bheramara-410 MW ST 6) Baghabari 100 MW 7) Siddhirganj ST 210 MW 8) Siddhirgani 335 MW 9) Summit Bibiyana-2 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Kaptai-Hathazari 132 kV Ckt-2 was under shut down from 08:21 to 15:57 for A/M. b) Juldah-Shahmirpur 132 kV Ckt-2 was under shut down from 09:03 to 15:32 for A/M. c) Aminbazar 230/132 kV T2 transformer was under shut down from 09:20 to 16:53 for A/M. d) Comilla(N)-Meghnaghat 230 kV Ckt-2 was under shut down from 09:05 to 14:58 for A/M. e) Rampura-Bhulta 230 kV Ckt-4 was under shut down from 09:21 to 13:59 for A/M. f) Manikganj 132/33 kV T2 transformer & Manikganj-Kabirpur 132 kV Ckt-2 was under shut down from 08:20 to 14:50 for A/M. g) Kulaura 132 kV busbar-1 was under shut down from 09:31 to 13:56 for A/M. h) Ashugani-B.Baria 132 kV Ckt-1 was under shut down from 08:38 to 16:11 for A/M. i) Sylhet-Chattak 132 kV Ckt-1 was under shut down from 09:54 to 11:02 for A/M. j) Sylhet-Chattak 132 kV Ckt-2 was under shut down from 11:05 to for A/M. k) Srimongal-Fenchuganj 132 kV Ckt-1 was under shut down from 08:30 to 16:10 for A/M. I) Bhulta 400/230 kV T1 transformer was under shut down from 10:17 to 14:01 for D/W. m) Chapainawabganj 100 MW P/S was shut down at 08:27 and was synchronized at 14:58. n) Natore-Ishurdi 132 kV Ckt-2 was under shut down from 08:16 to 14:37 for A/M. o) Palashbari 132/33 kV T4 transformer was under shut down from 09:05 to 15:07 for A/M. p) Barisal-Bhola 230 kV Ckt-2 was under shut down from 08:06 to 16:12 for A/M. q) Khulna(S) 132 kV capacitor bank was under shut down from 09:05 to 16:45 for A/M. r) Gallamari 132/33 kV T1 transformer was under shut down from 09:15 to 16:41 for A/M. s) Jessore 132/33 kV T2 transformer was under shut down from 08:18 to 15:44 for A/M. t) Bheramara HVDC 230 kV filter-1 was under shut down from 10:03 to for D/W. u) Bibiyana-3 auxiliary 230 kV Ckt was under shut down from 09:59 to 18:53 for D/W by BPDB. v) Mirpur 132 kV bus-1 was under shut down from 10:20 to 15:55 for A/M. w) Ghorasal Unit-2 tripped at 13:12 showing no relay. x) Bhulta 400/230 kV T2 transformer was under shut down from 14:37 to 16:46 for D/W. y) Sikalbaha 150 MW was synchronized at 15:21. z) Raozan Unit-2 was synchronized at 18:16. aa) Chandpur 150 MW GT was synchronized at 18:26. ab) Biyanibazar 132/33 kV T2 transformer tripped at 06:33 (06/12/2018) due to 33 kV Jakiganj feeder fault

Sub Divisional Engineer **Network Operation Division**

and was switched on at 07:00.

Executive Engineer Network Operation Division

Res. E/F at 230 kV sides & mech trip at 132 kV sides and Maniknagar-Matuail 132 kV areas from 01:40 to 02:10(06/12/2018).

on at 02:10 & T1 was switched on at 03:27. At the same time Maniknagar-Bangabhabon 132 kV Ckt-1,2 tripped from Maniknagar end only showing main/back-up protection and Ckt-1 was switched on at 02:50

ac) Maniknagar 230/132 kV T1 & T2 transformers tripped at 01:40(06/12/2018) from bo About 90 MW Power interruption occurred under Maniknagar & Narinda S/S

Superintendent Engineer Load Dispatch Circle