POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER

OF-LDC-08 DAILY REPORT Reporting Date: 13-Dec-18 Till now the maximum generation is: 19:30 Hrs 19-Sep-18 Today's Actual Min Gen. & Probable Gen. & Demand
Min. Gen. at 5:00 4980 MW The Summary of Yesterday's
Day Peak Generation : 12-Dec-18 ec-18 Generation & Demand 6519.0 MW Evening Peak Generation 8349 0 MW 19:00 Available Max Generation 11296 MW E.P. Demand (at gen end) 8349.0 MW 19:00 Max Demand (Evening) 8500 MW Maximum Generation 8349.0 MW 19:00 Reserve(Generation end) 2796 MW Total Gen. (MKWH) 153.0 System Load Factor : 76.37%

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR 0 MW Load Shed MKWHR. Export from East grid to West grid :- Maximum -640 MW at 8:00 Energy Import from West grid to East grid :- Maximum Energy Water Level of Kaptai Lake at 6:00 A M on 13-Dec-18 Actual : Ft.(MSL) Rule curve : 104.94 Ft.(MSL) 99.59 Oil Consumed (PDB): Gas Consumed 967.16 MMCFD. Total = HSD Liter Cost of the Consumed Fuel (PDB+Pvt): Tk81,593,766 Oil : Tk167,233,482 Tk14,163,112 Total : Tk262,990,360 Load Shedding & Other Information Today Estimated Shedding (S/S end) Estimated Demand (S/S end) Rates of Shedding On Estimated Demand Dhaka n·nn 3036 **Λ%** Chittagong Area 0:00 1026 0% Khulna Area Rajshahi Area 918 829 0% 0% 0:00 0:00 Comilla Area 0.00 749 0% 605 0% Mymensingh Area 0:00 Sylhet Area 0:00 347 0% 156 Barisal Area 0:00 0 0% Rangpur Area Total 8132 Information of the Generating Units under shut down Planned Shut- Down Forced Shut-Down 1) Barapukuria ST: Unit-1,2 10)Bhagabari 71,100MW 2) Khulna ST 110 MW 11) Raozan # 01 3) Ghorasal Unit-2,3,4,5 12) Sikalbaha 150 MW 4) Tongi GT 5) Siddhirganj GT-1,2 6) Baghabari 100 MW 7) Siddhirganj ST 210 MW 8) Siddhirganj 335 MW 9) Summit Bibiyana-2 Additional Information of Machines, lines, Interruption / Forced Load shed etc. Description Comments on Power Interruption a) Bibiyana Unit-3 GT was synchronized at 08:37 for on test. b) Khulna 225 MW GT was synchronized at 11:10. c) Bogura-Palashbari 132 kV Ckt-2 tripped at 10:25 from both ends showing Dist A-phase at Palashbari end & no relay at Bogura end and was switched on at 10:40. d) Aminbazar-Agargaon 230 kV Ckt-1 was under shut down from 09:55 to 15:54 for A/M. e) Kallayanpur 132 kV main bus was shut down at 08:58 for A/M. f) Savar 132/33 kV T1 transformer was under shut down from 09:31 to 12:55 for A/M. g) Tongi 230/132 kV T1 transformer was under shut down from 09:43 to 11:38 for A/M. h) Kaliakoir-Tangail 132 kV Ckt-1 was under shut down from 08:03 to 16:34 for A/M. i) Kabirpur 132/33 kV T03 transformer was under shut down from 09:25 to 13:25 for A/M. j) Comilla(N)-Ashuganj 230 kV Ckt-1 was under shut down from 08:53 to 15:20 for A/M. k) Haripur-Meghnaghat 230 kV Ckt-2 was under shut down from 09:00 to 15:52 for A/M. I) Jamalpur-Mymensingh 132 kV Ckt-1 was under shut down from 08:08 to 16:58 for A/M. m) B.Baria-Shahjibazar 132 kV Ckt-1 was under shut down from 08:52 to 16:39 for A/M. n) Srimongal-Fenchugani 132 kV Ckt-1 was under shut down from 09:52 to 13:03 for A/M. o) Mirpur-Uttara 132 kV Ckt was under shut down from 08:48 to 15:26 for A/M. p) Baraulia 132/33 kV T2 transformer was shut down at 08:12 for D/W. q) Kaliakoir 400/132 kV T1 transformer was under shut down from 09:52 to 14:18 for A/M. r) Madanganj-Munshiganj 132 kV Ckt-1 was under shut down from 09:52 to 16:00 for A/M. s) Baraulia 132/33 kV T1 transformer tripped at 12:11 from 33 kV side showing O/C and was About 40 MW Power interruption occurred under Baraulia S/S switched on at 12:27. t) Srimongal-Fenchuganj 132 kV Ckt-2 was under shut down from 13:07 to 17:16 for A/M. u) Raishahi 132/33 kV T2 transformer was under shut down from 10:21 to 12:05 for A/M. v) Bogura-Sirajganj 230 kV Ckt-1 was under shut down from 08:20 to 16:12 for A/M. w) Thakurgaon 132/33 kV T2 transformer was under shut down from 08:15 to 15:05 for A/M. x) Khulna(S)-Khulna(C) 132 kV Ckt-1 was under shut down from 09:13 to 14:30 for A/M. y) Chapainawabganj 132/33 kV T1 transformer was shut down at 09:06 for D/W. z) Fenchuganj S/S-Fenchuganj P/S 132 kV Ckt-1 was under shut down from 15:09 to 17:10 due to Y-phase CT oil leakage at Fenchugani S/S end. aa) Meghnaghat-Aminbazar 230 kV Ckt-1 was switched on at 17:18. ab) Bibiyana Unit-3 tripped at 15:35 during partial rejection test. ac) Ashuganj Unit-3 was shut down at 22:59 due to gas shortage. ad) Ashuganj Unit-4 was synchronized at 21:15. ae) Jamalpur 132/33 kV T1 transformer tripped at 06:55 (13/12/2018) due to 33 kV Dhanbari feeder fault and was switched on at 07:06. Sub Divisional Engineer Executive Engineer Superintendent Engineer

Network Operation Division

Load Dispatch Circle

Network Operation Division