			ı	POWER GRID COMPA	DESPATCH								QF-LDC-08
				DAIL	Y REPORT					Donortin	na Data :	14-Dec-18	Page -1
Till now the maximum generati	ion is : -		11623 MW					19:	30 Hrs on		ng Date :	14-Dec-18	
The Summary of Yesterday's		13-Dec-18	Generation & D	emand					Today's Actual	Min Gen.	. & Proba	able Gen. & Demand	
Day Peak Generation :		6723.8 8326.0				Hour:	12:00		Min. Gen. at		:00	4967 MW 10900 MW	
Evening Peak Generation : E.P. Demand (at gen end) :		8326.0 8326.0				Hour : Hour :	19:00 19:00		Available Max G Max Demand (E		:	10900 MW 8200 MW	
Maximum Generation :		8326.0				Hour :	19:00		Reserve(Genera			2700 MW	
Total Gen. (MKWH) :		156.1				System Load Factor	: 78.11		Load Shed	<u> </u>		0 MW	
,			EXPORT	/ IMPORT THROUGH	EAST-WEST	T INTERCONNECTOR	700 101		0.00		_		TTD.
Export from East grid to West grid : Import from West grid to East grid :							-720 MW MW	at at	8:00		Energy Energy	MKW - MKW	
Water Level of Kaptai Lake at 6			14-Dec-18					ut			Liloigy		1110.
Actual :	99.53	Ft.(MSL),				Rule cu	irve :	104.80	Ft.(MSL)				
	-	070.05					010		(DDD)				
Gas Consumed :	Total =	972.95	MMCFD.				Oil Co	onsumed	(PDB):	HSD		Liter	
										FO	:	Liter	
Cost of the Consumed Fuel (PDB+I	Pvt):	Gas : Coal :			3,077,294			Oil	. Th161 004 470		Total	TLOED 104 777	
		Coai .	•	IKI	4,133,004			Oil	: Tk161,894,479		TOTAL .	Tk259,104,777	
		Load Sheddin	ng & Other Inforn	nation									
Area	Yesterd	lay		Estimated	Demand (S/S e	and)			Today Estimated Shed	ding /9/9	and)	Rates of Shedding	
	MW			Estimated	MW	enu)			Estimated Shed	MW	enu)	(On Estimated Deman	d)
Dhaka	0	0:00			2905						0	0%	-/
Chittagong Area	0	0:00			980						0	0%	
Khulna Area Rajshahi Area	0	0:00 0:00			877 792						0	0% 0%	
Comilla Area	0	0:00			716						0	0%	
Mymensingh Area	0	0:00			578						0	0%	
Sylhet Area	0	0:00			333						0	0%	
Barisal Area	0	0:00 0:00			149 445						0	0% 0%	
Rangpur Area Total	0	0.00			7774						0	070	
	Informatio	n of the Genera	ating Units under	shut down.									
Pla	anned Shut-	Down					Force	d Shut-	Down				
									ST: Unit-1,2	10)Bha	gabari 7	1,100MW	
Nil								ulna ST			ozan#0		
								ıorasal U ngi GT	nit-2,3,4,5		albaha 19 eramara-		
								ldhirganj	GT-1.2	13) DIR	eraniara-	410 10100	
							6) Ba	ghabari 1	00 MW				
									ST 210 MW				
								idhirganj mmit Bib	335 MW				
							<i>5)</i> 0u	minic Dib	iyana-z				
Ad	ditional Info	rmation of Ma	chines, lines, Int	erruption / Forced Lo	ad shed etc.								
		Description							Comments on	Power In	terruptio	on	
a) Bakulia-Sikalbaha 132 kV Ckt-1													
b) Mirpur 132 kV Reserve Bus was													
c) Haripur-Megnaghat 230 kV Ckt-2 was under shut down from 09:40 to 20:05 for A/M. d) Jamalpur-Mymensing 132 kV Ckt-1 was under shut down from 09:05 to 16:11 for A/M.													
e) Munsiganj-Madanganj 132 kV Ckt-1 was under shut down from 10:09 to 14:46 for A/M.													
f) B.Baria-Shahjibazar 132 kV Ckt-1 was under shut down from 09:20 to 15:54 for A/M.													
g) Shahjibazar-Sreemongal 132 kV Ckt-1 was under shut down from 09:41 to 11:45 for A/M. h) Shahjibazar-Sreemongal 132 kV Ckt-2 was under shut down from 11:49 to 12:34 for A/M.													
i) Fenchuganj S/S-Fenchuganj P/S													
j) Joydevpur 132/33 kV T-4 transfor													
k) Bogura-Sirajganj 230 kV Ckt-1 w													
 I) Khulna(S)-Gallamari 132 kV Ckt- m) Hathazari-Raozan 230 kV Ckt-2 													
at R-phase line isolator of Hathaz		silut down iloin	09.03 to 13.10 to	red not maintenance									
n) Siddirganj S/S-Siddirganj GT-1 was shut down at 09:50 for maintenance and was switched on at 13:08.													
o) Sikalbaha-Julda 132 kV Ckt was shut down at 10:21 for development work.													
p) After maintenance Kallyanpur 132 kV main Bus was switched on at 15:36. q) Bibiyana #3 GT was synchronized at 08:35 and shut down at 21:14 for full load rejection test.													
r) Cumilla(S)-Surjamoni Nagar(India					OTF								
ABC due to R-phase IVT failure a	t Cumilla(S)	end.	, ,	· ·			1						
s) Rampura 230/132 kV TR-1 trans							,						
t) Megnaghat-APR 230 kV Ckt is ur u) Bogura-Sirajganj 230 kV Ckt-2 is													
v) Siddirganj-Maniknagar 230 kV Ckt-2 is													
, , , , , , ,			,	•									
Sub Divisional Engineer				Execu	ıtive Engineer				Superi	ntendent	Enginee	r	
Network Operation Division		Network Operation Division					Load Dispatch Circle						