

QF-LDC-08  
Page -1

### EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Cost of the Consumed Fuel (PDB) :	Gas	:	Tk53,560,360		Oil	:	Tk11,981,246		Total	:	Tk65,541,606
-----------------------------------	-----	---	--------------	--	-----	---	--------------	--	-------	---	--------------

Area	Yesterday			Today			
	Actual Shedding (s/s end)			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)	
	MW	fro	to				
Dhaka	255	(19:30-06:55, gen. shortage)		1700	325	19%	
Chittagong Area	108	(19:30-06:55, gen. shortage)		470	72	15%	
Khulna Area	91	(19:30-06:50, gen. shortage)		421	74	18%	
Rajshahi Area	81	(19:30-06:55, gen. shortage)		382	67	18%	
Comilla Area	64	(19:30-04:03, gen. shortage)		266	45	17%	
Mymensing Area	53	(19:30-04:03, gen. shortage)		240	38	16%	
Sylhet Area	28	(19:30-00:22, gen. shortage)		175	30	17%	
Barisal Area	18	(19:30-06:50, gen. shortage)		80	16	20%	
Rangpur Area	44	(19:30-06:55, gen. shortage)		195	19	10%	
<b>Total</b>	<b>742</b>	<b>20:00</b>		<b>3929</b>	<b>686</b>		

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	7) Baghabari GT-2(02/07/09)
2) Shajibazar- 2 (13/07/08)	8) Ashuganj CCPP St (07/08/09)
3) Shajibazar-4 (18/10/08)	9) Raozan -1 (08/08/09)
4) Ghorasal-2 (13/08/09)	10) Ashuganj CCPP GT-1 (12/08/09)
5) Khulna 110 (31/03/09)	11) Ghorasal -6(14/08/09)
6) NEPC 1 unit is under S/D	12) Siddhirganj 210 MW (15/08/09)

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 742 MW (20:00) of load shed was imposed over the whole area of the national grid .
b) Due to gas limitation, Raozan (180 MW), NEPC (95 MW), RPCL (175 MW) and Haripur SBU (64 MW) were limited to 170 MW , 73 MW,144 MW and 38 MW respectively.	
c) Due to gas limitation, Shahjibazar - 4 & 5, Haripur SBU GT- 3 (32 MW) were under shut down.	
d) Baghabari GT-1 (71 MW) tripped at 18:47 due to auxiliary failure and was synchronized at 03:47 (17/08/09).	
e) Ashuganj unit -1 was forced shut down at 04:35 (17/08/09) due to seal oil vacuum pump trip and was synchronized at 09:53 (17/08/09).	
f) Tongi GT was shut down at 06:40 (17/08/09) due to changing of filter. It may be synchronized before evening peak hour today.	
g) Rangpur - Barapukuria 132 KV line -1 , Rajshahi - Chapainababganj 132 KV line -2 and Rangpur - Barapukuria 132 KV line -2 were under NLDC project work from 09:20 to 15:04, 09:44 to 14:16 and 15:35 to 21:10 respectively.	
h) Barapukuria - Bogra 230 KV line -1 was under shut down from 10:58 to 18:22 for project work.	
i) After maintenance, Kabirpur 132/33 KV T2 transformer was switched on at 17:45.	
j) After maintenance, Gulshan 132/33 KV MT2 transformer was switched on at 11:35. Again it was under shut down from 18:10 to 18:50 due to maintenance of B-phase U/G cable line .	
	Due to generation shortage and MVAR problem , about 150 MW (10 :00) of load shed has been running since morning (17/08/09) over the whole area (except Sylhet ) of the national grid.

Deputy General Manager  
Load Despatch Circle