POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTER DAILY REPORT

QF-LDC-08 Page -1

Reporting Date 8-Dec-10 4698.5 MW at Till now the maximum generation is: 20-Aug-10 7-Dec-10) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand The Summary of Yesterday's (Day Peak Generation 3214.0 MW Hour 10:00 Min Gen. at 2582 MW Evening Peak Generation 3502.7 MW Max Generation 3520 MW Hour 20:00 E.P. Demand (at gen end) : 4300.0 MW 20:00 Max Demand 4300 MW Hour Maximum Generation 3502.7 MW Hour 20:00 Shortage 780 MW Total Gen. (MKWH) 72.82 System L/ Factor 85.41% Load Shed 695 MW EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from East grid to West grid :- Maximum MW 7391000 KWHR. at Energy MW KWHR. Import from West grid to East grid :- Maximum Energy at

Water Level of Kaptai Lake at 6:00 A M of 8-Dec-10

Actual 100.34 Ft.(MSL) Rule curve 105.37 Ft.(MSL)

> MMCFt. Oil Consumed (PDB):

HSD 1657416 Liter FO 0 Liter

Cost of the Consumed Fuel (PDB): Gas : Tk66,296,626 Total: Tk109,633,015

Load Shedding & Other Information

Gas Consumed :

| Area | Yesterday | | | Today | Today | |
|-----------------|-----------|-----------------------------|---------------------------|---------------------------|-----------------------|--|
| """" | | | Estimated Demand(s/s end) | Estimated Shedding (s/s e | Rates of Shedding | |
| | MW | | from toMW | MW | (On Estimated Demand) | |
| Dhaka | 330 | (17:00-22:34 gen. shortage) | 1653 | 265 | 16% | |
| Chittagong Area | 95 | (17:00-22:31 gen. shortage) | 465 | 96 | 21% | |
| Khulna Area | 74 | (17:00-21:56 gen. shortage) | 428 | 90 | 21% | |
| Rajshahi Area | 66 | (17:00-21:58 gen. shortage) | 350 | 73 | 21% | |
| Comilla Area | 50 | (17:00-22:07 gen. shortage) | 277 | 58 | 21% | |
| Mymensing Area | 35 | (17:00-21:54 gen. shortage) | 178 | 37 | 21% | |
| Sylhet Area | 21 | (17:00-21:55 gen. shortage) | 201 | 20 | 10% | |
| Barisal Area | 10 | (17:00-21:56 gen. shortage) | 80 | 14 | 18% | |
| Rangpur Area | 29 | (17:00-21:57 gen. shortage) | 198 | 42 | 21% | |
| Total | 710 | 20:00 | 3830 | 695 | | |

Information of the Generating machines under shut down.

| Planned Shut- Down | Forced Shut-Down | |
|--------------------------------|------------------------------------|-------------------------------|
| 1) Haripur SBU GT-3 (18/06/09) | 9) Kaptai #3 (1/12/10) | 1) Ghorasal 6(18/07/10) |
| 2) Ghorasal 2(26/04/10) | 10) Megnaghat P. ltd GT-1(7/11/10) | 2) Ashuganj-1(09/11/10) |
| 3) Siddirganj GT-1 (18/06/10) | 11) Barapukuria-1(09/11/10) | 3) Sikalbaha 60MW(19/11/10) |
| 4) Ashuganj-4(12/09/10) | | 4) Siddirganj-210MW(23/11/10) |
| 5) Raozan-1 (03/10/10) | | 5) Barapukuria-2(03/12/10) |
| 6) Sikalbaha GT (24/10/10) | | |
| 7) Raozan-2 (21/10/10) | | |
| 8) Kaptai #5 (02/11/10) | | |

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

| Description | Forced load shaded / Interrupted Areas |
|-------------|--|
| | 0 1 1740 1044 (00 00) (1 1 1 1 |

- a) There was generation shortage in the evening peak hour yesterday.
- b) Due to low gas pressure RPCL (210 MW) and Tongi (105 MW) were limited to 108 MW and 35 MW respectively.
- c) Patuakhali T2 (from 07:06 to 17:22), Madaripur T2 (from 09:12 to 14:10) 132/33 KV X-formers and Khulna (S) T02 (from 09:29 to 17:05), Tongi T02 (from 09:38 to 17:18) 230/132 KV X-formers were under annual maintenance.
- d) 132 KV Kishoreganj Ashuganj line-1 (from 08:26 to 15:15), Rangpur-Polashbari line-2 (from 09:12 to 17:18), Halishahar-Kulshi line-1 (from 10:15 to 15:40), Comilla (N) - Haripur line -1 (from 08:46 to 16:50) and 230 KV Rampura - Haripur line-1 (from 09:20 to 16:33) Baghabari-Ishurdi line-2 (from 08:55 to 16:36) were under annual maint.
- e) Ashuganj-Serajganj 230 KV line-2 was under shut down from 11:00 to 15:45 due to NLDC
- f) Baghabari 230/132 KV T01 was under shut down from 12:01 to 13:12 due to panel maintenance.
- g) Bashundhara 132 KV reserve bus was under shut down from 08:32 to 14:45 due to annual maint.
- h) Baghabari 100 MW was under forced shut down from 17:10 to 19:22 due to lube oil cooling system problem.

So about 710 MW (20:00) of load shed was imposed over the whole areas of the national grid.

Due to generation shortage, about 50 MW (09:00) of load shed has been running since morning (8/12/10) over the whole area (except Dhaka & Sylhet) of the national grid.

Deputy General Manager Deputy / Asstt. Manager Manager Network Operation Division Network Operation Division Load Despatch Circle