

**POWER GRID COMPANY OF BANGLADESH LTD.  
NATIONAL LOAD DESPATCH CENTER  
DAILY REPORT**

QF-LDC-08  
Page -1

Till now the maximum generation is : -		<b>12893 MW</b>	<b>21:00 Hrs</b>	Reporting Date : 4-Jul-19
<b>The Summary of Yesterday's</b>		3-Jul-19	<b>Generation &amp; Demand</b>	<b>Today's Actual Min Gen. &amp; Probable Gen. &amp; Demand</b>
Day Peak Generation :	9709.0 MW	12:00	Min. Gen. at	8:00 8380 MW
Evening Peak Generation :	12029.0 MW	21:00	Available Max Generation	14468 MW
E.P. Demand (at gen end) :	12049.0 MW	21:00	Max Demand (Evening) :	12500 MW
Maximum Generation :	12029.0 MW	21:00	Reserve(Generation end)	1968 MW
Total Gen. (MKWH) :	246.3	ystem Load Factor : 85.30%	Load Shed	0 MW
<b>EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR</b>				
Export from East grid to West grid :- Maximum	-500 MW	at	20:00	Energy MKWHR.
Import from West grid to East grid :- Maximum	-	MW	-	Energy - MKWHR.
Water Level of Kaptai Lake at 6:00 A M on		4-Jul-19		
Actual :	78.18	Ft.(MSL) ,	Rule curve :	84.48 Ft.( MSL )
Gas Consumed :	Total = 1303.64	MMCFD.	Oil Consumed (PDB) :	
			HSD :	Liter
			FO :	Liter
Cost of the Consumed Fuel (PDB+Pvt) :	<b>Gas</b> :	Tk104,442,484		
	<b>Coal</b> :	Tk18,822,518	Oil :	Tk403,829,790
			Total :	Tk527,094,792
<b><u>Load Shedding &amp; Other Information</u></b>				
Area	Yesterday		Today	
	MW	Estimated Demand (S/S end)	Estimated Shedding (S/S end)	Rates of Shedding
		MW	MW	(On Estimated Demand)
Dhaka	0	0:00	4457	0 0%
Chittagong Area	0	0:00	1519	0 0%
Khulna Area	0	0:00	1362	0 0%
Rajshahi Area	0	0:00	1231	0 0%
Comilla Area	0	0:00	1112	0 0%
Mymensingh Area	0	0:00	897	0 0%
Sylhet Area	0	0:00	497	0 0%
Barisal Area	0	0:00	231	0 0%
Rangpur Area	0	0:00	692	0 0%
<b>Total</b>	<b>0</b>	<b>11999</b>	<b>0</b>	
Information of the Generating Units under shut down.				
Planned Shut- Down		Forced Shut- Down		
		1) Barapukuria ST: Unit	7) Baghabari 100 MW	
		2) Khulna ST 110 MW	8) Ghorasal Unit-4	
		3) Sikalbaha ST 60 MW		
		4) Bheramara 410 MW.		
		5) Siddhirganj ST		
		6) Ashuganj #4,5		
<b>Additional Information of Machines, lines, Interruption / Forced Load shed etc.</b>				
<b>Description</b>			<b>Comments on Power Interruption</b>	
a) Bogura 132 kV main bus was under shut down from 08:35 to 13:30 for C/M.				
b) Bogura-Natore 132 kV Ckt-2 was under shut down from 08:50 to 13:57 for C/M.				
c) Barapukuria 230/132 kV T-1 transformer was under shut down from 09:28 to 13:52 for C/M.				
d) Shahmirpur-Juldah 132 kV Ckt-2 was under shut down from 09:01 to 11:07 for gas filling.				
e) Sikalbaha-Dohazari 132 kV Ckt-2 was under shut down from 09:25 to 10:58 for D/W.				
f) Jaldhaka 132/33 kV T-2 transformer was under shut down from 12:15 to 17:00 for C/M.				
g) Tangail 132/33 kV T-3 transformer was under shut down from 16:40 to 17:32 for C/M.				
h) Feni 132/33 kV T-2 transformer was under shut down from 06:14(04/7/2019) to 06:22 for C/M.				
i) Bhola GT-1 tripped at 18:14.				
Sub Divisional Engineer	Executive Engineer		Superintendent Engineer	
Network Operation Division	Network Operation Division		Load Despatch Circle	