POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC, DHAKA DAILY REPORT

QF-LDC-08 Page -1

Reporting Date : 2-Aug-08 Till now the maximum generation is: - MW at 4130.0 20:00 The Summary of Yesterday's (1-Aug-08) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation MW 9:00 3151 MW Hour Min Gen. at 8:00 **Evening Peak Generation** 3433.0 1/1/1/ Hour 20:00 Max Generation 3470 MW E.P. Demand (at gen end) : 4100.0 20:00 4300 MW MW Hour Max Demand Maximum Generation 3464.8 MW Hour 24:00 Shortage 830 MW Total Gen. (MKWH) 93.54% 625 MW 77.78 EXPORT / IMPORT THROUGH FAST-WEST INTERCONNECTOR 4125000 KWHR. Export from Ghorasal to Ishurdi :- Maximum 228 MW 19:00 Energy Import from Ishurdi to Ghorasal:- Maximum MW KWHR. at Energy

Water Level of Kaptai Lake at 6:00 A M of 2-Aug-08 78.14 Rule curve 89.32 Ft.(MSL)

Oil Consumed : PDB

SKO 0 Liter HSD 277620

So about 564 MW (20:00) of load shed was imposed over the whole

Liter FO 719078 Liter

Gas Consumed : Total 641.22 MMCFt.

Cost of the Consumed Fuel (PDB) : Tk47,392,570 Oil : Tk15,655,483 Total Tk63,048,053

Load Shedding & Other Information

Area	Yesterday Actual Shedding (s/s end), MW		Today		
			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	fr to m 18:30	5:15	MW	MW	(On Estimated Demand)
Dhaka	105		1540	216	14%
Chittagong Area	103		435	93	21%
Khulna Area	101		420	90	21%
Rajshahi Area	81		325	67	21%
Comilla Area	43		261	52	20%
Mymensing Area	51		180	34	19%
Sylhet Area	15		140	26	19%
Barisal Area	11		72	14	19%
Rangpur Area	54		175	33	19%
	(
Total	564	20:00	3548	625	

Information of the Generating machines under maintenance

Planned Shut- Dowr	Forced Shut- Down		
1) Khulna 60 MW (05/07/06)	1) Ashuganj CCPP ST-(20/10/07)	8) Shajibazar-2 (13/07/08)	
	2) Kaptai- 3 (19/04/08)	9) Sylhet GT (01/08/08)	
	3) Raozan -1 (05/07/08)		
	4) Sikalbaha St- (19/06/08)		
	5) Ashuganj -3 (13/05/08)		
	6) Ghorasal -1 (22/06/08)		
	7) 4 units of KPCL		

Additional Information of Machines. lin

Description Forced load shaded / Interrupted Areas

- b) Due to gas limitation, Raozan (180 MW), Siddhirganj (210 MW) and RPCL (210 MW) were limited to 90 MW ,100 MW and 128 MW respectively.
- c) Due to gas limitation, Raozan -2, Sikalbaha Steam, Haripur SBU GT1, GT2 & GT3 and Shahjibazar - 2 are under shut down.
 d) After maintenance, Ashuganj unit - 4 was synchronized at 23:47.

Deputy / Asstt. Manager

Load Despatch Division

a) There was generation shortage in the evening peak hour yesterday .

- e) Raoazan unit 1 was synchronized at 23:37. Unit -2 was shut down at 01:38 (02/08/08) for maintenance of unit breaker.
- f) Kabirpur Joydevpur 132 KV line -1 & 2 was under shut down from 09:50 to 19:50 due to installation of optical fiber.

Manager Deputy General Manager Load Despatch Division Load Despatch Circle

area of the national grid.