## POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC, DHAKA DAILY REPORT

QF-LDC-08 Page -1

4768500 KWHR.

KWHR.

Reporting Date: 9-Aug-08 Till now the maximum generation is: - MW at 4130.0 20:00 The Summary of Yesterday's ( 8-Aug-08 ) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation MW Hour 12:00 Min Gen. at 3134 MW **Evening Peak Generation** 3/178 2 1/1/1/ Hour 20:00 Max Generation 3500 MW 4250.0 4350 MW E.P. Demand (at gen end) MW Hour 20:00 Max Demand Maximum Generation 3516.5 MW Hour 22:00 Shortage 850 MW Total Gen. (MKWH) 91.78% 77.45 Load Shed 719 MW EXPORT / IMPORT THROUGH FAST-WEST INTERCONNECTOR

240 MW

at 3:00

Oil Consumed (PDB):

area of the national grid.

 Import from Ishurdi to Ghorasal:
 Maximum
 MW
 at

 Water Level of Kaptai Lake at 6:00 A M of
 9-Aug-08

MMCFt.

Actual: 78.67 Ft.(MSL), Rule curve: 91.56 Ft.(MSL)

SKO : 0 Liter HSD : 257425 Liter

Energy

Energy

FO : 711170 Liter

Cost of the Consumed Fuel (PDB): Gas : Tk48,779,122 Oil : Tk15,049,451 Total : Tk63,828,573

## Load Shedding & Other Information

659.98

Export from Ghorasal to Ishurdi :- Maximum

Gas Consumed: Total

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	fr <b>to</b> m 18:3	30 4:40	MW	MW	(On Estimated Demand)
Dhaka	10	)1	1570	225	14%
Chittagong Area	10	8	460	114	25%
Khulna Area	11	5	440	107	24%
Rajshahi Area	9	95	340	80	24%
Comilla Area	4	8	260	56	22%
Mymensing Area	4	9	192	44	23%
Sylhet Area	5	51	150	34	23%
Barisal Area	2	25	76	17	22%
Rangpur Area	6	51	185	42	23%
		(			
Total	65	20:00	3673	719	

Information of the Generating machines under maintenance

Forced Shut- Down		
1) Ashuganj CCPP ST-(20/10/07)	8) Tongi GT (04/08/08)	
2) Kaptai- 3 (19/04/08)	9) Ashuganj CCPP GT2-(07/08/08)	
3) Raozan -2 (02/07/08)		
4) Sikalbaha St- (19/06/08)		
5) Ghorasal -1 (22/06/08)		
6) 4 units of KPCL		
7) Shajibazar-2 (13/07/08)		
	2) Kaptai- 3 (19/04/08) 3) Raozan -2 (02/07/08) 4) Sikalbaha St- (19/06/08) 5) Ghorasal -1 (22/06/08) 6) 4 units of KPCL	

## Additional Information of Machines. lin

a) There was generation shortage in the evening peak hour yesterday . So about 653 MW (20:00) of load shed was imposed over the whole

- b) Due to gas limitation, Raozan (180 MW), Siddhirgani (210 MW), HPL (360 MW) and RPCL
- (210 MW) were limited to 90 MW ,100 MW, 350 MW and 160 MW respectively c) Due to gas limitation, Raozan -2, Sikalbaha Steam, Haripur SBU GT1, GT2 & GT3 and Shahjibazar 2 are under shut down.
- d) After maintenance, Kaptai unit -2 was synchronized at 11:10.
- e) After maintenance, Ashuganj unit 5 and unit 3 were synchronized at 19:25 and 02:25 (09/08/08) respectively.
- Sylhet GT tripped at 08:04 due to lub oil temperature high. It may be synchronized before evening peak hour today.
- g) Hathazari Madanhat 132 KV line -1 & 2 tripped at 12:15 and 12:16 from both side and Hathazari side showing 'DIST B & C-phase & E/F', 'on DISYT Y & B phase' and 'YB start E/F' respectively and were switched on at 13:10 and 12:19 respectively.
- h) Sylhet Chatak 132 KV line -1 tripped at 18:20 due to CT brust at Sylhet end. At the same time, Sylhet Chatak 132 KV line -2, Fenchuganj P/S Sylhet 132 KV line -1 & 2, Sylhet 20 MW (floating) and SRPS machines also tripped. Power supply was normalized by switched on Fenchganj P/S Sylhet 132 KV line -1 & 2 at 18:50. Sylhet Chatak 132 KV line -2 was switched on at 19:02. Line -1 is now unde maintenance. Sylhet 20 MW and SRPP machines were synchronized at 19:01 and 19:25 respectively
- i) After installation of optical fiber, Hathazari Baraulia 132 KV line -1& 2 were switched on at 16:58. Again line-1 is under shut down since 07:18 (09/08/08) due to the same reason

Power interruption (65 MW) occurred under Sylhet and Chatak S/S from 18:20 to 18:50.

Deputy / Asstt. Manager Load Despatch Division

Manager Load Despatch Division Deputy General Manager Load Despatch Circle