POWER GRID COMPANY OF BANGLADESH LTD. CENTRAL LOAD DESPATCH CENTER, LDC, DHAKA DAILY REPORT

QF-LDC-08 Page -1

KWHR.

Liter

Reporting Date : 7-Oct-08 Till now the maximum generation is: - MW at 4130.0 20:00 The Summary of Yesterday's () Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation MW 2351 MW 2848.0 Hour 11:00 Min Gen. at **Evening Peak Generation** 3871 0 1/1/1/ Hour 19:30 Max Generation 3880 MW E.P. Demand (at gen end) : 4050 MW 4000.0 MW Hour 19:30 Max Demand Maximum Generation 3871.9 MW Hour 19:30 Shortage 170 MW Total Gen. (MKWH) 77.58% 149 MW 72.09 EXPORT / IMPORT THROUGH FAST-WEST INTERCONNECTOR 5824500 KWHR. Export from Ghorasal to Ishurdi :- Maximum 360 MW at 21:00 Energy

MW

at

Oil Consumed (PDB):

: Tk14,656,593

Water Level of Kaptai Lake at 6:00 A M of 7-Oct-08

MMCFt.

Actual: 88.45 Ft.(MSL), Rule curve: 106.54 Ft.(MSL)

HSD : 246489 Liter

0

Tk58,328,534

Energy

Total :

SKO

FO : 701497 Liter

Tk43,671,941

Load Shedding & Other Information

590.88

Import from Ishurdi to Ghorasal:- Maximum

Cost of the Consumed Fuel (PDB): Gas

Gas Consumed: Total

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding
	frtom 18:	15 22:42	MW	MW	(On Estimated Demand)
Dhaka		-	1557	-	-
Chittagong Area	;	30	452	34	8%
Khulna Area		18	403	30	7%
Rajshahi Area		19	322	25	8%
Comilla Area	:	26	247	19	8%
Mymensing Area		-	187	14	7%
Sylhet Area		-	149	11	7%
Barisal Area		8	74	5	7%
Rangpur Area		11	156	11	7%
		(
Total	1:	12 19:30	3547	149	

Information of the Generating machines under maintenance

Planned Shut- Dowr		Forced Shut-Down
1) Khulna 60 MW (05/07/06)	1) Kaptai- 3 (19/04/08)	8) Ashugonj -1 (04/10/08)
	2) Raozan -1 (17/09/08)	9) Ashugonj CCPP St (01/10/08)
	3) Sikalbaha St- (19/06/08)	10) Tongi GT (01/10/08)
	4) Shajibazar-2 (13/07/08)	11) Barapukuria-2 (05/10/08)
	5) Shajibazar-4 (27/09/08)	12) Shajibazar-6 (02/10/08)
	6) Ghorasal-1 (30/09/08)	
	7) Ghorasal-5 (01/10/08)	

Additional Information of Machines. lines. Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening neak hour vesterday	So about 112 MW (19:30) of load shed was imposed over the whole

- b) Due to gas limitation, Raozan -1, Sikalbaha Steam and Shahijibazar -2, 4, 6 are under shut down. c) After maintenance, Ashuganj CCPP GT-1 was synchronized at 19:08.
- d) Comilla (N) Comilla (S) 132 KV line tripped at 17:36 showing 'E/F' due to snapping of C-phase jumper of 132 KV line isolator. Power supply was normalized at Comilla (S) S/S by switching on Comilla (N) Chandpur 132 KV line at 17:55. But this line also tripped at 18:25 due to the same reason. Then power supply was normalized by switching on Comilla (N) Feni 132 KV line -2 at 18:55. Comilla (N) Comilla (S) 132 KV line was switched on at 09:27 (07/10/08). Comilla (S) Chandpur 132 KV line is now under maintenance.

Power interruption (55 MW) occurred under Comilla (S) S/S areas from 17:36 to 17:55 and 18:25 to 18:55 respectively.

(except Dhaka, Mymensing & Sylhet) areas of the national grid.

 Deputy / Assit. Manager
 Manager

 Load Despatch Division
 Load Despatch Division

 Deputy General Manager

 Load Despatch Division
 Load Despatch Circle