POWER GRID COMPANY OF BANGLADESH LTD. NATIONAL LOAD DESPATCH CENTEF DAILY REPORT

QF-LDC-08

Reporting Date : 17-Dec-10 Till now the maximum generation is:-4698.5 MW at on 20-Aug-10 The Summary of Yesterday's (16-Dec-10) Generation & Demand Today's Actual Min Gen. & Probable Gen. & Demand Day Peak Generation 2736.0 MW 2130 Hour : 12:00 Min Gen. at 3:00 3625.7 Evening Peak Generation : MW Hour : 19:30 Max Generation 3888 MWE.P. Demand (at gen end): 3850.0 MW MW Hour : 19:30 Max Demand 4025 Maximum Generation 3625.7 MW 137 MW Hour : 19:30 Shortage Total Gen. (MKWH) 85.41% MW 67.02 System L/ Factor Load Shed 122 EXPORT/IMPORT THROUGH EAST-WEST INTERCONNECTOR Export from East grid to West grid :- Maximum 436 MW Energy 8486000 KWHR. at

Import from West grid to East grid :- Maximum - MW at - Energy - KWHR.

Water Level of Kaptai Lake at 6:00 A M of 17-Dec-10

Actual: 99.28 Ft.(MSL), Rule curve: 104.50 Ft.(MSL)

MMCFt.

Oil Consumed (PDB):
HSD : 1289985 Liter

FO : 712928 Liter

Load Despatch Circle

Cost of the Consumed Fuel (PDB): Gas : Tk39,986,788 Oil : Tk65,857,961 Total : Tk105,844,749

Load Shedding & Other Information

Gas Consumed :

Network Operation Division

Area	Yesterday		Today		
"			Estimated Demand(s/s end)	Estimated Shedding (s/s	Rates of Shedding
	MW		from toMW	MW	(On Estimated Demand)
Dhaka	86	(16:50-21:19 gen. shortage)	1553	27	2%
Chittagong Area	27	(16:45-21:18 gen. shortage)	431	23	5%
Khulna Area	28	(16:45-21:05 gen. shortage)	394	21	5%
Rajshahi Area	21	(16:45-21:17 gen. shortage)	322	16	5%
Comilla Area	18	(16:45-21:15 gen. shortage)	254	13	5%
Mymensing Area	8	(16:45-21:02 gen. shortage)	167	9	5%
Sylhet Area	-	0	196	-	-
Barisal Area	3	(16:45-21:05 gen. shortage)	76	4	5%
Rangpur Area	8	(16:45-21:17 gen. shortage)	180	9	5%
Total	199	19:30	3573	122	

Information of the Generating machines under shut down.

Planned Shut- Down		Forced Shut- Down
1) Haripur SBU GT-3 (18/06)	5/09) 9) Kaptai #3 (1/12/10)	1) Ghorasal 6(18/07/10)
2) Ghorasal 2(26/04/10)	10) Barapukuria-1(09/11/10)	2) Ashuganj-1(09/11/10)
3) Siddirganj GT-1 (18/06/10	0)	3) Sikalbaha 60MW(19/11/10)
4) Ashuganj-4(12/09/10)		4) Siddirganj-210MW(23/11/10)
5) Raozan-1 (03/10/10)		
6) Sikalbaha GT (24/10/10)		
7) Raozan-2 (21/10/10)		
8) Kaptai #5 (02/11/10)		

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description		Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak h	nour yesterday.	So about 199 MW (19:30) of load shed was imposed over the
b) Due to low gas pressure RPCL (210 MW) and Tongi and 75 MW respectively.	(105 MW) were limited to 107 MW	whole areas of the national grid .
c) Megnaghat GT-1,2 & ST tripped at 11:14 as lightning	arrester at 230 KV side(R-phase) of unit	
transformer(GT-1) burst and was synchronized at 01:23	(17/12/10),14:30 & 16:10 respectively.	
d) Bheramara GT-1 was forced shut down at 19:47 due e) Bheramara RPP was shut down at 20:10 due to com f) After maintenance Khulna-110 MW was synchronized g) Megnaghat - Comilla(N) 230 KV line-1 & 2 tripped at was switched on at 11:55. h) Khulshi 132/33 KV T3 transformer was shut down at switched on at 09:55(17/12/2010). i) Gulshan 132/33 KV T2 transformer was shut down at	mission of new machine. I at 21:10. 11:18 showing distance relays and 08:32 due to maintenance and was	
Deputy / Asstt. Manager	Manager	Deputy General Manager

Network Operation Division