

QF-LDC-08
Page -1

Reporting Date : 24-Oct-08
17-Sep-07

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Water Level of Kaptai Lake at 6:00 A M of

Gas Consumed :	Total	674.79	MMCFt.	Oil Consumed (PDB) :	SKO :	0	Liter
					HSD :	187515	Liter
					FO :	697109	Liter

Cost of the Consumed Fuel (PDB) : Gas	: Tk49,873,729	Oil	: Tk13,111,299	Total	: Tk62,985,028
---------------------------------------	----------------	-----	----------------	-------	----------------

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand (s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	17:30 6:00			
Dhaka	182		1532	75	5%
Chittagong Area	99		454	65	14%
Khulna Area	80		405	58	14%
Rajshahi Area	73		323	47	15%
Comilla Area	62		247	35	14%
Mymensing Area	43		188	27	14%
Sylhet Area	37		150	22	15%
Barisal Area	15		75	11	15%
Rangpur Area	34		157	22	14%
	(
Total	625	18:30	3531	362	

Planned Shut- Down	Forced Shut- Down
1) Khulna 60 MW (05/07/06)	8) Haripur SBU GT-1 (12/10/08)
	9) Haripur SBU GT-2 (12/10/08)
	10) Haripur SBU GT-3 (08/10/08)
	11) NEPC - 7 (13/10/08)
	12) Bheramara GT2 (17/10/08)
	13) RPCL St (20/10/08)
2) Kaptai- 3 (19/04/08)	
3) Raozan -1 (17/09/08)	
4) Sikalbaha St- (19/06/08)	
5) Shajibazar-2 (13/07/08)	
6) Shajibazar-4 (27/09/08)	
7) Ghorasal-1 (30/09/08)	
8) Ghorasal-2 (22/10/08)	

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday .	So about 625 MW (18:30) of load shed was imposed over the whole areas of the national grid.
b) Due to gas limitation, Ghorasal (780 MW), NEPC (110 MW), Siddhirganj (190 MW) and RPCL (210 MW) were limited to 690 MW, 78 MW, 120 MW and 69 MW respectively	
c) Due to gas limitation, Raozan -1, Sikalbaha Steam, Haripur SBU GT1, GT2 & GT3 and Shahjibazar -2, 4 and 6 are under shut down.	
d) After maintenance, Ashuganj CCGP GT1 and Steam were synchronized at 18:27 and 22:36 respectively	
e) Barisal GT-1 & 2 tripped at 18:10 and 18:23 respectively due to combustible fault and GT-2 was synchronized at 19:38. GT-1 will be synchronized before evening peak hour today.	
f) Khulna 110 MW was shut down at 23:20 due to condenser tube leakage.	
g) Natore 132/33 KV T1 transformer was under annual maintenance from 09:10 to 16:40.	
h) Ullon - Dhanmondi 132 KV line -1 was under shut down from 07:04 (24/10/08) to 09:50 due to cable termination at Ullon and Dhanmondi end.	
i) Bagerhat - Bhandaria 132 KV line tripped at 04:07 (24/10/08) from Bagerhat end showing ' E/F' and was switched on at 04:16.	

Deputy General Manager
Load Despatch Circle