

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	17-Sep-07	Reporting Date : 4-Jan-08
The Summary of Yesterday's (3-Jan-08) Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	2563.0	MW	Hour :	9:00	Min Gen. at	4:00	1947.5 MW
Evening Peak Generation :	3410.1	MW	Hour :	19:30	Max Generation :		3407 MW
E.P. Demand (at gen end) :	3600.0	MW	Hour :	19:30	Max Demand :		3500 MW
Maximum Generation :	3410.1	MW	Hour :	19:30	Shortage :		93 MW
Total Gen. (MKWH) :	61.36	System L/ Factor :		74.98%	Load Shed :		82 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :-	Maximum	378 MW	at	20:00	Energy	6105000 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW	at	-	Energy - KWHR.

Water Level of Kaptai Lake at 6:00 A M of

4-Jan-08

Actual :	99.99	Ft.(MSL) ,	Rule curve :	102.73	Ft.(MSL)		
Gas Consumed :	PDB	353.82	MMCFt.	Oil Consumed :	PDB	SKO :	0
	WMPL	9.49	MMCFt.			HSD :	320592
	RPCL	24.25	MMCFt.			FO :	412631
	NEPC	11.59	MMCFt.				Liter
	CDC (H+M)	116.79	MMCFt.				Liter
	Total	515.93	MMCFt.				
Cost of the Consumed Fuel (PDB) : Gas :		Tk26,150,793	Oil :	Tk13,065,757	Total :	Tk39,216,550	

Load Shedding & Other Information

Area	Yesterday		Today	
	Actual Shedding (s/s end), MW		Estimated Shedding (s/s end)	
	from 17:15	to 21:20	Estimated Demand(s/s end)	Estimated Shedding (s/s end)
			MW	MW
Dhaka	20		1320	-
Chittagong Area	30		365	16
Khulna Area	28		360	16
Rajshahi Area	28		265	13
Comilla Area	20		255	12
Mymensing Area	10		158	7
Sylhet Area	10		148	7
Barisal Area	6		60	3
Rangpur Area	15		140	8
Total	167	(19:30)	3071	82

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
	1) Haripur SBU GT -1 (19/05/05)
	2) Haripur SBU GT-3 (25/05/05)
	3) Baghabari-71MW(26/02/2006)
	4) Sahjibazar GT-8(29/07/06)
	5) Khulna 60 MW (05/07/06)
	6) Ashuganj -5(22/07/07)
	7) Khulna BMPP -1 (27/08/07)
	8) Ghorasal -5 (24/09/07)
	9) Ashuganj CCPP St-(20/10/07)
	10) Khulna BMPP -2 (03/12/07)
	11) WMPL - 1 (04/12/07)
	12) Barapukuria-1 (27/12/07)
	13) Ghorasal -1(14/12/07)
	14) Kaptai -3 (20/12/07)
	15) Sikalbaha ST (27/12/07)
	16) Siddhirganj (28/12/07)
	17) Rangpur GT-(28/12/07)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 167 MW (19:30) of load shed was imposed over the whole areas of the National grid.
b) After maintenance, Ashuganj CCPP GT-1 was synchronized at 16:21.	
c) After completion of project (90 MW) work , Fenchuganj CCPP GT-1 and GT-2 were synchronized at 19:06 and 18:40 respectively.	
d) After completion of project (90 MW) work, Fenchuganj P/S 132KV main bus ,Fenchugonj P/S - Fenchugonj S/S 132KV line -1, Fenchugonj - Sylhet 132 KV line 1 were switched on at 18:33,	
e) Feni 132/33 KV T2 transformer, Mymensing - RPCL 132 KV line -2 and Kabirpur 132 KV main bus were under annual maintenance from 08:33 to 15:19, 08:55 to 17:20 and 12:31 to 16:20 respectively.	
f) Haripur - Rampura 230 KV line -1 was under annual maintenance from 08:39 to 15:57.	
g) After annual maintenance, Ghorasal - Ishurdi EWIC 230 KV line -2 was switched on at 16:25.	
h) After annual maintenance, Ashuganj - Ghorasal 132 KV line 1, Madanhata - Kaptai 132 KV line -1 and Aminbazar - Mirpur 132 KV line 1 were switched on 18:27,15:45 and 17:06 respectively.	
i) Ishurdi - Bheramara 132 KV line -1, Ghorasal -Ashuganj 132 KV line -2, Mirpur - Aminbazar 132 KV line -1 and Maniknagar - Narinda 132 KV line -1 are under annual maintenance since 07:50 (04/01/08), 07:55, 08:10 and 08:00 respectively	
j) Hathazari - Feni 132 KV line -2 and Joydevpur - Ghorasal 132 KV line -1 were under shut down from 08:17 to 15:27 and 08:30 to 17:32 respectively for annual maintenance.	

Deputy / Asstt. Manager
Load Despatch DivisionManager
Load Despatch DivisionDeputy General Manager
Load Despatch Circle