

DAILY REPORT

Till now the maximum generation is :-		4130.0 MW	at	20:00	on	17-Sep-07	Reporting Date : 5-Jan-08
The Summary of Yesterday's (4-Jan-08) Generation & Demand		Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	2392.0	MW	Hour :	9:00	Min Gen. at	4:00	1947.5 MW
Evening Peak Generation :	3464.2	MW	Hour :	18:30	Max Generation :		3631 MW
E.P. Demand (at gen end) :	3550.0	MW	Hour :	18:30	Max Demand :		3550 MW
Maximum Generation :	3497.1	MW	Hour :	20:00	Shortage :		0 MW
Total Gen. (MKWH) :	59.74	System L/ Factor :		71.18%	Load Shed :		-- MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :-	Maximum	390 MW	at	20:00	Energy	7293000 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW	at	-	Energy - KWHR.

Water Level of Kaptai Lake at 6:00 A M of

5-Jan-08

Actual :	99.91	Ft.(MSL) ,	Rule curve :	102.24	Ft.(MSL)
Gas Consumed : : PDB	330.79	MMCFt.	Oil Consumed :		
WMPL	9.65	MMCFt.	PDB		
RPCL	30.75	MMCFt.	SKO :	0	Liter
NEPC	8.47	MMCFt.	HSD :	357022	Liter
CDC (H+M)	113.61	MMCFt.	FO :	412631	Liter
Total	493.26	MMCFt.			
Cost of the Consumed Fuel (PDB) : Gas :		Tk24,448,740	Oil :	Tk13,987,791	Total : Tk38,436,531

Load Shedding & Other Information

Area	Yesterday			Today		
	Actual Shedding (s/s end), MW			Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from	17:30	to 21:20			
Dhaka		15		1300	-	-
Chittagong Area		10		340	-	-
Khulna Area		10		315	-	-
Rajshahi Area		10		320	-	-
Comilla Area		7		260	-	-
Mymensing Area		6		180	-	-
Sylhet Area		5		150	-	-
Barisal Area		6		60	-	-
Rangpur Area		6		173	-	-
Total		75	(18:30)	3098	0	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
	1) Haripur SBU GT -1 (19/05/05)
	2) Haripur SBU GT-3 (25/05/05)
	3) Baghabari-71MW(26/02/2006)
	4) Sahjibazar GT-8(29/07/06)
	5) Khulna 60 MW (05/07/06)
	6) Ashuganj -5(22/07/07)
	7) Khulna BMPP -1 (27/08/07)
	8) Ghorasal -5 (24/09/07)
	9) Ashuganj CCPP St-(20/10/07)
	10) Khulna BMPP -2 (03/12/07)
	11) WMPL - 1 (04/12/07)
	12) Barapukuria-1 (27/12/07)
	13) Ghorasal -1(14/12/07)
	14) Kaptai -3 (20/12/07)
	15) Sikalbaha ST (27/12/07)
	16) Rangpur GT-(28/12/07)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 75 MW (18:30) of load shed was imposed over the whole areas of the National grid.
b) After maintenance, Siddhirganj 210 MW was synchronized at 18:57.	
c) Tongi 132/33 KV T2 & T1 transformers, Rampura - Magbazar 132 KV line and Tongi - Kabirpur 132 KV line -1 were under annual maintenance from 08:47 to 16:20, 09:16 to 13:30, 09:26 to 17:08 and 09:07 to 16:23 respectively.	
d) After annual maintenance, Ishurdi - Bheramara 132 KV line -1, Ghorasal - Ashuganj 132 KV line -2, Mirpur - Aminbazar 132 KV line -1 and Maniknagar - Narinda 132 KV line -1 were switched on at 18:03, 15:51, 16:35 and 16:54 respectively.	
e) Madaripur - Barisal 132 KV line -1, Mymensing Netrokona 132 KV line -2, Ishurdi - Bheramara 132 KV line -2, Madanhat - Kaptai 132 KV line, Kabirpur - Manikganj 132 KV line -1 and Comilla (N) - Feni 132 KV line -2 are under annual maintenance since 07:06(05/1/08), 07:14, 07:28, 07:32, 08:02 and 08:32 respectively .	
f) Sylhet 132 KV bus section - III and Sylhet - Chatak 132 KV line - 1 & 2 were shut down at 08:40 for annual maintenance. At 09:13 hrs, Chatak 33 KV loop snapped . So Chatak was fully interrupted. Bus section - III and Sylhet Chatak line -1 & 2 were switched on at 12:45, 13:47 and 12:43 respectively.	Power interruption occurred under Chatak S/S areas from 09:13 to 12:43.
g) Jessore - Noapara 132 KV line -2 is under shut down since 08:06 (05/01/08) due to by passing one tower.	

Deputy / Asstt. Manager
Load Despatch DivisionManager
Load Despatch DivisionDeputy General Manager
Load Despatch Circle