

DAILY REPORT

Reporting Date : 6-Jan-08

Till now the maximum generation is :-

4130.0 MW at

20:00 on

17-Sep-07

The Summary of Yesterday's (5-Jan-08) Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand		
Day Peak Generation :	2578.0	MW	Hour :	9:00	Min Gen. at 5:00	2005 MW
Evening Peak Generation :	3643.8	MW	Hour :	18:30	Max Generation :	3673 MW
E.P. Demand (at gen end) :	3770.0	MW	Hour :	18:30	Max Demand :	3775 MW
Maximum Generation :	3667.3	MW	Hour :	19:00	Shortage :	102 MW
Total Gen. (MKWH) :	62.45	System L/ Factor :	70.96%	Load Shed :		91 MW

EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR

Export from Ghorasal to Ishurdi :-	Maximum	362 MW	at 19:00	Energy	7639500 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW at -	Energy	- KWHR.

Water Level of Kaptai Lake at 6:00 A M of

6-Jan-08

Actual :	99.82	Ft.(MSL) ,	Rule curve :	102.05	Ft.(MSL)
Gas Consumed :	PDB	356.35	MMCFt.	Oil Consumed :	
	WMPL	9.87	MMCFt.	PDB	
	RPCL	26.21	MMCFt.	SKO :	0
	NEPC	8.93	MMCFt.	HSD :	414525
	CDC (H+M)	111.83	MMCFt.	FO :	409234
	Total	513.19	MMCFt.		Liter

Cost of the Consumed Fuel (PDB) : Gas : Tk26,338,157 Oil : Tk15,402,417 Total : Tk41,740,574

Load Shedding & Other Information

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from 17:20	to 21:30			
Dhaka	-		1390	-	-
Chittagong Area	-		420	18	4%
Khulna Area	96		330	15	5%
Rajshahi Area	-		328	15	5%
Comilla Area	-		300	14	5%
Mymensing Area	-		210	10	5%
Sylhet Area	-		162	8	5%
Barisal Area	17		60	3	5%
Rangpur Area	-		175	8	5%
Total	113	(18:30)	3375	91	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
	1) Haripur SBU GT -1 (19/05/05)
	2) Haripur SBU GT-3 (25/05/05)
	3) Baghabari-71MW(26/02/2006)
	4) Sahjibazar GT-8(29/07/06)
	5) Khulna 60 MW (05/07/06)
	6) Ashuganj -5(22/07/07)
	7) Khulna BMPP -1 (27/08/07)
	8) Ghorasal -5 (24/09/07)
	9) Ashuganj CCPP St-(20/10/07)
	10) Khulna BMPP -2 (03/12/07)
	11) WMPL - 1 (04/12/07)
	12) Barapukuria-1 (27/12/07)
	13) Ghorasal -1(14/12/07)
	14) Sikabaha ST (27/12/07)
	15) Rangpur GT-(28/12/07)

Additional Information of Machines, lines, Interruption / Forced Load shed etc.

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 113 MW (18:30) of load shed was imposed over the Khulna & Barisal areas of the National grid.
b) After annual maintenance, Ishurdi - Bheramara 132 KV line -2 was switched on at 21:07,	
c) After maintenance, Kaptai unit -3 was synchronized (on test run) at 14:32 and was shut down at 21:45.	
d) Hathazari - Raozan 230 KV line -1, Hasnabad - Meghnaghat 230 KV line -1, Hasnabad - Aminbazar 230 KV line -2, Rampura- Ghorasal 230 KV line -1 were under annual maintenance from 09:06 to 21:15, 08:49 to 17:31, 08:50 to 17:17 and 08:52 to 16:44 respectively.	
e) Maniknagar - Narinda 132 KV line-2, Sylhet - Fenchuganj 90 MW 132 KV line -2, Shyampur - Haripur 132 KV line, Ullon - Siddhirganj 132 KV line -1, Kabirpur 132 KV main bus, Mymensing - RPCL 132 KV line -1, Jhenidaha - Bottail 132 KV line -1, Shahjadpur - Ullapara 66 KV line and Joydevpur - Ghorasal 132 KV line -1 were under annual maintenance from 08:45 to 15:30, 09:04 to 12:51, 09:04 to 16:45, 08:55 to 14:22, 09:30 to 16:32 , 09:42 to 15:50, 08:43 to 17:05, 08:50 to 17:09 and 09:51 to 18:07 respectively.	
f) After annual maintenance, Madaripur - Barisal 132 KV line -1, Mymensing Netrokona 132 KV line -2, , Madanhat - Kaptai 132 KV line, Kabirpur - Manikganj 132 KV line -1 and Comilla (N) - Feni 132 KV line -2 were switched on at 16:13, 16:10, 15:54, 16:58 and 13:57 respectively.	
g) Madanhat - Kaptai 132 KV line -1, Ishurdi - Bheramara 132 KV line -1 and Madaripur - Barisal 132 KV line -1 are under shut down since 07:24 (06/01/08), 07:40 and 07:10 respectively.	
h) Mymensing - Netrokona 132 KV line 2 are under shut down since 06:45 (06/01/08) due to installation of optical fiber.	

Deputy / Asstt. Manager
Load Despatch DivisionManager
Load Despatch DivisionDeputy General Manager
Load Despatch Circle