

**DAILY REPORT**

Reporting Date : 10-Jan-08

Till now the maximum generation is :-

4130.0 MW at

20:00 on

17-Sep-07

The Summary of Yesterday's ( 9-Jan-08 ) Generation & Demand				Today's Actual Min Gen. & Probable Gen. & Demand			
Day Peak Generation :	2779.0	MW	Hour :	10:00	Min Gen. at	4:00	2051 MW
Evening Peak Generation :	3209.9	MW	Hour :	18:30	Max Generation :		3175 MW
E.P. Demand (at gen end) :	3900.0	MW	Hour :	18:30	Max Demand :		3900 MW
Maximum Generation :	3213.0	MW	Hour :	20:00	Shortage :		725 MW
Total Gen. (MKWH) :	62.93	System L/ Factor :		81.61%	Load Shed :		638 MW

**EXPORT / IMPORT THROUGH EAST-WEST INTERCONNECTOR**

Export from Ghorasal to Ishurdi :-	Maximum	306 MW	at	19:30	Energy	6550500 KWHR.
Import from Ishurdi to Ghorasal:-	Maximum	-	MW	at	-	Energy - KWHR.

Water Level of Kaptai Lake at 6:00 A M of

10-Jan-08

Actual :	99.40	Ft.(MSL) ,	Rule curve :	101.29	Ft.( MSL )			
Gas Consumed :	PDB	445.82	MMCFt.	Oil Consumed :	PDB	SKO :	0	Liter
	WMPL	10.13	MMCFt.			HSD :	265989	Liter
	RPCL	33.04	MMCFt.			FO :	410366	Liter
	NEPC	18.97	MMCFt.					
	CDC (H+M)	55.58	MMCFt.					
	Total	563.53	MMCFt.					

Cost of the Consumed Fuel (PDB) : Gas : Tk32,950,390 Oil : Tk11,656,560 Total : Tk44,606,951

**Load Shedding & Other Information**

Area	Yesterday		Today		
	Actual Shedding (s/s end), MW		Estimated Demand(s/s end)	Estimated Shedding (s/s end)	Rates of Shedding (On Estimated Demand)
	from 17:15	to 21:57			
Dhaka	98		1425	120	8%
Chittagong Area	89		425	110	26%
Khulna Area	93		370	96	26%
Rajshahi Area	93		315	80	25%
Comilla Area	61		295	76	26%
Mymensing Area	53		192	50	26%
Sylhet Area	51		170	44	26%
Barisal Area	15		70	18	26%
Rangpur Area	54		170	44	26%
Total	607	( 18:30 )	3432	638	

Information of the Generating machines under maintenance

Planned Shut- Down	Forced Shut- Down
	1) Haripur SBU GT -1 (19/05/05)
	2) Haripur SBU GT-3 (25/05/05)
	3) Baghabari-71MW(26/02/2006)
	4) Sahjibazar GT-8(29/07/06)
	5) Khulna 60 MW (05/07/06)
	6) Ashuganj -5(09/01/08)
	7) Khulna BMPP -1 (27/08/07)
	8) Ghorasal -5 (24/09/07)
	9) Ashuganj CCPP St-(20/10/07)
	10) Khulna BMPP -2 (03/12/07)
	11) WMPL - 1 (04/12/07)
	12) Barapukuria-1 (27/12/07)
	13) Ghorasal -1(09/01/08)
	14) Rangpur GT-(28/12/07)
	15) Meghnaghat Gt-1,2 & st - (06/01/08)
	16) Ashuganj -1 (07/01/08)
	17) Raozan unit -1 (07/01/08)

**Additional Information of Machines, lines, Interruption / Forced Load shed etc.**

Description	Forced load shaded / Interrupted Areas
a) There was generation shortage in the evening peak hour yesterday.	So about 607 MW (18:30) of load shed was imposed over the whole area of the National grid.
b) After maintenance, Ghorasal - 1 was synchronized at 15:26 on test run and was shutdown at 22:40.	
c) After annual maintenance, Barisal - Madaripur 132 KV line -2 and Ghorasal - Bhulta 132 KV line was switched on at 13:58 and 17:37 respectively.	
d) Tongi 230/132 KV T02 X-former , Hathazari - Raozan 230 KV line 2 and Hasnabad 230/132 KV T02 X-former were under annual maintenance 08:15 to 15:35, 09:14 to 16:14 and 09:50 to 17:12 respectively.	
e) After installation of optical fiber, Sylhet - Chatak 132 KV line -1 was switched on at 16:13. Again it is under shut down since 06:44 (10/01/08) due to the same reason.	
f) Sikalbaha - Dohazari 132 KV line 1, Natore -Rajshahi 132 KV line 1, Purbasadipur - Thakurgaon 132 KV line 1, Hathazari - Feni 132 KV line 2, Siddirganj 132/33 KV T1 X-former, Comilla(S) 132/33 KV X-former T1, Jhenaidah - Bottail 132 KV line 1, Mymensing - Jamalpur 132 KV line 1 and Faridpur 132/33 KV T1X-former were under annual maintenance 08:10 to 17:10, 08:46 to 17:34, 09:05 to 15:30, 09:04 to 14:28, 09:32 to 14:04, 09:02 to 14:15, 08:54 to 18:23, 09:16 to 14:55 and 15:05 to 16:25 respectively	
g) Faridpur 132/33 KV T1 X-former were under protection test from 11:55 to 14:33.	
h) Ghorasal - Bhulta 132 KV line is under annual maintenance since 07:42 (10/01/08).	

Deputy / Asstt. Manager  
Load Despatch DivisionManager  
Load Despatch DivisionDeputy General Manager  
Load Despatch Circle